



NOTE:
SERVICE SHALL HAVE 18" MIN.
AT METER, AND 30" MIN. COVER
BETWEEN MAIN AND METER

MAINTAIN 4' DEPTH TO AVOID
CONFLICT WITH OTHER UTILITIES

NOTES:

1. SERVICE LINE SHALL BE 1" FROM MAIN TO METER
2. USE ALL FLARE JOINTS
3. INSTALLATION SHALL ALLOW ADEQUATE ROOM TO REMOVE AND/OR REPAIR METER
4. METER BOX SHALL BE APPROXIMATELY 18" X 24"
5. TYPE K COPPER SERVICE LINE MUST BE CONTINUOUS FROM METER TO MAIN

FULTON COUNTY STANDARD DETAIL 602
1" METER INSTALLATION

DATE	REVISIONS	DATE	REVISIONS
8/08	NRR		

DGS/DRN/CS/KO: OMS
APPROVED: ML
DATE: 12-2-05



FULTON COUNTY PUBLIC WORKS
141 PRYOR ST. ATLANTA, GA. 30303
404-612-7400 FAX: 404-224-0498

DRAWING NO.
602