



NOTES:

1. VALVE MARKER REQUIRED.
2. A&V VALVE AND COPPER SHALL BE SIZED IN ACCORDANCE WITH VALVE MANUFACTURERS RECOMMENDATIONS.
3. METER BOX SHALL BE CDR-10 X 15HC OR APPROVED EQUAL.
4. A & V VALVE SHALL BE VENT-Q/M/AT SERIES RBX OR EQUAL.

**FULTON COUNTY STANDARD DETAIL 817
A & V RELEASE VALVE ASSEMBLY
1" OR 2"**

DATE	REVISIONS	DATE	REVISIONS
8/08	NRR		

DGS/DRN/CHKD: CMS
APPROVED: _____
DATE: 12-2-05



FULTON COUNTY PUBLIC WORKS
141 PRYOR ST. ATLANTA, GA. 30303
404-612-7400 FAX: 404-224-0498

DRAWING NO.
817