

**Fulton County ADA Transition Plan
ARTS AND CULTURE
Appendix 7-10**

Department	Bldg Name	Address	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction	Priority	Cost
Arts and Culture	Abernathy Arts Center and Crafts	254 Johnson Ferry Rd. Sandy Springs, GA 30328	Basement Entrance	Mat is not securely attached to the floor.	\$302.2	Provide a securely attached mat with a leveled loop or level cut pile, with texture height that is 0.5" (13 mm) max. and has a firm cushion pad or backing (2010 ADA Fig. 302.2).	A	\$55.00
Arts and Culture	Abernathy Arts Center and Crafts	254 Johnson Ferry Rd. Sandy Springs, GA 30328	Emergency Exit at Workshop	Emergency exit signage is mounted on the ceiling.	\$703.4.1	Provide additional signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. from the baseline of the highest tactile character (2010 ADA Fig. 703.4.1).	A	\$149.95
Arts and Culture	Abernathy Arts Center and Crafts	254 Johnson Ferry Rd. Sandy Springs, GA 30328	Main Entrance	Accessible entrance does not have signage displaying the international symbol of accessibility.	\$216.6	Provide signage at accessible entrance displaying the International symbol of accessibility.	B	\$149.95
Arts and Culture	Abernathy Arts Center and Crafts	254 Johnson Ferry Rd. Sandy Springs, GA 30328	Basement Entrance	Accessible entrance does not have signage displaying the international symbol of accessibility.	\$216.6	Provide signage at accessible entrance displaying the International symbol of accessibility.	B	\$149.95
Arts and Culture	Abernathy Arts Center and Crafts	254 Johnson Ferry Rd. Sandy Springs, GA 30328	Accessible Route From Accessible Parking Spaces Leading to Main Entrance	There is no signage posted indicating the location of an accessible entrance.	\$216.6	Post signage indicating location of the accessible entrance serving the facility. If sign is to be placed overhead it shall have a minimum character height of 3" (76 mm). We recommend providing a small segment of sidewalk over the planters and connect with sidewalk at Public Rights-of-Way, to avoid excessive slope issues when traversing over driveway. A small ramp may be necessary, if a small ramp is needed try to extend the ramp run so as to provide the least running slope possible not exceeding 5%, so that it does not trigger requirement for handrails that may increase the cost substantially	B	\$149.95
Arts and Culture	Abernathy Arts Center and Crafts	254 Johnson Ferry Rd. Sandy Springs, GA 30328	Accessible Route From Accessible Parking Spaces Leading to Main Entrance	Accessible route has a non-compliant cross slope of 7.1 % that extends 10 ft (3.04 mt).	\$403.3	We recommend providing a small segment of sidewalk over the planters and connect with sidewalk at Public Rights-of-Way, to avoid excessive slope issues when traversing over driveway. A small ramp may be necessary, if a small ramp is needed try to extend the ramp run so as to provide the least running slope possible not exceeding 5%, so that it does not trigger requirement for handrails that may increase the cost substantially	B	\$0.00
Arts and Culture	Abernathy Arts Center and Crafts	254 Johnson Ferry Rd. Sandy Springs, GA 30328	Accessible Route From Accessible Parking Spaces Leading to Main Entrance	Accessible route has a non-compliant cross slope of 5.3 % that extends 10 ft (3.04 mt).	\$403.3	We recommend providing a small segment of sidewalk over the planters and connect with sidewalk at Public Rights-of-Way, to avoid excessive slope issues when traversing over driveway. A small ramp may be necessary, if a small ramp is needed try to extend the ramp run so as to provide the least running slope possible not exceeding 5%, so that it does not trigger requirement for handrails that may increase the cost substantially	B	\$2,750.00
Arts and Culture	Abernathy Arts Center and Crafts	254 Johnson Ferry Rd. Sandy Springs, GA 30328	Main Entrance	Maneuvering clearance on the pull side of the door has non-compliant slope of 2.8 %.	\$404.2.4	Rework area to provide the required 18" (457 mm) min. maneuvering clearance on the pull side of the door beyond the latch side and 60" (1524 mm) min. deep clear floor leveled area with slopes not exceeding 1:48 (2010 ADA Fig. 404.2.4.1). Reverse door swing so that it opens towards the inside of the workshop or install an automatic door opener or rework area to provide the required 18" (457 mm) min. maneuvering clearance on the pull side of the door beyond the latch side and 60" (1524 mm) min. deep clear floor leveled area with slopes not exceeding 1:48 (2010 ADA Fig. 404.2.4.1).	B	\$450.00
Arts and Culture	Abernathy Arts Center and Crafts	254 Johnson Ferry Rd. Sandy Springs, GA 30328	Basement Entrance	Door does not have the required maneuvering clearance on the pull side.	\$404.2.4	Reverse door swing so that it opens towards the inside of the workshop or install an automatic door opener or rework area to provide the required 18" (457 mm) min. maneuvering clearance on the pull side of the door beyond the latch side and 60" (1524 mm) min. deep clear floor leveled area with slopes not exceeding 1:48 (2010 ADA Fig. 404.2.4.1).	B	\$1,500.00
Arts and Culture	Abernathy Arts Center and Crafts	254 Johnson Ferry Rd. Sandy Springs, GA 30328	Emergency Exit at Workshop	Trash bin encroaches over maneuvering clearance on the push side of the door.	\$404.2.4	Relocate trash bin to provide the required 12" (304 mm) min. maneuvering clearance on the push side of the door handle side (2010 ADA Fig. 404.2.4.1).	B	\$55.00
Arts and Culture	Abernathy Arts Center and Crafts	254 Johnson Ferry Rd. Sandy Springs, GA 30328	Main Entrance	Non-compliant hardware, requiring grasping and turning of the wrist to operate.	\$404.2.7	Replace or retrofit with system operable with one hand, not requiring pinching, tight grasping or turning of the wrist to operate.	B	\$291.64
Arts and Culture	Abernathy Arts Center and Crafts	254 Johnson Ferry Rd. Sandy Springs, GA 30328	Unmarked Class Room by Main Entrance	Non-compliant knob-type door hardware, requiring grasping and turning of the wrist to operate.	\$404.2.7	Replace or retrofit with system operable with one hand, not requiring pinching, tight grasping or turning of the wrist to operate.	B	\$291.64
Arts and Culture	Abernathy Arts Center and Crafts	254 Johnson Ferry Rd. Sandy Springs, GA 30328	Restroom at Basement	Non-compliant knob-type door hardware, requiring grasping and turning of the wrist to operate.	\$404.2.7	Replace or retrofit with system operable with one hand, not requiring pinching, tight grasping or turning of the wrist to operate.	B	\$291.64
Arts and Culture	Abernathy Arts Center and Crafts	254 Johnson Ferry Rd. Sandy Springs, GA 30328	Men's Accessible Restroom	Door has a non-compliant opening force of 8 lbf.	\$404.2.9	Adjust or replace door closer, maintain door hinges to provide an opening force not to exceed 5 lbf.	B	\$131.00
Arts and Culture	Abernathy Arts Center and Crafts	254 Johnson Ferry Rd. Sandy Springs, GA 30328	Accessible Route From Accessible Parking Spaces Leading to Main Entrance	Ramp handrails have non-compliant extensions at top landing	\$405.5	Provide handrails extensions 12" (304 mm) min. beyond the top and bottom of the ramp segment (2010 ADA Fig. 505.10.1).	B	\$360.00
Arts and Culture	Abernathy Arts Center and Crafts	254 Johnson Ferry Rd. Sandy Springs, GA 30328	Accessible Route From Accessible Parking Spaces Leading to Main Entrance	Ramp handrails are mounted at 33.25" (845 mm) above the finish floor to top of gripping surfaces,	\$405.8	For ramps rising over 6" (152 mm) provide handrails on both sides of ramp and mount between 34" and 38" (863 mm - 965 mm) above the ramp surface to top of gripping surfaces, extending 12" (304 mm) min. beyond the top and bottom of the ramp segment (2010 A	B	\$4,000.00
Arts and Culture	Abernathy Arts Center and Crafts	254 Johnson Ferry Rd. Sandy Springs, GA 30328	Accessible Route From Accessible Parking Spaces Leading to Main Entrance	Ramp handrails have non-compliant extensions that are 4.5" (114 mm) long.	\$405.8	Provide handrails extensions 12" (304 mm) min. beyond the top and bottom of the ramp segment (ADAAG Fig. 17).	BA	\$360.00
Arts and Culture	Abernathy Arts Center and Crafts	254 Johnson Ferry Rd. Sandy Springs, GA 30328	Classroom No. 2	Permanent room identifying signage does not have Braille or raised characters and is mounted on the hinge side of the door.	\$703.4.1	Provide signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. from the baseline of the highest tactile character (2010 ADA Fig. 703.4.1).	B	\$55.00
Arts and Culture	Abernathy Arts Center and Crafts	254 Johnson Ferry Rd. Sandy Springs, GA 30328	Women's Accessible Restroom	Permanent room identifying signage does not have Braille or raised characters and is mounted on the door leaf.	\$703.4.1	Provide signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. from the baseline of the highest tactile character (2010 ADA Fig. 703.4.1).	B	\$149.95
Arts and Culture	Abernathy Arts Center and Crafts	254 Johnson Ferry Rd. Sandy Springs, GA 30328	Men's Accessible Restroom	Permanent room identifying signage does not have Braille or raised characters and is mounted on the door leaf.	\$703.4.1	Provide signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. from the baseline of the highest tactile character (2010 ADA Fig. 703.4.1).	B	\$149.95
Arts and Culture	Abernathy Arts Center and Crafts	254 Johnson Ferry Rd. Sandy Springs, GA 30328	Classroom No 3	Permanent room identifying signage does not have Braille or raised characters.	\$703.4.1	Provide signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. from the baseline of the highest tactile character (2010 ADA Fig. 703.4.1).	B	\$149.95
Arts and Culture	Abernathy Arts Center and Crafts	254 Johnson Ferry Rd. Sandy Springs, GA 30328	Restroom at Basement	Restroom does not have sign with Braille or raised characters mounted on the latch side of door	\$703.4.1	Provide signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. from the baseline of the highest tactile character (2010 ADA Fig. 703.4.1).	B	\$149.95
Arts and Culture	Abernathy Arts Center and Crafts	254 Johnson Ferry Rd. Sandy Springs, GA 30328	Workshop at Basement	Mat is not securely attached to the floor.	\$302.2	Provide a securely attached mat with a leveled loop or level cut pile, with texture height that is 0.5" (13 mm) max. and has a firm cushion pad or backing (2010 ADA Fig. 302.2).	C	\$55.00
Arts and Culture	Abernathy Arts Center and Crafts	254 Johnson Ferry Rd. Sandy Springs, GA 30328	Outdoor Seating Area by Main Entrance	Mat is not securely attached to the floor.	\$302.2	Provide a securely attached mat with a leveled loop or level cut pile, with texture height that is 0.5" (13 mm) max. and has a firm cushion pad or backing (2010 ADA Fig. 302.2).	C	\$55.00
Arts and Culture	Abernathy Arts Center and Crafts	254 Johnson Ferry Rd. Sandy Springs, GA 30328	Corridor by Accessible Restroom	Fire extinguisher protrudes into walkway, projecting 6" (152 mm) from back wall, and is mounted at 48.25" (1226 mm) above the finished floor to its bottom leading edge.	\$307.2	Relocate or recess fire extinguisher so that it does not project more than 4" (101 mm) from back wall to outer leading edge (2010 ADA Fig. 307.2).	C	\$131.00
Arts and Culture	Abernathy Arts Center and Crafts	254 Johnson Ferry Rd. Sandy Springs, GA 30328	Women's Accessible Restroom	Paper towel dispenser protrudes into walkway, projecting 8.5" (216 mm) from back wall.	\$307.2r	Relocate or recess paper towel dispenser so that it does not project more than 4" (101 mm) from back wall to outer leading edge (2010 ADA Fig. 307.2).	C	\$131.00
Arts and Culture	Abernathy Arts Center and Crafts	254 Johnson Ferry Rd. Sandy Springs, GA 30328	Men's Accessible Restroom	Paper towel dispenser protrudes into walkway, projecting 11" (279 mm) from back wall, and is mounted at 46.75" (1187 mm) above the finished floor to its bottom leading edge.	\$307.2r	Relocate or recess paper towel dispenser so that it does not project more than 4" (101 mm) from back wall to outer leading edge (2010 ADA Fig. 307.2).	C	\$131.00

**Fulton County ADA Transition Plan
ARTS AND CULTURE
Appendix 7-10**

Department	Bldg Name	Address	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction	Priority	Cost
Arts and Culture	Abemathy Arts Center and Crafts	254 Johnson Ferry Rd. Sandy Springs, GA 30328	Unmarked Class Room by Main Entrance	Soap dispenser is mounted beyond required reach ranges over an obstruction (counter).	§308.2.1	Lower or install soap dispenser at 44" (1219 mm) max. above the finished floor, over a 20" - 25" (510 mm - 1120 mm) max. obstruction for forward approach to object (2010 ADA Fig. 308.2.1).	C	\$131.00
Arts and Culture	Abemathy Arts Center and Crafts	254 Johnson Ferry Rd. Sandy Springs, GA 30328	Kitchenette	Paper towel dispenser is mounted beyond required reach allowed for approach provided and is mounted at 53.25" (1353 mm) above the finished floor to paper.	§308.2.1	Lower or install paper towel dispenser at 48" (1219 mm) max. above the finished floor to paper for forward approach to object (2010 ADA Fig. 308.3.1). Per 36.304(d)(2)(i) Safe harbor. Elements that comply with the corresponding technical requirements and scoping requirements for those elements in the 1991 Standards do not need to be modified in order to comply with the requirements set forth in the 2010 Standards.	C	\$0.00
Arts and Culture	Abemathy Arts Center and Crafts	254 Johnson Ferry Rd. Sandy Springs, GA 30328	Corridor Leading to Accessible Restrooms	Thermostat is mounted beyond required reach allowed for approach provided and is mounted at 62" (1575 mm) above the finished floor to the highest operable part.	§308.2.1	Lower or install thermostat at 48" (1219 mm) max. above the finished floor to the highest operable part (2010 ADA Fig. 308.2.1).	C	\$378.14
Arts and Culture	Abemathy Arts Center and Crafts	254 Johnson Ferry Rd. Sandy Springs, GA 30328	Women's Accessible Restroom	Paper towel dispenser is mounted beyond required reach allowed for approach provided and is mounted at 58" (1473 mm) above the finished floor to the highest operable part.	§308.2.1	Lower or install paper towel dispenser at 48" (1219 mm) max. above the finished floor to the highest operable part (2010 ADA Fig. 308.3.1).	C	\$0.00
Arts and Culture	Abemathy Arts Center and Crafts	254 Johnson Ferry Rd. Sandy Springs, GA 30328	Women's Accessible Restroom	Privacy lock is mounted beyond required reach allowed for approach provided and is mounted at 59" (1499 mm) above the finished floor.	§308.2.1	Lower or install at privacy lock 48" (1219 mm) max. above the finished floor for forward approach to object (2010 ADA Fig. 308.2.1).	C	\$0.00
Arts and Culture	Abemathy Arts Center and Crafts	254 Johnson Ferry Rd. Sandy Springs, GA 30328	Men's Accessible Restroom	Paper towel dispenser is mounted beyond required reach allowed for approach provided and is mounted at 52.75" (1340 mm) above the finished floor to the highest operable part.	§308.2.1	Lower or install paper towel dispenser at 48" (1219 mm) max. above the finished floor to the highest operable part for forward approach to object (2010 ADA Fig. 308.3.1).	C	\$0.00
Arts and Culture	Abemathy Arts Center and Crafts	254 Johnson Ferry Rd. Sandy Springs, GA 30328	Men's Accessible Restroom	Privacy lock is mounted beyond required reach allowed for approach provided and is mounted at 59.5" (1511 mm) above the finished floor.	§308.2.1	Lower or install privacy lock at 48" (1219 mm) max. above the finished floor for forward approach to object (2010 ADA Fig. 308.2.1).	C	\$0.00
Arts and Culture	Abemathy Arts Center and Crafts	254 Johnson Ferry Rd. Sandy Springs, GA 30328	Corridor by Accessible Restroom	Fire extinguisher is mounted beyond required reach allowed for approach provided and is mounted at 65" (1651 mm) above the finished floor to the hook.	§308.2.1	Lower or install fire extinguisher at 48" (1219 mm) max. above the finished floor for forward approach to object (2010 ADA Fig. 308.2.1).	C	\$0.00
Arts and Culture	Abemathy Arts Center and Crafts	254 Johnson Ferry Rd. Sandy Springs, GA 30328	Classroom No 3	Paper towel dispenser is mounted beyond required reach allowed for approach provided over an obstruction (sink counter).	§308.2.1	Lower or install paper towel dispenser at 44" (1219 mm) max. above the finished floor to highest operable part, over a 20" - 25" (510 mm - 1120 mm) max. obstruction, for forward approach to object (2010 ADA Fig. 308.2.1).	C	\$131.00
Arts and Culture	Abemathy Arts Center and Crafts	254 Johnson Ferry Rd. Sandy Springs, GA 30328	Classroom No 3	Soap dispenser is mounted beyond required reach allowed for approach provided at 51" (1295 mm) above the finished floor over an obstruction (sink counter).	§308.2.1	Lower or install soap dispenser at 44" (1219 mm) max. above the finished floor to the highest operable part, over a 20" - 25" (510 mm - 1120 mm) max. obstruction, for forward approach to object (2010 ADA Fig. 308.2.1).	C	\$131.00
Arts and Culture	Abemathy Arts Center and Crafts	254 Johnson Ferry Rd. Sandy Springs, GA 30328	Restroom at Basement	Soap dispenser is mounted beyond required reach allowed for approach provided and is mounted at 52.25" (1327 mm) above the finished floor to the highest operable part.	§308.2.1	Lower or install soap dispenser at 48" (1219 mm) max. above the finished floor to the highest operable part (2010 ADA Fig. 308.2.1).	C	\$131.00
Arts and Culture	Abemathy Arts Center and Crafts	254 Johnson Ferry Rd. Sandy Springs, GA 30328	Restroom at Basement	Paper towel dispenser is mounted beyond required reach allowed for approach provided and is mounted at 56.25" (1429 mm) above the finished floor to highest operable part.	§308.2.1	Lower or install paper towel dispenser at 48" (1219 mm) max. above the finished floor to highest operable part (2010 ADA Fig. 308.3.1).	C	\$131.00
Arts and Culture	Abemathy Arts Center and Crafts	254 Johnson Ferry Rd. Sandy Springs, GA 30328	Corridor Leading to Classroom No. 2	Coat hook is mounted beyond required reach allowed for approach provided and is mounted at 52.5" (1334 mm) above the finished floor.	§308.3	Lower or install coat hook at 48" (1219 mm) max. above the finished floor for forward approach to object (2010 ADA Fig. 308.3.1). Per 36.304(d)(2)(i) Safe harbor. Elements that comply with the corresponding technical requirements and scoping requirements for those elements in the 1991	C	\$0.00
Arts and Culture	Abemathy Arts Center and Crafts	254 Johnson Ferry Rd. Sandy Springs, GA 30328	Corridor by Accessible Restroom	Coat hook is mounted beyond required reach allowed for approach provided and is mounted at 67" (1702 mm) above the finished floor.	§308.3	Lower or install coat hook at 48" (1219 mm) max. above the finished floor for forward approach to object (2010 ADA Fig. 308.3.1).	C	\$55.00
Arts and Culture	Abemathy Arts Center and Crafts	254 Johnson Ferry Rd. Sandy Springs, GA 30328	Workshop at Basement	Coat hook is mounted beyond required reach allowed for approach provided and is mounted at 55.75" (1416 mm) above the finished floor.	§308.3	Lower or install coat hook at 48" (1219 mm) max. above the finished floor for forward approach to object (2010 ADA Fig. 308.3.1).	C	\$55.00
Arts and Culture	Abemathy Arts Center and Crafts	254 Johnson Ferry Rd. Sandy Springs, GA 30328	Women's Accessible Restroom	Privacy lock requires pinching and tight grasping to operate.	§309.4	Replace or retrofit with system operable with one hand, not requiring pinching, tight grasping or turning of the wrist to operate.	C	\$291.64
Arts and Culture	Abemathy Arts Center and Crafts	254 Johnson Ferry Rd. Sandy Springs, GA 30328	Men's Accessible Restroom	Privacy lock requires pinching and tight grasping to operate.	§309.4	Replace or retrofit with system operable with one hand, not requiring pinching, tight grasping or turning of the wrist to operate.	C	\$291.64
Arts and Culture	Abemathy Arts Center and Crafts	254 Johnson Ferry Rd. Sandy Springs, GA 30328	Classroom No. 2	Accessible route has a non-compliant running slope of 5.7 %.	§403.3	Rework area to provide a running slope not exceeding 5%.	C	\$450.00
Arts and Culture	Abemathy Arts Center and Crafts	254 Johnson Ferry Rd. Sandy Springs, GA 30328	Corridor Leading to Accessible Restrooms	Accessible route has a non-compliant cross slope of 2.9 %.	§403.3	Rework or repave accessible route to provide a cross slope not exceeding 2%.	C	\$1,250.00
Arts and Culture	Abemathy Arts Center and Crafts	254 Johnson Ferry Rd. Sandy Springs, GA 30328	Workshop at Basement	Accessible route has a non-compliant running slope of 13.2 %.	§403.3	Rework or repave accessible route to provide a running slope not exceeding 5%.	C	\$900.00
Arts and Culture	Abemathy Arts Center and Crafts	254 Johnson Ferry Rd. Sandy Springs, GA 30328	Outdoor Seating Area by Main Entrance	The only means of access to the outdoor seating area is by stairs.	§403.3	Provide an alternative accessible location or mitigate condition by means of a ramp or platform lift.	C	\$4,390.00
Arts and Culture	Abemathy Arts Center and Crafts	254 Johnson Ferry Rd. Sandy Springs, GA 30328	Women's Accessible Restroom	Coat hook is mounted beyond required reach allowed for approach provided and is mounted at 64.25" (1632 mm) above the finished floor.	§603.4	Lower or install coat hook at 48" (1219 mm) max. above the finished floor for forward approach to object (For toilet and bathing rooms only).	C	\$55.00
Arts and Culture	Abemathy Arts Center and Crafts	254 Johnson Ferry Rd. Sandy Springs, GA 30328	Men's Accessible Restroom	Coat hook is mounted beyond required reach allowed for approach provided and is mounted at 64" (1626 mm) above the finished floor.	§603.4	Lower or install coat hook at 48" (1219 mm) max. above the finished floor for forward approach to object (For toilet and bathing rooms only).	C	\$55.00
Arts and Culture	Abemathy Arts Center and Crafts	254 Johnson Ferry Rd. Sandy Springs, GA 30328	Men's Accessible Restroom	Water closet is centered at 18.5" (470 mm) from side wall.	§604.2	Relocate water closet and center between 16" and 18" (406 mm - 457 mm) from side wall (2010 ADA Fig. 604.2).	C	\$1,029.03

**Fulton County ADA Transition Plan
ARTS AND CULTURE
Appendix 7-10**

Department	Bldg Name	Address	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction	Priority	Cost
Arts and Culture	Abernathy Arts Center and Crafts	254 Johnson Ferry Rd. Sandy Springs, GA 30328	Restroom at Basement	Water closet is centered at 18.25" (464 mm) from side wall.	\$604.2	Relocate water closet and center between 16" and 18" (406 mm - 457 mm) from side wall (2010 ADA Fig. 604.2). For a facility that pre-dates the enactment of the ADA this dimension should be considered acceptable per 1990 ADA section 3.2 Dimensional Tolerances and 2010 ADA section 104.1 Construction and Manufacturing Tolerance.	C	\$0.00
Arts and Culture	Abernathy Arts Center and Crafts	254 Johnson Ferry Rd. Sandy Springs, GA 30328	Men's Accessible Restroom	Water closet seat is mounted at 19.5" (495 mm) above the finished floor to top.	\$604.4	Retrofit water closet seat and mount between 17" and 19" (431 mm - 482 mm) above the finished floor to top of seat.	C	\$0.00
Arts and Culture	Abernathy Arts Center and Crafts	254 Johnson Ferry Rd. Sandy Springs, GA 30328	Restroom at Basement	Water closet side wall grab bar is mounted at 51.5" (1308 mm) perpendicular from rear wall to centerline of its outer flange.	\$604.5.1	Install a 42" (1066 mm) min. long side wall grab bar at 54" (1371 mm) min. perpendicular from rear wall to centerline of outer flange and mount at 33" - 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (ADAAG Fig. 604.5.1)	C	\$150.00
Arts and Culture	Abernathy Arts Center and Crafts	254 Johnson Ferry Rd. Sandy Springs, GA 30328	Men's Accessible Restroom	Water closet flush control is toward the wall side.	\$604.6	Rotate water closet flush control toward the open side or install an electronically controlled mechanism.	C	\$350.00
Arts and Culture	Abernathy Arts Center and Crafts	254 Johnson Ferry Rd. Sandy Springs, GA 30328	Restroom at Basement	Water closet flush control is toward the wall side.	\$604.6	Rotate water closet flush control toward the open side or install an electronically controlled mechanism.	C	\$350.00
Arts and Culture	Abernathy Arts Center and Crafts	254 Johnson Ferry Rd. Sandy Springs, GA 30328	Restroom at Basement	Toilet tissue dispenser is mounted at 11.5" (292 mm) in front of the water closet to the centerline of the dispenser.	\$604.7	Relocate toilet tissue dispenser to water closet side wall at 7"-9" (177 mm to 228 mm) in front of the water closet to the centerline of the dispenser and 15"-48" (381 mm to 1219 mm) above the Option A) Combine both stalls to provide a fully accessible 60" by 59" (1524 mm by 1498 mm) min. toilet compartment for a floor mounted water closet, remove existing stall partitions and one water closet if allowed by local plumbing codes or ordinances Option B: Remove all stall partitions and 1 water closet, provide hardware on door and convert into a single user restroom (2010 ADA Fig. 604.8.1.1).	C	\$131.00
Arts and Culture	Abernathy Arts Center and Crafts	254 Johnson Ferry Rd. Sandy Springs, GA 30328	Women's Accessible Restroom	Accessible toilet compartment (stall) is 37" by 65.25" (940 by 1657 mm) deep and it is configured as an ambulatory stall.	\$604.8.1.1	Remove stall partitions and install hardware on door and convert into a fully accessible single user restroom that provides a 60" by 56" (1422 mm by 1498 mm) min. clear floor space for a floor mounted water closet with the corresponding 60" (1524 mm) min. diameter wheelchair turnaround space inside restroom. (2010 ADA	C	\$2,119.74
Arts and Culture	Abernathy Arts Center and Crafts	254 Johnson Ferry Rd. Sandy Springs, GA 30328	Men's Accessible Restroom	Accessible toilet compartment (stall) does not have compliant dimensions	\$604.8.1.1	Remove stall partitions and install hardware on door and convert into a fully accessible single user restroom that provides a 60" by 56" (1422 mm by 1498 mm) min. clear floor space for a floor mounted water closet with the corresponding 60" (1524 mm) min. diameter wheelchair turnaround space inside restroom. (2010 ADA	C	\$2,119.74
Arts and Culture	Abernathy Arts Center and Crafts	254 Johnson Ferry Rd. Sandy Springs, GA 30328	Men's Accessible Restroom	Toilet compartment (stall) door does not provide pull handles on both sides of the door near the latch.	\$604.8.1.2	Provided pull handles on both sides of the door near the latch and center door opening hardware between 34" and 48" (863 mm - 1219 mm) above the finished floor.	C	\$0.00
Arts and Culture	Abernathy Arts Center and Crafts	254 Johnson Ferry Rd. Sandy Springs, GA 30328	Men's Accessible Restroom	Accessible compartment (stall) door does not have a self closing mechanism.	\$604.8.2.2	Provide a self closing mechanism on door with an opening force not exceeding 5 lbf.	C	\$0.00
Arts and Culture	Abernathy Arts Center and Crafts	254 Johnson Ferry Rd. Sandy Springs, GA 30328	Men's Accessible Restroom	Urinal is mounted in a 31" (787 mm) wide and 65.25" (1586 mm) deep alcove.	\$605.3	Remove/relocate partitions to provide a 36" (914 mm) min. wide alcove for a forward approach to object (2010 ADA Fig. 305.7.1).	C	\$0.00
Arts and Culture	Abernathy Arts Center and Crafts	254 Johnson Ferry Rd. Sandy Springs, GA 30328	Women's Accessible Restroom	Stall door swings into lavatory clear floor space.	\$606.2	Reverse door swing or reconfigure fixtures and/or offset partitions to provide a 30" by 48" (762 mm by 1219 mm) min. lavatory clear floor space (2010 ADA Fig. 305).	C	\$0.00
Arts and Culture	Abernathy Arts Center and Crafts	254 Johnson Ferry Rd. Sandy Springs, GA 30328	Men's Accessible Restroom	Stall door swings into lavatory clear floor space.	\$606.2	Reverse door swing or reconfigure fixtures and/or offset partitions to provide a 30" by 48" (762 mm by 1219 mm) min. lavatory clear floor space (2010 ADA Fig. 305).	C	\$0.00
Arts and Culture	Abernathy Arts Center and Crafts	254 Johnson Ferry Rd. Sandy Springs, GA 30328	Women's Accessible Restroom	Lavatory has partially unwrapped bottom sink pipes.	\$606.5	Cover (insulate) lavatory bottom supply and drain pipes or reconfigure to protect against contact.	C	\$120.12
Arts and Culture	Abernathy Arts Center and Crafts	254 Johnson Ferry Rd. Sandy Springs, GA 30328	Men's Accessible Restroom	Lavatory has partially unwrapped bottom sink pipes.	\$606.5	Cover (insulate) lavatory bottom supply and drain pipes or reconfigure to protect against contact.	C	\$120.12
Arts and Culture	Abernathy Arts Center and Crafts	254 Johnson Ferry Rd. Sandy Springs, GA 30328	Women's Accessible Restroom	Toilet seat cover dispenser is mounted over the toilet tank.	\$609.3	Relocate toilet seat cover dispenser and mount between 15" to 48" (380 mm - 1219 mm) above the finished floor for unobstructed forward approach to object (2010 ADA Fig. 308.2.1). If mounted below the side wall grab bar there shall be a clearance of 1.5" (38 mm) below the grab bar. If mounted above the side wall grab bar there shall be a clearance of 12" (305 mm) min.	C	\$131.00
Arts and Culture	Abernathy Arts Center and Crafts	254 Johnson Ferry Rd. Sandy Springs, GA 30328	Men's Accessible Restroom	Toilet seat cover dispenser is mounted on top of the side wall grab bar.	\$609.3	Relocate toilet seat cover dispenser to provide a clear space between the side wall grab bar and projecting objects above of 12" (305 mm) min. (2010 ADA Fig. 609.3).	C	\$131.00
Arts and Culture	Abernathy Arts Center and Crafts	254 Johnson Ferry Rd. Sandy Springs, GA 30328	Classroom No. 2	Kitchen sink counter does not have the required knee clearance.	\$804.3.1	Rework sink to provide a 27" (685 mm) min. knee clearance above the finished floor to bottom leading edge of fixture at an 8" (203 mm) min. horizontal projection (2010 ADA Fig. 306.3)	C	\$0.00
Arts and Culture	Abernathy Arts Center and Crafts	254 Johnson Ferry Rd. Sandy Springs, GA 30328	Kitchenette	Kitchen sink counter does not have the required knee clearance.	\$804.3.1	Rework sink to provide a 27" (685 mm) min. knee clearance above the finished floor to bottom leading edge of fixture at an 8" (203 mm) min. horizontal projection (2010 ADA Fig. 306.3)	C	\$0.00
Arts and Culture	Abernathy Arts Center and Crafts	254 Johnson Ferry Rd. Sandy Springs, GA 30328	Classroom No 3	Kitchen sink counter does not have the required knee clearance due to pipes and garbage disposal.	\$804.3.1	Rework sink to provide a 27" (685 mm) min. knee clearance above the finished floor to bottom leading edge of fixture, that is 30" (762 mm) min. wide, with an 8" (203 mm) min. horizontal projection (2010 ADA Fig. 306.3)	C	\$500.00
Arts and Culture	Abernathy Arts Center and Crafts	254 Johnson Ferry Rd. Sandy Springs, GA 30328	Workshop at Basement	Kitchen sink counter does not have the required knee clearance.	\$804.3.1	Rework sink to provide a 27" (685 mm) min. knee clearance above the finished floor to bottom leading edge of fixture at an 8" (203 mm) min. horizontal projection (2010 ADA Fig. 306.3)	C	\$0.00
Arts and Culture	Abernathy Arts Center and Crafts	254 Johnson Ferry Rd. Sandy Springs, GA 30328	Workshop at Basement	Sink knee clearance is 26.5" (673 mm) above the finished floor to bottom leading edge of fixture.	\$804.3.1	Rework sink to provide a 27" (685 mm) min. knee clearance above the finished floor to bottom leading edge of fixture at an 8" (203 mm) min. horizontal projection (2010 ADA Fig. 306.3)	C	\$500.00
Arts and Culture	Abernathy Arts Center and Crafts	254 Johnson Ferry Rd. Sandy Springs, GA 30328	Unmarked Class Room by Main Entrance	Sink has unwrapped bottom pipes.	\$804.4	Cover (insulate) sink bottom supply and drain pipes.	C	\$120.12
Arts and Culture	Abernathy Arts Center and Crafts	254 Johnson Ferry Rd. Sandy Springs, GA 30328	Classroom No. 2	Sink is mounted at 36" (914 mm) above the finished floor to top of rim.	\$804.4	Relocate and/or mount sink at 34" (863 mm) max. above the finished floor to top of rim.	C	\$1,891.00

**Fulton County ADA Transition Plan
ARTS AND CULTURE
Appendix 7-10**

Department	Bldg Name	Address	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction	Priority	Cost
Arts and Culture	Abernathy Arts Center and Crafts	254 Johnson Ferry Rd. Sandy Springs, GA 30328	Classroom No. 2	Sink has unwrapped bottom pipes.	\$804.4	Cover (insulate) sink bottom supply and drain pipes.	C	\$120.12
Arts and Culture	Abernathy Arts Center and Crafts	254 Johnson Ferry Rd. Sandy Springs, GA 30328	Kitchenette	Sink is mounted at 36.5" (927 mm) above the finished floor to top of rim.	\$804.4	Relocate and/or mount sink at 34" (863 mm) max. above the finished floor to top of rim.	C	\$1,891.00
Arts and Culture	Abernathy Arts Center and Crafts	254 Johnson Ferry Rd. Sandy Springs, GA 30328	Kitchenette	Sink has unwrapped bottom pipes.	\$804.4	Cover (insulate) sink bottom supply and drain pipes.	C	\$120.12
Arts and Culture	Abernathy Arts Center and Crafts	254 Johnson Ferry Rd. Sandy Springs, GA 30328	Classroom No 3	Sink has unwrapped bottom pipes.	\$804.4	Cover (insulate) sink bottom supply and drain pipes.	C	\$120.12
Arts and Culture	Abernathy Arts Center and Crafts	254 Johnson Ferry Rd. Sandy Springs, GA 30328	Workshop at Basement	Sink has unwrapped bottom pipes.	\$804.4	Cover (insulate) sink bottom supply and drain pipes.	C	\$120.12
Arts and Culture	Abernathy Arts Center and Crafts	254 Johnson Ferry Rd. Sandy Springs, GA 30328	Unmarked Class Room by Main Entrance	Wall cabinets over the work surface are mounted at 51" (1295 mm) above the finished floor to the bottom shelf.	\$804.5	Relocate wall cabinets, above the work surface, and mount at 48" (1219 mm) max. above the finished floor to the bottom shelf. Handles shall be mounted as close to the bottom as possible.	C	\$1,891.00
Arts and Culture	Abernathy Arts Center and Crafts	254 Johnson Ferry Rd. Sandy Springs, GA 30328	Classroom No. 2	Wall cabinets over the work surface are mounted at 56.25" (1429 mm) above the finished floor to the bottom shelf.	\$804.5	Relocate wall cabinets, above the work surface, and mount at 48" (1219 mm) max. above the finished floor to the bottom shelf. Handles shall be mounted as close to the bottom as possible.	C	\$1,891.00
Arts and Culture	Abernathy Arts Center and Crafts	254 Johnson Ferry Rd. Sandy Springs, GA 30328	Classroom No 3	Wall cabinets over the work surface are mounted at 62.25" (1581 mm) above the finished floor to the bottom shelf.	\$804.5	Relocate wall cabinets, above the work surface, and mount at 48" (1219 mm) max. above the finished floor to the bottom shelf. Handles shall be mounted as close to the bottom as possible.	C	\$1,891.00
Arts and Culture	Abernathy Arts Center and Crafts	254 Johnson Ferry Rd. Sandy Springs, GA 30328	Kitchenette	Table has a non-compliant clear floor space provided due to pedestal base.	\$902.2	Replace with a new table mounted between 28" (710 mm) min. and 34" (865 mm) max. above the finished floor or ground. The table must provide a knee clearance that is at least 27" (685 mm) high, 30" (762 mm) wide and with a horizontal projection that is 17" (432 mm) deep. With it's corresponding 30" by 48" (762 mm by 1219 mm) min. wheelchair clear floor space (2010 ADA Figs. 305.5 (a), 306.2 (a)(b) and 306.3 (a)(b))	C	\$452.12
Arts and Culture	Abernathy Arts Center and Crafts	254 Johnson Ferry Rd. Sandy Springs, GA 30328	Classroom No 3	Tables and desk have a non-compliant knee clearance and/or non-compliant clear floor space.	\$902.2	Replace with a new table mounted between 28" (710 mm) min. and 34" (865 mm) max. above the finished floor or ground. The table must provide a knee clearance that is at least 27" (685 mm) high, 30" (762 mm) wide and with a horizontal projection that is 17" (432 mm) deep. With it's corresponding 30" by 48" (762 mm by 1219 mm) min. wheelchair clear floor space (2010 ADA Figs. 305.5 (a), 306.2 (a)(b) and 306.3 (a)(b))	C	\$372.14
Arts and Culture	Abernathy Arts Center and Crafts	254 Johnson Ferry Rd. Sandy Springs, GA 30328	Workshop at Basement	Pottery wheels have a non-compliant knee clearance and non-compliant clear floor space.	\$902.2	Provide pottery wheel with the surface mounted at 28" to 34" (711 mm to 863 mm) above the finished to the top, with a corresponding 30" by 48" (762 mm by 1219 mm) clear floor space, 27" (685 mm) min. bottom knee clearance above the finished floor, that is 30" (762 mm) min. wide and has a 17" (430 mm) horizontal projection.	C	\$765.00
Arts and Culture	Abernathy Arts Center and Crafts	254 Johnson Ferry Rd. Sandy Springs, GA 30328	Women's Accessible Restroom	Toilet compartment (stall) door does not provide pull handles on both sides of the door near the latch.	\$604.8.1.2	Provided pull handles on both sides of the door near the latch and center door opening hardware between 34" and 48" (863 mm - 1219 mm) above the finished floor.	D	\$0.00
Arts and Culture	Abernathy Arts Center and Crafts	254 Johnson Ferry Rd. Sandy Springs, GA 30328	Women's Accessible Restroom	Accessible compartment (stall) door does not have a self closing mechanism.	\$604.8.2.2	Provide a self closing mechanism on door with an opening force not exceeding 5 lbf.	D	\$0.00
Arts and Culture	Abernathy Arts Center Annex	254 Johnson Ferry Sandy Springs, GA 30328	Accessible Route Leading to Main Entrance	There is no signage posted indicating the location of an accessible entrance.	\$216.6	Post signage indicating location of the accessible entrance serving the facility. If sign is to be placed overhead it shall have a minimum character height of 3" (76 mm).	B	\$149.95
Arts and Culture	Abernathy Arts Center Annex	254 Johnson Ferry Sandy Springs, GA 30328	Main Entrance	Accessible entrance does not have signage displaying the international symbol of accessibility.	\$216.6	Provide signage at accessible entrance displaying the International symbol of accessibility.	B	\$149.95
Arts and Culture	Abernathy Arts Center Annex	254 Johnson Ferry Sandy Springs, GA 30328	Ramp Leading to Accessible Parking Spaces at Abernathy Greenway Park	There is no signage posted indicating the location of an accessible entrance.	\$216.6	Post signage indicating location of the accessible entrance serving the facility. If sign is to be placed overhead it shall have a minimum character height of 3" (76 mm).	B	\$149.95
Arts and Culture	Abernathy Arts Center Annex	254 Johnson Ferry Sandy Springs, GA 30328	Main Entrance	Mat is not securely attached to the floor.	\$302.2	Provide a securely attached mat with a leveled loop or level cut pile, with texture height that is 0.5" (13 mm) max. and has a firm cushion pad or backing (2010 ADA Fig. 302.2).	B	\$55.00
Arts and Culture	Abernathy Arts Center Annex	254 Johnson Ferry Sandy Springs, GA 30328	Ramp Leading to Accessible Parking Spaces at Abernathy Greenway Park	Bottom landing has a non-compliant 8.2 % surface slope.	\$405.7.1	Rework landing to provide a surface slope not exceeding 2% in all directions (2010 ADA Fig. 405.7).	B	\$900.00
Arts and Culture	Abernathy Arts Center Annex	254 Johnson Ferry Sandy Springs, GA 30328	Ramp Leading to Accessible Parking Spaces at Abernathy Greenway Park	Handrails extensions are mounted over the sloped area of ramp.	\$405.8	Rework handrails so that they extend horizontally above the landing 12" (304 mm) min. beyond the top and bottom of ramp runs (2010 ADA Fig. 505.10.1)	B	\$1,160.00
Arts and Culture	Abernathy Arts Center Annex	254 Johnson Ferry Sandy Springs, GA 30328	Accessible Parking Spaces	Accessible parking spaces are not clearly outlined or need re-striping.	\$502.2	Restripe to provide an accessible parking space 96" (2438 mm) min. wide and a 60" (1525 mm) min. wide access aisle with a surface slope not exceeding 2% in all directions (2010 ADA Figs. 502.3).	B	\$0.00
Arts and Culture	Abernathy Arts Center Annex	254 Johnson Ferry Sandy Springs, GA 30328	Accessible Parking Spaces	Access aisle on left has a non-compliant running slope of up to 3.8% due to driveway	\$502.4	Due to site constraints we recommend relocating accessible parking spaces and reworking area to provide an accessible parking space with surface slope not exceeding 2% in all directions.	B	\$0.00
Arts and Culture	Abernathy Arts Center Annex	254 Johnson Ferry Sandy Springs, GA 30328	Accessible Parking Spaces	Access aisle on right has a non-compliant running slope of up to 5.6% due to driveway	\$502.4	Due to site constraints we recommend relocating accessible parking spaces and reworking area to provide an accessible parking space with surface slope not exceeding 2% in all directions.	B	\$0.00
Arts and Culture	Abernathy Arts Center Annex	254 Johnson Ferry Sandy Springs, GA 30328	Accessible Parking Spaces	Accessible parking space in the middle does not have signage indicating the penalty for illegal use of the parking space.	\$502.6	Install sign indicating accessible parking displaying the international symbol of accessibility, bearing the caption "Parking by disabled Permit only" and the penalty for illegal use of this space, and mount at 60" (1524 mm) min. above the finish floor	B	\$0.00
Arts and Culture	Abernathy Arts Center Annex	254 Johnson Ferry Sandy Springs, GA 30328	Accessible Parking Spaces	Accessible parking space on right does not have signage indicating accessible parking.	\$502.6	Install signage indicating accessible parking that displays the international symbol of accessibility and mount at 60" (1524 mm) min. above the finished floor.	B	\$0.00
Arts and Culture	Abernathy Arts Center Annex	254 Johnson Ferry Sandy Springs, GA 30328	Accessible Parking Spaces	Accessible parking space (on middle) has a non-compliant running slope of up to 4.2% due to driveway	\$504.2	Due to site constraints we recommend relocating accessible parking spaces and reworking area to provide an accessible parking space with surface slope not exceeding 2% in all directions.	B	\$0.00
Arts and Culture	Abernathy Arts Center Annex	254 Johnson Ferry Sandy Springs, GA 30328	Accessible Parking Spaces	Accessible parking space on left has a non-compliant running slope of up to 6.3% due to driveway	\$504.2	Due to site constraints we recommend relocating accessible parking spaces and reworking area to provide an accessible parking space with surface slope not exceeding 2% in all directions.	B	\$0.00
Arts and Culture	Abernathy Arts Center Annex	254 Johnson Ferry Sandy Springs, GA 30328	Accessible Parking Spaces	Accessible parking on right space has a non-compliant running slope of up to 6.0% due to driveway	\$504.2	Due to site constraints we recommend relocating accessible parking spaces and reworking area to provide an accessible parking space with surface slope not exceeding 2% in all directions.	B	\$7,589.56

Fulton County ADA Transition Plan
ARTS AND CULTURE
Appendix 7-10

Department	Bldg Name	Address	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction	Priority	Cost
Arts and Culture	Abernathy Arts Center Annex	254 Johnson Ferry Sandy Springs, GA 30328	Ginkgo Room	Permanent room identifying signage does not have Braille or raised characters.	\$703.4.1	Provide signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. from the baseline of the highest tactile character (2010 ADA Fig. 703.4.1).	B	\$149.95
Arts and Culture	Abernathy Arts Center Annex	254 Johnson Ferry Sandy Springs, GA 30328	Magnolia Room	Permanent room identifying signage does not have Braille or raised characters.	\$703.4.1	Provide signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. from the baseline of the highest tactile character (2010 ADA Fig. 703.4.1).	B	\$149.95
Arts and Culture	Abernathy Arts Center Annex	254 Johnson Ferry Sandy Springs, GA 30328	Women's Accessible Restrooms	Hand dryer protrudes into walkway, projecting 8" (203 mm) from back wall, and is mounted at 43.5" (1105 mm) above the finished floor to its bottom leading edge.	\$307.2r	Relocate or recess hand dryer so that it does not project more than 4" (101 mm) from back wall to outer leading edge (2010 ADA Fig. 307.2).	C	\$378.14
Arts and Culture	Abernathy Arts Center Annex	254 Johnson Ferry Sandy Springs, GA 30328	Women's Accessible Restrooms	Sanitary napkin/tampon dispenser protrudes into walkway, projecting 6.75" (171 mm) from back wall, and is mounted at 41.25" (1048 mm) above the finished floor to its bottom leading edge.	\$307.2r	Relocate or recess sanitary napkin/tampon dispenser so that it does not project more than 4" (101 mm) from back wall to outer leading edge (2010 ADA Fig. 307.2).	C	\$131.00
Arts and Culture	Abernathy Arts Center Annex	254 Johnson Ferry Sandy Springs, GA 30328	Ginkgo Room	Soap dispenser is mounted beyond required reach allowed for approach provided at 37" (940 mm) above the finished floor over a 29.5" (749 mm) obstruction (counter).	\$308.2.1	Lower or install soap dispenser at 44" (1219 mm) max. above the finished floor, over a 20"-25" (510 mm - 1120 mm) max. obstruction, for forward approach to object (2010 ADA Fig. 308.2.1).	C	\$131.00
Arts and Culture	Abernathy Arts Center Annex	254 Johnson Ferry Sandy Springs, GA 30328	Ginkgo Room	Paper towel dispenser is mounted beyond required reach allowed for approach provided at 49.25" (1251 mm) above the finished floor over a 29.5" (749 mm) obstruction (counter).	\$308.2.1	Lower or install paper towel dispenser at 44" (1219 mm) max. above the finished floor, over a 20"-25" (510 mm - 1120 mm) max. obstruction, for forward approach to object (2010 ADA Fig. 308.2.1).	C	\$131.00
Arts and Culture	Abernathy Arts Center Annex	254 Johnson Ferry Sandy Springs, GA 30328	Magnolia Room	Light switch is mounted at 49" (1245 mm) above the finished floor to the centerline of the highest operable part.	\$308.2.1	Install light switch at 48" (1219 mm) max. above the finished floor to the highest operable part for a forward approach to object (2010 ADA Fig. 308.2.1). <i>Per 36.304(d)(2)(j) Safe harbor. Elements that comply with the corresponding technical requirements.</i>	C	\$0.00
Arts and Culture	Abernathy Arts Center Annex	254 Johnson Ferry Sandy Springs, GA 30328	Magnolia Room	Kitchen outlet is mounted at a non-compliant height over an obstruction (sink counter).	\$308.2.1	Lower or install outlet at 44" (1219 mm) max. above the finished floor, over a 20"-25" (510 mm - 1120 mm) max. obstruction, and at 15" (381 mm) min. above the finished floor to the centerline for Lower or install Paper towel dispenser at 44" (1219 mm) max. above the finished floor, over a 20"-25" (510 mm - 1120 mm) max. obstruction, for forward approach to object (2010 ADA Fig. 308.2.1).	C	\$378.00
Arts and Culture	Abernathy Arts Center Annex	254 Johnson Ferry Sandy Springs, GA 30328	Magnolia Room	Paper towel dispenser is mounted beyond required reach allowed for approach provided at 47.5" (1206 mm) above the finished floor over a 29.5" (749 mm) obstruction (counter).	\$308.2.1	Lower or install soap dispenser at 44" (1219 mm) max. above the finished floor, over a 20"-25" (510 mm - 1120 mm) max. obstruction, for forward approach to object (2010 ADA Fig. 308.2.1).	C	\$131.00
Arts and Culture	Abernathy Arts Center Annex	254 Johnson Ferry Sandy Springs, GA 30328	Magnolia Room	Soap dispenser is mounted beyond required reach allowed for approach provided at 47.5" (1206 mm) above the finished floor over a 29.5" (749 mm) obstruction (counter).	\$308.2.1	Lower or install soap dispenser at 44" (1219 mm) max. above the finished floor, over a 20"-25" (510 mm - 1120 mm) max. obstruction, for forward approach to object (2010 ADA Fig. 308.2.1).	C	\$131.00
Arts and Culture	Abernathy Arts Center Annex	254 Johnson Ferry Sandy Springs, GA 30328	Women's Accessible Restrooms	Toilet seat cover dispenser is mounted beyond reach ranges at 51" (1295 mm) above the finished floor and is mounted behind the water closet.	\$308.2.1	Relocate toilet seat cover dispenser and mount between 15" to 48" (380 mm - 1219 mm) above the finished floor for unobstructed forward approach to object (2010 ADA Fig. 308.2.1).	C	\$131.00
Arts and Culture	Abernathy Arts Center Annex	254 Johnson Ferry Sandy Springs, GA 30328	Men's Accessible Restrooms	Toilet seat cover dispenser is mounted beyond reach ranges at 53" (1346 mm) above the finished floor and is mounted behind the water closet.	\$308.2.1	Relocate toilet seat cover dispenser and mount between 15" to 48" (380 mm - 1219 mm) above the finished floor for unobstructed forward approach to object (2010 ADA Fig. 308.2.1).	C	\$131.00
Arts and Culture	Abernathy Arts Center Annex	254 Johnson Ferry Sandy Springs, GA 30328	Ginkgo Room	Coat hook is mounted beyond required reach allowed for approach provided and is mounted at 64" (1626 mm) above the finished floor.	\$308.3	Lower or install coat hook at 48" (1219 mm) max. above the finished floor for forward approach to object (2010 ADA Fig. 308.3.1).	C	\$55.00
Arts and Culture	Abernathy Arts Center Annex	254 Johnson Ferry Sandy Springs, GA 30328	Magnolia Room	Coat hook is mounted beyond required reach allowed for approach provided and is mounted at 60.25" (1530 mm) above the finished floor.	\$308.3	Lower or install coat hook at 48" (1219 mm) max. above the finished floor for forward approach to object (2010 ADA Fig. 308.3.1).	C	\$131.00
Arts and Culture	Abernathy Arts Center Annex	254 Johnson Ferry Sandy Springs, GA 30328	Women's Accessible Restrooms	Sanitary napkin dispenser requires pinching and tight grasping to operate.	\$309.4	Replace or retrofit with system operable with one hand, not requiring pinching, tight grasping or turning of the wrist to operate.	C	\$288.00
Arts and Culture	Abernathy Arts Center Annex	254 Johnson Ferry Sandy Springs, GA 30328	Women's Accessible Restrooms	Tampon dispenser hardware requires pinching and tight grasping to operate.	\$309.4	Replace or retrofit with system operable with one hand, not requiring pinching, tight grasping or turning of the wrist to operate.	C	\$0.00
Arts and Culture	Abernathy Arts Center Annex	254 Johnson Ferry Sandy Springs, GA 30328	Corridor Leading to Restrooms	Furniture and equipment encroaches passage width reducing it to less than 36" (914 mm).	\$403.5.1	Relocate furniture and equipment to provide a 36" (914 mm) min. clear width continuously (2010 ADA Fig. 403.5.1).	C	\$55.00
Arts and Culture	Abernathy Arts Center Annex	254 Johnson Ferry Sandy Springs, GA 30328	Women's Accessible Restrooms	Sanitary napkin dispenser encroaches passage width reducing it to 34.75" (883 mm).	\$403.5.1	Relocate item to provide a 36" (914 mm) min. clear width continuously (2010 ADA Fig. 403.5.1).	C	\$0.00
Arts and Culture	Abernathy Arts Center Annex	254 Johnson Ferry Sandy Springs, GA 30328	Women's Accessible Restrooms	Door has a non-compliant opening force of 12 lbf.	\$404.2.9	Adjust or replace door closer, maintain door hinges to provide an opening force not to exceed 5 lbf.	C	\$131.00
Arts and Culture	Abernathy Arts Center Annex	254 Johnson Ferry Sandy Springs, GA 30328	Men's Accessible Restrooms	Door has a non-compliant opening force of 15 lbf.	\$404.2.9	Adjust or replace door closer, maintain door hinges to provide an opening force not to exceed 5 lbf.	C	\$131.00
Arts and Culture	Abernathy Arts Center Annex	254 Johnson Ferry Sandy Springs, GA 30328	Ramp Leading to Accessible Parking Spaces at Abernathy Greenway Park	Ramp handrails are not continuous due to stairs.	\$405.8	Provide continuous handrails on both sides of ramp and mount between 34" and 38" (863 mm - 965 mm) above the ramp surface to top of gripping surfaces, extending 12" (304 mm) min. beyond the top and bottom of the ramp segment (2010 ADA 505.10.1)	C	\$0.00
Arts and Culture	Abernathy Arts Center Annex	254 Johnson Ferry Sandy Springs, GA 30328	Ramp Leading to Accessible Parking Spaces at Abernathy Greenway Park	Ramp handrails do not provide curb or barrier edge protection.	\$405.9.2	Rework ramp to provide a curb or barrier that prevents the passage of a 4" (100 mm) diameter sphere, where any portion of the sphere is within 4" (100 mm) of the finished floor or ground surface (2010 ADA Fig 405.9.2)	C	\$6,400.00
Arts and Culture	Abernathy Arts Center Annex	254 Johnson Ferry Sandy Springs, GA 30328	Women's Accessible Restrooms	Lavatory mirror is mounted at 41.25" (1048 mm) above the finished floor to bottom edge of its reflecting surface.	\$603.3	Lower lavatory mirror to 40" (1016 mm) max. above the finished floor to bottom edge of its reflecting surface.	C	\$131.00
Arts and Culture	Abernathy Arts Center Annex	254 Johnson Ferry Sandy Springs, GA 30328	Men's Accessible Restrooms	Lavatory mirror is mounted at 41.25" (1048 mm) above the finished floor to bottom edge of its reflecting surface.	\$603.3	Lower lavatory mirror to 40" (1016 mm) max. above the finished floor to bottom edge of its reflecting surface.	C	\$131.00
Arts and Culture	Abernathy Arts Center Annex	254 Johnson Ferry Sandy Springs, GA 30328	Women's Accessible Restrooms	Coat hook is mounted beyond required reach allowed for approach provided and is mounted at 54" (1372 mm) above the finished floor.	\$603.4	Lower or install coat hook at 48" (1219 mm) max. above the finished floor for forward approach to object. <i>Per 36.304(d)(2)(j) Safe harbor. Elements that comply with the corresponding technical requirements and scoping requirements for those elements in the 1991 Standards do not need to be modified in order to comply with the requirements set forth in the 2010 Standards.</i>	C	\$0.00
Arts and Culture	Abernathy Arts Center Annex	254 Johnson Ferry Sandy Springs, GA 30328	Men's Accessible Restrooms	Coat hook is mounted beyond required reach allowed for approach provided and is mounted at 51.25" (1302 mm) above the finished floor.	\$603.4	Lower or install coat hook at 48" (1219 mm) max. above the finished floor for forward approach to object. <i>Per 36.304(d)(2)(j) Safe harbor. Elements that comply with the corresponding technical requirements and scoping requirements for those</i>	C	\$0.00

**Fulton County ADA Transition Plan
ARTS AND CULTURE
Appendix 7-10**

Department	Bldg Name	Address	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction	Priority	Cost
Arts and Culture	Abernathy Arts Center Annex	254 Johnson Ferry Sandy Springs, GA 30328	Women's Accessible Restrooms	Water closet is centered at 18.25" (464 mm) from side wall.	§604.2	Relocate water closet and center between 16" and 18" (406 mm - 457 mm) from side wall (2010 ADA Fig. 604.2). <i>This dimension should be considered acceptable per 1990 ADA section 3.2 Dimensional Tolerances and 2010 ADA section 104.1 Construction and Manufacturing Tolerance.</i>	C	\$0.00
Arts and Culture	Abernathy Arts Center Annex	254 Johnson Ferry Sandy Springs, GA 30328	Men's Accessible Restrooms	Water closet is centered at 19" (483 mm) from side wall.	§604.2	Relocate water closet and center between 16" and 18" (406 mm - 457 mm) from side wall (2010 ADA Fig. 604.2).	C	\$0.00
Arts and Culture	Abernathy Arts Center Annex	254 Johnson Ferry Sandy Springs, GA 30328	Men's Accessible Restrooms	Water closet seat is mounted at 19.5" (495 mm) above the finished floor to top.	§604.4	Retrofit water closet seat and mount between 17" and 19" (431 mm - 482 mm) above the finished floor to top of seat.	C	\$1,029.03
Arts and Culture	Abernathy Arts Center Annex	254 Johnson Ferry Sandy Springs, GA 30328	Women's Accessible Restrooms	Water closet side wall grab bar is mounted at 46.5" (1181 mm) perpendicular from rear wall to centerline of its outer flange.	§604.5.1	Install a 42" (1066 mm) min. long side wall grab bar at 54" (1371 mm) min. perpendicular from rear wall to centerline of outer flange and mount at 33"-36" (838 mm - 914 mm) above the finished floor to the top of the griping surface. (ADAAG Fig. 604.5.1)	C	\$150.00
Arts and Culture	Abernathy Arts Center Annex	254 Johnson Ferry Sandy Springs, GA 30328	Men's Accessible Restrooms	Water closet side wall grab bar is mounted at 46.5" (1181 mm) perpendicular from rear wall to centerline of its outer flange.	§604.5.1	Install a 42" (1066 mm) min. long side wall grab bar at 54" (1371 mm) min. perpendicular from rear wall to centerline of outer flange and mount at 33"-36" (838 mm - 914 mm) above the finished floor to the top of the griping surface. (ADAAG Fig. 604.5.1)	C	\$150.00
Arts and Culture	Abernathy Arts Center Annex	254 Johnson Ferry Sandy Springs, GA 30328	Women's Accessible Restrooms	Water closet rear wall grab bar is mounted at 37.25" (946 mm) above the finished floor to the top of the gripping surface.	§604.5.2	Relocate rear wall grab bar and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface.	C	\$150.00
Arts and Culture	Abernathy Arts Center Annex	254 Johnson Ferry Sandy Springs, GA 30328	Men's Accessible Restrooms	Water closet rear wall grab bar is mounted at 37.25" (946 mm) above the finished floor to the top of the gripping surface.	§604.5.2	Relocate rear wall grab bar and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface.	C	\$150.00
Arts and Culture	Abernathy Arts Center Annex	254 Johnson Ferry Sandy Springs, GA 30328	Women's Accessible Restrooms	Toilet tissue dispenser is mounted at 17.25" (438 mm) in front of the water closet to the centerline of the dispenser.	§604.7	Relocate toilet tissue dispenser to water closet side wall at 7"-9" (177 mm to 228 mm) in front of the water closet to the centerline of the dispenser and 15"-48" (381 mm to 1219 mm) above the finished floor to the dispenser outlet.	C	\$131.00
Arts and Culture	Abernathy Arts Center Annex	254 Johnson Ferry Sandy Springs, GA 30328	Men's Accessible Restrooms	Toilet tissue dispenser is mounted at 13" (330 mm) in front of the water closet to the centerline of the dispenser.	§604.7	Relocate toilet tissue dispenser to water closet side wall at 7"-9" (177 mm to 228 mm) in front of the water closet to the centerline of the dispenser and 15"-48" (381 mm to 1219 mm) above the finished floor to the dispenser outlet.	C	\$131.00
Arts and Culture	Abernathy Arts Center Annex	254 Johnson Ferry Sandy Springs, GA 30328	Women's Accessible Restrooms	Accessible toilet compartment (stall) is 56.5" (1435 mm) wide.	§604.8.1.1	Rework partitions and/or fixtures to provide a 60" (1524 mm) min. wide by 56" (1422 mm) min. deep accessible toilet compartment for a wall mounted water closet (2010 ADA Fig. 604.8.1.1).	C	\$2,119.74
Arts and Culture	Abernathy Arts Center Annex	254 Johnson Ferry Sandy Springs, GA 30328	Men's Accessible Restrooms	Accessible toilet compartment (stall) is 54.5" (1384 mm) wide.	§604.8.1.1	Rework partitions and/or fixtures to provide a 60" (1524 mm) min. wide by 56" (1422 mm) min. deep accessible toilet compartment for a wall mounted water closet (2010 ADA Fig. 604.8.1.1).	C	\$2,119.74
Arts and Culture	Abernathy Arts Center Annex	254 Johnson Ferry Sandy Springs, GA 30328	Women's Accessible Restrooms	Toilet seat cover dispenser is mounted 7" (178 mm) over the rear wall grab bar.	§609.3	Relocate toilet seat cover dispenser and mount between 15" to 48" (380 mm - 1219 mm) above the finished floor for unobstructed forward approach to object (2010 ADA Fig. 609.3). <i>If mounted below the side wall grab bar there shall be a clearance of 1.5" (38 mm) below the grab bar. If mounted above the side wall grab bar there shall be a clearance of 12" (305 mm) min. above the grab bar (2010 ADA Fig 609.3).</i>	C	\$0.00
Arts and Culture	Abernathy Arts Center Annex	254 Johnson Ferry Sandy Springs, GA 30328	Men's Accessible Restrooms	Toilet seat cover dispenser is mounted 9.75" (248 mm) over the side wall grab bar.	§609.3	Relocate toilet seat cover dispenser to provide a clear space between the rear wall grab bar and projecting objects above of 12" (305 mm) min. (2010 ADA Fig. 609.3).	C	\$0.00
Arts and Culture	Abernathy Arts Center Annex	254 Johnson Ferry Sandy Springs, GA 30328	Ginko Room	Sink has unwrapped bottom pipes.	§804.4	Cover (insulate) sink bottom supply and drain pipes.	C	\$120.12
Arts and Culture	Abernathy Arts Center Annex	254 Johnson Ferry Sandy Springs, GA 30328	Ginko Room	Sink knob-type faucet requires pinching and tight grasping to operate.	§804.4	Replace or retrofit sink controls with paddle-operated, push-type or electronically-controlled mechanism.	C	\$228.00
Arts and Culture	Abernathy Arts Center Annex	254 Johnson Ferry Sandy Springs, GA 30328	Ginko Room	Wall cabinets over the work surface are mounted at 61.75" (1568 mm) above the finished floor to the bottom shelf.	§804.5	Relocate wall cabinets, above the work surface, and mount at 48" (1219 mm) max. above the finished floor to the bottom shelf. Handles shall be mounted as close to the bottom as possible.	C	\$1,891.00
Arts and Culture	Abernathy Arts Center Annex	254 Johnson Ferry Sandy Springs, GA 30328	Magnolia Room	Wall cabinets over the work surface are mounted at 60.75" (1543 mm) above the finished floor to the bottom shelf.	§804.5	Relocate wall cabinets, above the work surface, and mount at 48" (1219 mm) max. above the finished floor to the bottom shelf. Handles shall be mounted as close to the bottom as possible.	C	\$1,891.00
Arts and Culture	Abernathy Arts Center Annex	254 Johnson Ferry Sandy Springs, GA 30328	Main Entrance	Counter is mounted at 41.75" (1060 mm) above the finished floor.	§904.4.1	Provide an alternative counter or rework main counter to provide a portion that is 36" (914 mm) min. long, mounted at 36" (914 mm) max. above the finished floor to the top (For a parallel approach to counter).	C	\$372.14
Arts and Culture	Abernathy Arts Center Annex	254 Johnson Ferry Sandy Springs, GA 30328	Women's Accessible Restrooms	Toilet compartment (stall) door does not provide pull handles on both sides of the door near the latch.	§604.8.1.2	Provided pull handles on both sides of the door near the latch and center door opening hardware between 34" and 48" (863 mm - 1219 mm) above the finished floor.	D	\$55.00
Arts and Culture	Abernathy Arts Center Annex	254 Johnson Ferry Sandy Springs, GA 30328	Men's Accessible Restrooms	Toilet compartment (stall) door does not provide pull handles on both sides of the door near the latch.	§604.8.1.2	Provided pull handles on both sides of the door near the latch and center door opening hardware between 34" and 48" (863 mm - 1219 mm) above the finished floor.	D	\$55.00
Arts and Culture	Abernathy Arts Center Annex	254 Johnson Ferry Sandy Springs, GA 30328	Men's Accessible Restrooms	Accessible compartment (stall) door does not have a self closing mechanism.	§604.8.2.2	Provide a self closing mechanism on door with an opening force not exceeding 5 lbf.	D	\$291.64
Arts and Culture	Camp Truitt Education Center	4300 Herschel Road College Park, GA 30337	Multipurpose Room	Emergency pull station is mounted at 49" (1245 mm) above the finished floor to highest operable part.	§308.2.1	Lower or install emergency pull station at 48" (1219 mm) max. above the finished floor to highest operable part (2010 ADA Fig. 308.2.1). <i>Per 36.304(d)(2)(i) Safe harbor. Elements that comply with the corresponding technical requirements and scoping requirements for those elements in the 1991 Standards do not need to be modified in order to comply with the requirements set forth in the 2010 Standards.</i>	A	\$0.00
Arts and Culture	Camp Truitt Education Center	4300 Herschel Road College Park, GA 30337	Multipurpose Room	Emergency exit does not have sign with Braille or raised characters mounted on the latch side of door.	§703.4.1	Provide signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. from the baseline of the highest tactile character (2010 ADA Fig. 703.4.1).	A	\$149.95
Arts and Culture	Camp Truitt Education Center	4300 Herschel Road College Park, GA 30337	Path of Travel From Street to Main Entrance	The surface of the walkway is broken or unstable.	§302.1	Rework and clean sidewalk to provide a stable, firm, and slip-resistant floor surface.	B	\$900.00
Arts and Culture	Camp Truitt Education Center	4300 Herschel Road College Park, GA 30337	Path of Travel From Street to Main Entrance	Walkway has a vertical change in level.	§303.2	Rework area and provide a 0.25" (6 mm) max. vertical change of level, with a slope no greater than 1:2 (2010 ADA Fig. 303.2).	B	\$0.00
Arts and Culture	Camp Truitt Education Center	4300 Herschel Road College Park, GA 30337	Main Entrance	Door bell is mounted beyond required reach allowed for approach provided and is mounted at 57.5" (1460 mm) above the finished floor.	§308.2.1	Lower or install door bell at 48" (1219 mm) max. above the finished floor for forward approach to object (2010 ADA Fig. 308.2.1).	B	\$131.00
Arts and Culture	Camp Truitt Education Center	4300 Herschel Road College Park, GA 30337	Men's Restroom	Maneuvering clearance on the pull side of the door is 17" (432 mm).	§404.2.4	Install an automatic door opener or rework area to provide the required 18" (457 mm) min. maneuvering clearance on the pull side of the door beyond the latch side and 60" (1524 mm) min. deep clear floor level area with slopes not exceeding 1:48 (2010 ADA Fig. 404.2.4.1).	B	\$1,500.00

**Fulton County ADA Transition Plan
ARTS AND CULTURE
Appendix 7-10**

Department	Bldg Name	Address	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction	Priority	Cost
Arts and Culture	Camp Truitt Education Center	4300 Herschel Road College Park, GA 30337	Women's Restroom	Maneuvering clearance on the pull side of the door is 16.5" (419 mm).	\$404.2.4	Install an automatic door opener or rework area to provide the required 18" (457 mm) min. maneuvering clearance on the pull side of the door beyond the latch side and 60" (1524 mm) min. deep clear floor leveled area with slopes not exceeding 1:48 (2010 ADA Fig. 404.2.4.1).	B	\$1,500.00
Arts and Culture	Camp Truitt Education Center	4300 Herschel Road College Park, GA 30337	Men's Restroom	Door closing time is less than 5 seconds.	\$404.2.8.1	Provide a sweep period of 5 seconds min. measured from 90° open position to a position of 12" from door latch.	B	\$0.00
Arts and Culture	Camp Truitt Education Center	4300 Herschel Road College Park, GA 30337	Men's Restroom	Door has a non-compliant opening force of 8 lbf.	\$404.2.9	Adjust or replace door closer, maintain door hinges to provide an opening force not to exceed 5 lbf.	B	\$131.00
Arts and Culture	Camp Truitt Education Center	4300 Herschel Road College Park, GA 30337	Two Accessible Parking Spaces in Front of Main Entrance	Right accessible parking space markings are faded.	\$502.3.3	Restripe to provide an accessible parking space 96" (2438 mm) min. wide (2010 ADA Figs. 502.3).	B	\$428.03
Arts and Culture	Camp Truitt Education Center	4300 Herschel Road College Park, GA 30337	Two Accessible Parking Spaces in Front of Main Entrance	Left accessible parking space markings are faded.	\$502.3.3	Restripe to provide an accessible parking space 96" (2438 mm) min. wide (2010 ADA Figs. 502.3).	B	\$428.03
Arts and Culture	Camp Truitt Education Center	4300 Herschel Road College Park, GA 30337	Two Accessible Parking Spaces in Front of Main Entrance	Access aisle markings are faded.	\$502.3.3	Restripe area to provide an accessible parking space that has a 60" (1524 mm) min. wide access aisle with a surface slope not exceeding 2% in all directions (2010 ADA Fig. 502.3).	B	\$428.03
Arts and Culture	Camp Truitt Education Center	4300 Herschel Road College Park, GA 30337	Kitchen Adjacent to Event Hall	Paper towel dispenser is mounted beyond required reach allowed for approach provided and is mounted at 49.75" (1264 mm) above the finished floor to paper.	\$308.2.1	Lower or install paper towel dispenser at 48" (1219 mm) max. above the finished floor to paper for forward approach to object (2010 ADA Fig. 308.3.1). Per 36.304(d)(2)(i) Safe harbor. Elements that comply with the corresponding technical requirements and scoping requirements for those elements in the 1991 Standards do not need to be modified in order to comply with the requirements set forth in the 2010 Standards.	C	\$131.00
Arts and Culture	Camp Truitt Education Center	4300 Herschel Road College Park, GA 30337	Men's Restroom	Paper towel dispenser is mounted beyond required reach allowed for approach provided and is mounted at 51.5" (1308 mm) above the finished floor to paper.	\$308.2.1	Lower or install paper towel dispenser at 48" (1219 mm) max. above the finished floor to paper for forward approach to object (2010 ADA Fig. 308.3.1). Per 36.304(d)(2)(i) Safe harbor. Elements that comply with the corresponding technical requirements and scoping requirements for those elements in the 1991 Standards do not need to be modified in order to comply with the requirements set forth in the 2010 Standards.	C	\$0.00
Arts and Culture	Camp Truitt Education Center	4300 Herschel Road College Park, GA 30337	Men's Restroom	Toilet seat cover dispenser is mounted behind the water closet.	\$308.2.1	Patch wall and relocate toilet seat cover dispenser and mount between 15" to 48" (380 mm - 1219 mm) above the finished floor for unobstructed forward approach to object (2010 ADA Fig. 308.2.1).	C	\$450.00
Arts and Culture	Camp Truitt Education Center	4300 Herschel Road College Park, GA 30337	Women's Restroom	Paper towel dispenser is mounted beyond required reach allowed for approach provided and is mounted at 51.5" (1308 mm) above the finished floor to paper.	\$308.2.1	Lower or install paper towel dispenser at 48" (1219 mm) max. above the finished floor to paper for forward approach to object (2010 ADA Fig. 308.3.1). Per 36.304(d)(2)(i) Safe harbor. Elements that comply with the corresponding technical requirements and scoping requirements for those elements in the 1991 Standards do not need to be modified in order to comply with the requirements set forth in the 2010 Standards.	C	\$0.00
Arts and Culture	Camp Truitt Education Center	4300 Herschel Road College Park, GA 30337	Women's Restroom	Toilet seat cover dispenser is mounted behind the water closet.	\$308.2.1	Patch wall and relocate toilet seat cover dispenser and mount between 15" to 48" (380 mm - 1219 mm) above the finished floor for unobstructed forward approach to object (2010 ADA Fig. 308.2.1).	C	\$450.00
Arts and Culture	Camp Truitt Education Center	4300 Herschel Road College Park, GA 30337	Drinking fountains Adjacent to Restrooms	Drinking fountain on right side has a 26.75" (679 mm) knee clearance.	\$602.1	Relocate/rework fountain to provide a 27" (685 mm) min. knee clearance above the finished floor, 30" (762 mm) min. wide and 25" (635 mm) max. deep (2010 ADA Fig. 306.3).	C	\$697.18
Arts and Culture	Camp Truitt Education Center	4300 Herschel Road College Park, GA 30337	Men's Restroom	Water closet seat is mounted at 19.5" (495 mm) above the finished floor to top.	\$604.4	Retrofit water closet seat and mount between 17" and 19" (431 mm - 482 mm) above the finished floor to top of seat.	C	\$1,029.03
Arts and Culture	Camp Truitt Education Center	4300 Herschel Road College Park, GA 30337	Men's Restroom	Accessible toilet stall door is 5.75" (146 mm) away from side wall	\$604.8.1.1	Rework partitions to provide 4" (102 mm) max from side wall to door (2010 ADA Fig. 604.8.1.1).	C	\$898.00
Arts and Culture	Camp Truitt Education Center	4300 Herschel Road College Park, GA 30337	Men's Restroom	Accessible stall door does not provide pull handles on both sides of the door near the latch.	\$604.8.2.2	Provide pull handles on both sides of the door near the latch and center door opening hardware between 34" and 48" (863 mm - 1219 mm) above the finished floor.	C	\$55.00
Arts and Culture	Camp Truitt Education Center	4300 Herschel Road College Park, GA 30337	Men's Restroom	Accessible compartment (stall) door does not have a self closing mechanism.	\$604.8.2.2	Provide a self closing mechanism on door with an opening force not exceeding 5 lbf.	C	\$291.64
Arts and Culture	Camp Truitt Education Center	4300 Herschel Road College Park, GA 30337	Women's Restroom	Accessible stall door does not provide pull handles on both sides of the door near the latch.	\$604.8.2.2	Provide pull handles on both sides of the door near the latch and center door opening hardware between 34" and 48" (863 mm - 1219 mm) above the finished floor.	C	\$55.00
Arts and Culture	Camp Truitt Education Center	4300 Herschel Road College Park, GA 30337	Women's Restroom	Accessible stall door does not have a self closing mechanism.	\$604.8.2.2	Provide a self closing mechanism on door with an opening force not exceeding 5 lbf.	C	\$291.64
Arts and Culture	Camp Truitt Education Center	4300 Herschel Road College Park, GA 30337	Men's Restroom	Urinal is mounted at 18.75" (476 mm) above the finished floor to top of rim.	\$605.2	Lower urinal and mount at 17" (431 mm) max. above the finished floor to top of rim. (2010 ADA Fig. 605.2)	C	\$1,029.03
Arts and Culture	Camp Truitt Education Center	4300 Herschel Road College Park, GA 30337	Men's Restroom	Toilet paper dispensers is mounted 3" (76.2 mm) over the side wall grab bar.	\$609.3	Relocate toilet paper dispenser to provide a clear space between the side wall grab bar and projecting objects above of 12" (305 mm) min. (2010 ADA Fig. 609.3).	C	\$131.00
Arts and Culture	Camp Truitt Education Center	4300 Herschel Road College Park, GA 30337	Women's Restroom	Toilet tissue dispenser is mounted 2.5" (64 mm) over the side wall grab bar.	\$609.3	Relocate item to provide a clear space between the side wall grab bar and projecting objects above of 12" (305 mm) min. (2010 ADA Fig. 609.3).	C	\$131.00
Arts and Culture	Camp Truitt Education Center	4300 Herschel Road College Park, GA 30337	Kitchen Adjacent to Event Hall	Wall cabinets over the work surface are mounted at 55.75" (1416 mm) above the finished floor to the bottom shelf.	\$804.5	Relocate wall cabinets, above the work surface, and mount at 48" (1219 mm) max. above the finished floor to the bottom shelf. Handles shall be mounted as close to the bottom as possible.	C	\$1,891.00
Arts and Culture	Camp Truitt Education Center	4300 Herschel Road College Park, GA 30337	Main Entrance	Mat is not securely attached to the floor.	\$302.2	Provide a securely attached mat with a leveled loop or level cut pile, with texture height that is 0.5" (13 mm) max. and has a firm cushion pad or backing (2010 ADA Fig. 302.2).	D	\$55.00
Arts and Culture	Cliffondale Arts Center	4654 Butler Rd SW Atlanta, GA 30349	Main Entrance	Accessible entrance does not have signage displaying the international symbol of accessibility.	\$216.6	Provide signage at accessible entrance displaying the International symbol of accessibility.	B	\$149.95
Arts and Culture	Cliffondale Arts Center	4654 Butler Rd SW Atlanta, GA 30349	Auditorium	There is no indication of the number of assistive listening devices provided in the auditorium	\$219.1	Provide hard-wired and/or wireless assistive listening systems as required by Table 219.3. Twenty five percent minimum of receivers shall be hearing aid compatible.	B	\$0.00
Arts and Culture	Cliffondale Arts Center	4654 Butler Rd SW Atlanta, GA 30349	Main Entrance	Mat is not securely attached to the floor.	\$302.2	Provide a securely attached mat with a leveled loop or level cut pile, with texture height that is 0.5" (13 mm) max. and has a firm cushion pad or backing (2010 ADA Fig. 302.2).	B	\$55.00
Arts and Culture	Cliffondale Arts Center	4654 Butler Rd SW Atlanta, GA 30349	Classroom No. 10 (Media Arts)	Vision lights are mounted at a non-compliant height above the finished floor.	\$404.2.11	Provide at least one see-thru glazed panel mounted at 43" (1090 mm) max. above the finished floor.	B	\$149.95
Arts and Culture	Cliffondale Arts Center	4654 Butler Rd SW Atlanta, GA 30349	Dance Studio Room No. 12	Vision lights are mounted at a non-compliant height above the finished floor.	\$404.2.11	Provide at least one see-thru glazed panel mounted at 43" (1090 mm) max. above the finished floor.	B	\$500.00
Arts and Culture	Cliffondale Arts Center	4654 Butler Rd SW Atlanta, GA 30349	Visual Arts Room No. 9	Vision lights are mounted at 55.5" (1410 mm) above the finished floor.	\$404.2.11	Provide at least one see-thru glazed panel mounted at 43" (1090 mm) max. above the finished floor.	B	\$500.00
Arts and Culture	Cliffondale Arts Center	4654 Butler Rd SW Atlanta, GA 30349	Room No. 11	Vision lights are mounted at 57.5" (1460 mm) above the finished floor.	\$404.2.11	Provide at least one see-thru glazed panel mounted at 43" (1090 mm) max. above the finished floor.	B	\$500.00
Arts and Culture	Cliffondale Arts Center	4654 Butler Rd SW Atlanta, GA 30349	Wheel Pottery Room No. 14	Vision lights are mounted at 57" (1448 mm) above the finished floor.	\$404.2.11	Provide at least one see-thru glazed panel mounted at 43" (1090 mm) max. above the finished floor.	B	\$500.00
Arts and Culture	Cliffondale Arts Center	4654 Butler Rd SW Atlanta, GA 30349	Unisex Accessible Restroom on Right	Trash bin encroaches over maneuvering clearance on the pull side of the door reducing it to 8" (203 mm)	\$404.2.4	Relocate trash bin to provide the required 18" (457 mm) min. maneuvering clearance on the pull side of the door (2010 ADA Fig. 404.2.4.1).	B	\$55.00

**Fulton County ADA Transition Plan
ARTS AND CULTURE
Appendix 7-10**

Department	Bldg Name	Address	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction	Priority	Cost
Arts and Culture	Cliffondale Arts Center	4654 Butner Rd SW Atlanta, GA 30349	Unisex Accessible Restroom on Left	Trash bin encroaches over maneuvering clearance on the pull side of the door.	§404.2.4	Relocate trash bin to provide the required 18" (457 mm) min. maneuvering clearance on the pull side of the door (2010 ADA Fig. 404.2.4.1).	B	\$55.00
Arts and Culture	Cliffondale Arts Center	4654 Butner Rd SW Atlanta, GA 30349	Classroom No. 10 (Media Arts)	Desk encroaches over maneuvering clearance on the pull side of the door.	§404.2.4	Relocate desk to provide the required 18" (457 mm) min. maneuvering clearance on the pull side of the door (2010 ADA Fig. 404.2.4.1).	B	\$55.00
Arts and Culture	Cliffondale Arts Center	4654 Butner Rd SW Atlanta, GA 30349	Wheel Pottery Room No. 14	Shelf encroaches over maneuvering clearance on the pull side of the door reducing it to 5.5" (140 mm)	§404.2.4	Relocate shelf to provide the required 18" (457 mm) min. maneuvering clearance on the pull side of the door (2010 ADA Fig. 404.2.4.1).	B	\$131.00
Arts and Culture	Cliffondale Arts Center	4654 Butner Rd SW Atlanta, GA 30349	Boys Accessible Restroom Adjacent to Activity Room No. 10	Maneuvering clearance on the pull side of the door is 39.5" (1003 mm) wide for a parallel latch approach.	§404.2.4	Install an automatic door opener and/or rework privacy partition to provide the required 24" (609 mm) min. maneuvering clearance on the pull side of the door for a parallel latch side approach and 54" (1370 mm) min. deep clear floor area (For door with a closer) (2010 ADA Fig. 404.2.4.1).	B	\$1,500.00
Arts and Culture	Cliffondale Arts Center	4654 Butner Rd SW Atlanta, GA 30349	Multipurpose Room	Non-compliant knob-type door hardware, requiring grasping and turning of the wrist to operate.	§404.2.7	Replace or retrofit with system operable with one hand, not requiring pinching, tight grasping or turning of the wrist to operate.	B	\$291.64
Arts and Culture	Cliffondale Arts Center	4654 Butner Rd SW Atlanta, GA 30349	Room Adjacent to Activity Room in Front of Classroom No. 10	Non-compliant knob-type door hardware, requiring grasping and turning of the wrist to operate.	§404.2.7	Replace or retrofit with system operable with one hand, not requiring pinching, tight grasping or turning of the wrist to operate.	B	\$291.64
Arts and Culture	Cliffondale Arts Center	4654 Butner Rd SW Atlanta, GA 30349	Boys Accessible Restroom Adjacent to Activity Room No. 10	Door closing time is less than 5 seconds.	§404.2.8.1	Provide a sweep period of 5 seconds min. measured from 90° open position to a position of 12° from door latch.	B	\$131.00
Arts and Culture	Cliffondale Arts Center	4654 Butner Rd SW Atlanta, GA 30349	Main Entrance	Door has a non-compliant opening force of 12 lbf.	§404.2.9	Adjust or replace door closer, maintain door hinges to provide an opening force not to exceed 5 lbf.	B	\$131.00
Arts and Culture	Cliffondale Arts Center	4654 Butner Rd SW Atlanta, GA 30349	Unisex Accessible Restroom on Right	Door has a non-compliant opening force of 9 lbf.	§404.2.9	Adjust or replace door closer, maintain door hinges to provide an opening force not to exceed 5 lbf.	B	\$131.00
Arts and Culture	Cliffondale Arts Center	4654 Butner Rd SW Atlanta, GA 30349	Unisex Accessible Restroom on Left	Door has a non-compliant opening force of 7 lbf.	§404.2.9	Adjust or replace door closer, maintain door hinges to provide an opening force not to exceed 5 lbf.	B	\$131.00
Arts and Culture	Cliffondale Arts Center	4654 Butner Rd SW Atlanta, GA 30349	Boys Accessible Restroom Adjacent to Activity Room No. 10	Door has a non-compliant opening force of 16 lbf.	§404.2.9	Adjust or replace door closer, maintain door hinges to provide an opening force not to exceed 5 lbf.	B	\$131.00
Arts and Culture	Cliffondale Arts Center	4654 Butner Rd SW Atlanta, GA 30349	Ramp Leading to The Main Entrance	The top portion of the ramp does not provide a curb or barrier edge protection.	§405.9.2	Rework ramp to provide a curb or barrier that prevents the passage of a 4" (100 mm) diameter sphere, where any portion of the sphere is within 4" (100 mm) of the finished floor or ground surface (2010 ADA Fig 405.9.2)	B	\$3,200.00
Arts and Culture	Cliffondale Arts Center	4654 Butner Rd SW Atlanta, GA 30349	Two Accessible Parking Spaces by Parks and Recreation Building	The surface of the accessible parking space on left is cracked and has gaps up to 1" (25 mm).	§502	Rework and clean accessible parking spaces to provide a stable, firm, and slip-resistant floor with surface slopes not exceeding 2%.	B	\$0.00
Arts and Culture	Cliffondale Arts Center	4654 Butner Rd SW Atlanta, GA 30349	Two Accessible Parking Spaces by Entrance to Baseball Field	The surface of the accessible parking space on left is cracked.	§502	Rework and clean accessible parking spaces to provide a stable, firm, and slip-resistant floor with surface slopes not exceeding 2%.	B	\$0.00
Arts and Culture	Cliffondale Arts Center	4654 Butner Rd SW Atlanta, GA 30349	Two Accessible Parking Spaces by Parks and Recreation Building	Van accessible parking space on left is 126" (3200 mm) wide measured from centerline to the centerline.	§502.2	Restripe to provide a van-accessible parking space 132" (3352 mm) min. wide and a 60" (1524 mm) min. wide access aisle with a surface slope not exceeding 2% in all directions (2010 ADA Figs. 502.2 - 502.3).	B	\$1,897.39
Arts and Culture	Cliffondale Arts Center	4654 Butner Rd SW Atlanta, GA 30349	Accessible Parking Spaces by Ramp Leading to Main Entrance	Van-accessible parking space is not clearly outlined or needs to be restriped.	§502.2	Restripe to provide a van-accessible parking space 132" (3352 mm) min. wide and a 60" (1524 mm) min. wide access aisle with a surface slope not exceeding 2% in all directions (2010 ADA Figs. 502.2 - 502.3).	B	\$427.83
Arts and Culture	Cliffondale Arts Center	4654 Butner Rd SW Atlanta, GA 30349	Two Accessible Parking Spaces by Parks and Recreation Building	Van accessible parking space on right is 107" (2718 mm) wide measured from centerline to the centerline.	§502.3	Restripe to provide a van-accessible parking space 132" (3352 mm) min. wide and a 60" (1524 mm) min. wide access aisle with a surface slope not exceeding 2% in all directions (2010 ADA Figs. 502.2 - 502.3).	B	\$1,897.39
Arts and Culture	Cliffondale Arts Center	4654 Butner Rd SW Atlanta, GA 30349	Two Accessible Parking Spaces by Entrance to Baseball Field	Accessible parking space is 93" (2362 mm) wide measured from centerline to centerline	§502.3.1	Restripe to provide an accessible parking space 96" (2438 mm) min. wide and a 60" (15258 mm) min. wide access aisle with a surface slope not exceeding 2% in all directions (2010 ADA Figs. 502.3).	B	\$0.00

**Fulton County ADA Transition Plan
ARTS AND CULTURE
Appendix 7-10**

Department	Bldg Name	Address	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction	Priority	Cost
Arts and Culture	Cliffondale Arts Center	4654 Butler Rd SW Atlanta, GA 30349	Two Accessible Parking Spaces by Entrance to Baseball Field	Accessible parking space on right is 87.5" (2222 mm) wide measured from centerline to centerline.	\$502.3.1	Restripe to provide an accessible parking space 96" (2438 mm) min. wide and a 60" (15258 mm) min. wide access aisle with a surface slope not exceeding 2% in all directions (2010 ADA Figs. 502.3).	B	\$0.00
Arts and Culture	Cliffondale Arts Center	4654 Butler Rd SW Atlanta, GA 30349	Two Accessible Parking Spaces by Entrance to Baseball Field	Access aisle has a non-compliant surface slope of up to 3.3%	\$502.4	Rework or repave to provide an access aisle with surface slope not exceeding 2% in all directions.	B	\$0.00
Arts and Culture	Cliffondale Arts Center	4654 Butler Rd SW Atlanta, GA 30349	Two Accessible Parking Spaces by Entrance to Baseball Field	Accessible parking space has a non-compliant surface slope of up to 2.7%	\$502.4	Rework or repave to provide an accessible parking space with surface slope not exceeding 2% in all directions.	B	\$1,897.39
Arts and Culture	Cliffondale Arts Center	4654 Butler Rd SW Atlanta, GA 30349	Two Accessible Parking Spaces by Entrance to Baseball Field	Signage indicating accessible parking on left is mounted at 32" (813 mm) above the finished floor.	\$502.6	Install signage indicating accessible parking that displays the international symbol of accessibility and mount at 60" (1524 mm) min. above the finished floor.	B	\$0.00
Arts and Culture	Cliffondale Arts Center	4654 Butler Rd SW Atlanta, GA 30349	Two Accessible Parking Spaces by Entrance to Baseball Field	Signage indicating accessible parking on right is mounted at 56.5" (1435 mm) above the finished floor.	\$502.6	Install signage indicating accessible parking that displays the international symbol of accessibility and mount at 60" (1524 mm) min. above the finished floor.	B	\$0.00
Arts and Culture	Cliffondale Arts Center	4654 Butler Rd SW Atlanta, GA 30349	Two Accessible Parking Spaces by Entrance to Baseball Field	Accessible parking space on right has a non-compliant running slope of up to 2.7%	\$504.2	Rework or repave to provide an accessible parking space with surface slope not exceeding 2% in all directions.	B	\$1,897.39
Arts and Culture	Cliffondale Arts Center	4654 Butler Rd SW Atlanta, GA 30349	Work Stations at Corridor	Computers do not appear to have accessible software.	\$508	Title II of the ADA requires that programs, services and activities offered by public agencies be accessible to persons with disabilities. Section 508 of the Rehabilitation Act of 1973 provides guidelines for developing, procuring, maintaining, or using electronic and information technology. Per Section 508 ensure computer provides accessible hardware/software	B	\$1,500.00
Arts and Culture	Cliffondale Arts Center	4654 Butler Rd SW Atlanta, GA 30349	Classroom No. 10 (Media Arts)	Computers do not appear to have accessible software.	\$508	Title II of the ADA requires that programs, services and activities offered by public agencies be accessible to persons with disabilities. Section 508 of the Rehabilitation Act of 1973 provides guidelines for developing, procuring, maintaining, or using electronic and information technology. Per Section 508 ensure computer provides accessible hardware/software	B	\$1,500.00
Arts and Culture	Cliffondale Arts Center	4654 Butler Rd SW Atlanta, GA 30349	Activity Room in Front of Classroom No. 10	Computers do not appear to have accessible software.	\$508	Title II of the ADA requires that programs, services and activities offered by public agencies be accessible to persons with disabilities. Section 508 of the Rehabilitation Act of 1973 provides guidelines for developing, procuring, maintaining, or using electronic and information technology.	B	\$1,500.00
Arts and Culture	Cliffondale Arts Center	4654 Butler Rd SW Atlanta, GA 30349	Auditorium	Auditorium does not have permanent room identifying sign with Braille or raised characters.	\$703.4.1	Provide signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. from the baseline of the highest tactile character (2010 ADA Fig. 703.4.1).	B	\$149.95
Arts and Culture	Cliffondale Arts Center	4654 Butler Rd SW Atlanta, GA 30349	Classroom No. 8	Permanent room identifying signage does not have Braille or raised characters and is mounted over the door header.	\$703.4.1	Provide signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. from the baseline of the highest tactile character (2010 ADA Fig. 703.4.1).	B	\$149.95
Arts and Culture	Cliffondale Arts Center	4654 Butler Rd SW Atlanta, GA 30349	Classroom No. 10 (Media Arts)	Permanent room identifying signage does not have Braille or raised characters.	\$703.4.1	Provide signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. from the baseline of the highest tactile character (2010 ADA Fig. 703.4.1).	B	\$149.95
Arts and Culture	Cliffondale Arts Center	4654 Butler Rd SW Atlanta, GA 30349	Activity Room in Front of Classroom No. 10	Activity room does not have permanent identifying signage with Braille or raised characters.	\$703.4.1	Provide signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. from the baseline of the highest tactile character (2010 ADA Fig. 703.4.1).	B	\$149.95
Arts and Culture	Cliffondale Arts Center	4654 Butler Rd SW Atlanta, GA 30349	Room Adjacent to Activity Room in Front of Classroom No. 10	Classroom does not have identifying signage with Braille or raised characters.	\$703.4.1	Provide signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. from the baseline of the highest tactile character (2010 ADA Fig. 703.4.1).	B	\$149.95
Arts and Culture	Cliffondale Arts Center	4654 Butler Rd SW Atlanta, GA 30349	Girls Accessible Restroom Adjacent to Activity Room No. 10	Permanent room identifying signage does not have Braille or raised characters and is mounted on the door leaf.	\$703.4.1	Provide signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. from the baseline of the highest tactile character (2010 ADA Fig. 703.4.1).	B	\$149.95
Arts and Culture	Cliffondale Arts Center	4654 Butler Rd SW Atlanta, GA 30349	Dance Studio Room No. 12	Permanent room identifying signage does not have Braille or raised characters.	\$703.4.1	Provide signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. from the baseline of the highest tactile character (2010 ADA Fig. 703.4.1).	B	\$149.95
Arts and Culture	Cliffondale Arts Center	4654 Butler Rd SW Atlanta, GA 30349	Visual Arts Room No. 9	Permanent room identifying signage does not have Braille or raised characters.	\$703.4.1	Provide signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. from the baseline of the highest tactile character (2010 ADA Fig. 703.4.1).	B	\$149.95
Arts and Culture	Cliffondale Arts Center	4654 Butler Rd SW Atlanta, GA 30349	Room No. 11	Permanent room identifying signage does not have Braille or raised characters and is mounted over the door header.	\$703.4.1	Provide signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. from the baseline of the highest tactile character (2010 ADA Fig. 703.4.1).	B	\$149.95
Arts and Culture	Cliffondale Arts Center	4654 Butler Rd SW Atlanta, GA 30349	Wheel Pottery Room No. 14	Permanent room identifying signage does not have Braille or raised characters.	\$703.4.1	Provide signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. from the baseline of the highest tactile character (2010 ADA Fig. 703.4.1).	B	\$149.95

**Fulton County ADA Transition Plan
ARTS AND CULTURE
Appendix 7-10**

Department	Bldg Name	Address	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction	Priority	Cost
Arts and Culture	Cliffondale Arts Center	4654 Butner Rd SW Atlanta, GA 30349	Auditorium	There is no signage indicating that assistive listening systems are provided in the auditorium.	§703.7.2.4	Provide signage by entrance to auditorium for assistive listening systems, identified by a symbol indicating International Symbol of Access for Hearing Loss (2010 ADA Fig. 703.7.2.4).	B	\$2,779.95
Arts and Culture	Cliffondale Arts Center	4654 Butner Rd SW Atlanta, GA 30349	Auditorium	There is no indication of the location of the accessible wheelchair spaces.	§802.2	Provide accessible wheelchair spaces as required by 2010 ADA Table 221.2.1.1 "Number of Wheelchair Spaces in Assembly Area". Ensure wheelchair areas are located so as to provide different lines of sight and have an adjacent fixed seat for companion per area (2010 ADA Figs. 802.2).	B	\$640.44
Arts and Culture	Cliffondale Arts Center	4654 Butner Rd SW Atlanta, GA 30349	Activity Room in Front of Classroom No. 10	Carpet pile texture height exceeds 0.5" (13 mm).	§302.2	Provide a securely attached carpet with a leveled loop or level cut pile, with texture height that is 0.5" (13 mm) max. and has a firm cushion pad or backing (2010 ADA Fig. 302.2).	C	\$650.00
Arts and Culture	Cliffondale Arts Center	4654 Butner Rd SW Atlanta, GA 30349	Main Entrance	Bench encroaches over key pad clear floor space.	§305.3	Relocate bench to provide a 30" by 48" (762 mm by 1219 mm) min. wheelchair clear floor space (2010 ADA Figs. 305.3-305.5).	C	\$378.00
Arts and Culture	Cliffondale Arts Center	4654 Butner Rd SW Atlanta, GA 30349	Classroom No. 10 (Media Arts)	Desk encroaches over thermostat and fan speed control clear floor space.	§305.3	Relocate desk to provide a 30" by 48" (762 mm by 1219 mm) min. wheelchair clear floor space (2010 ADA Figs. 305.3-305.5).	C	\$0.00
Arts and Culture	Cliffondale Arts Center	4654 Butner Rd SW Atlanta, GA 30349	Activity Room in Front of Classroom No. 10	Table encroaches over thermostat clear floor space.	§305.3	Relocate table to provide a 30" by 48" (762 mm by 1219 mm) min. wheelchair clear floor space (2010 ADA Figs. 305.3-305.5).	C	\$0.00
Arts and Culture	Cliffondale Arts Center	4654 Butner Rd SW Atlanta, GA 30349	Dance Studio Room No. 12	Shelf encroaches over light switch and fan speed control clear floor space.	§305.3	Relocate shelf to provide a 30" by 48" (762 mm by 1219 mm) min. wheelchair clear floor space at light switch and fan speed control (2010 ADA Figs. 305.3-305.5).	C	\$0.00
Arts and Culture	Cliffondale Arts Center	4654 Butner Rd SW Atlanta, GA 30349	Visual Arts Room No. 9	Lavatory encroaches over paper towel dispenser clear floor space.	§305.3	Relocate paper towel dispenser to provide a 30" by 48" (762 mm by 1219 mm) min. wheelchair clear floor space (2010 ADA Figs. 305.3-305.5).	C	\$0.00
Arts and Culture	Cliffondale Arts Center	4654 Butner Rd SW Atlanta, GA 30349	Room No. 11	Trash bin encroaches over light switch and fan speed control clear floor space.	§305.3	Relocate trash bin to provide a 30" by 48" (762 mm by 1219 mm) min. wheelchair clear floor space (2010 ADA Figs. 305.3-305.5).	C	\$0.00
Arts and Culture	Cliffondale Arts Center	4654 Butner Rd SW Atlanta, GA 30349	Wheel Pottery Room No. 14	Shelf encroaches over fan speed control and light switch clear floor space.	§305.3	Relocate shelf to provide a 30" by 48" (762 mm by 1219 mm) min. wheelchair clear floor space at fan speed control and light switch (2010 ADA Figs. 305.3-305.5).	C	\$0.00
Arts and Culture	Cliffondale Arts Center	4654 Butner Rd SW Atlanta, GA 30349	Girls Accessible Restroom Adjacent to Activity Room No. 10	Paper towel dispenser protrudes into walkway, projecting 9.5" (241 mm) from back wall, and is mounted at 45.75" (1162 mm) above the finished floor to its bottom leading edge.	§307.2r	Relocate or recess paper towel dispenser so that it does not project more than 4" (101 mm) from back wall to outer leading edge (2010 ADA Fig. 307.2).	C	\$131.00
Arts and Culture	Cliffondale Arts Center	4654 Butner Rd SW Atlanta, GA 30349	Corridor by Visual Arts Room No. 9	Display protrudes into walkway, projecting 4.75" (121 mm) from back wall, and is mounted at 57.75" (1467 mm) above the finished floor to its bottom leading edge.	§307.2r	Relocate or recess display so that it does not project more than 4" (101 mm) from back wall to outer leading edge (2010 ADA Fig. 307.2).	C	\$300.00
Arts and Culture	Cliffondale Arts Center	4654 Butner Rd SW Atlanta, GA 30349	Main Entrance	Key pad is mounted beyond required reach allowed for approach provided and is mounted at 61.75" (1568 mm) above the finished floor.	§308.2.1	Lower or install key pad at 48" (1219 mm) max. above the finished floor for forward approach to object (2010 ADA Fig. 308.2.1).	C	\$378.00
Arts and Culture	Cliffondale Arts Center	4654 Butner Rd SW Atlanta, GA 30349	Classroom No. 8	Fan speed control is mounted beyond required reach allowed for approach provided and is mounted at 70" (1778 mm) above the finished floor to the highest operable part.	§308.2.1	Lower or install fan speed control at 48" (1219 mm) max. above the finished floor for forward approach to object (2010 ADA Fig. 308.2.1).	C	\$378.00
Arts and Culture	Cliffondale Arts Center	4654 Butner Rd SW Atlanta, GA 30349	Classroom No. 8	Thermostat is mounted beyond required reach allowed for approach provided and is mounted at 61.75" (1568 mm) above the finished floor to the centerline of the highest operable part.	§308.2.1	Lower or install thermostat at 48" (1219 mm) max. above the finished floor to the centerline of the highest operable part for forward approach to object (2010 ADA Fig. 308.2.1).	C	\$378.00
Arts and Culture	Cliffondale Arts Center	4654 Butner Rd SW Atlanta, GA 30349	Classroom No. 10 (Media Arts)	Fan speed control is mounted beyond required reach allowed for approach provided and is mounted at 74" (1880 mm) above the finished floor to the highest operable part.	§308.2.1	Lower or install fan speed control at 48" (1219 mm) max. above the finished floor to the centerline of the highest operable part for forward approach to object (2010 ADA Fig. 308.2.1).	C	\$378.00
Arts and Culture	Cliffondale Arts Center	4654 Butner Rd SW Atlanta, GA 30349	Classroom No. 10 (Media Arts)	Thermostat is mounted beyond required reach allowed for approach provided and is mounted at 60.75" (1543 mm) above the finished floor to the centerline of the highest operable part.	§308.2.1	Lower or install thermostat at 48" (1219 mm) max. above the finished floor to the centerline of the highest operable part for forward approach to object (2010 ADA Fig. 308.2.1).	C	\$378.00
Arts and Culture	Cliffondale Arts Center	4654 Butner Rd SW Atlanta, GA 30349	Classroom No. 10 (Media Arts)	First aid kit is mounted beyond required reach allowed for approach provided and is mounted at 59" (1499 mm) above the finished floor to the latch.	§308.2.1	Lower or install first aid kit at 48" (1219 mm) max. above the finished floor to the latch for forward approach to object (2010 ADA Fig. 308.2.1).	C	\$131.00
Arts and Culture	Cliffondale Arts Center	4654 Butner Rd SW Atlanta, GA 30349	Activity Room in Front of Classroom No. 10	Thermostat is mounted beyond required reach allowed for approach provided and is mounted at 59.75" (1518 mm) above the finished floor to the centerline of the highest operable part.	§308.2.1	Lower or install thermostat at 48" (1219 mm) max. above the finished floor to the highest operable part for forward approach to object (2010 ADA Fig. 308.2.1).	C	\$378.00
Arts and Culture	Cliffondale Arts Center	4654 Butner Rd SW Atlanta, GA 30349	Activity Room in Front of Classroom No. 10	Light switch is mounted at 75" (1905 mm) above the finished floor to the highest operable part.	§308.2.1	Install light switch at 48" (1219 mm) max. above the finished floor to the highest operable part for a forward approach to object (2010 ADA Fig. 308.2.1).	C	\$378.00
Arts and Culture	Cliffondale Arts Center	4654 Butner Rd SW Atlanta, GA 30349	Boys Accessible Restroom Adjacent to Activity Room No. 10	Paper towel dispenser is mounted beyond required reach allowed for approach provided and is mounted at 52.5" (1334 mm) above the finished floor to paper.	§308.2.1	Lower or install paper towel dispenser at 48" (1219 mm) max. above the finished floor to paper for forward approach to object (2010 ADA Fig. 308.3.1). <i>Per 36.304(d)(2)(i) Safe harbor. Elements that comply with the corresponding technical requirements and scoping requirements for those elements in the 1991 Standards do not need to be modified in order to comply with the requirements set forth in the 2010 Standards.</i>	C	\$0.00
Arts and Culture	Cliffondale Arts Center	4654 Butner Rd SW Atlanta, GA 30349	Boys Accessible Restroom Adjacent to Activity Room No. 10	Toilet seat cover dispenser is mounted at a non-compliant height above the finished floor.	§308.2.1	Lower or install toilet seat cover dispenser 36" (915 mm) max. above the finished floor to the highest operable part for forward approach to object (2010 Children's Reach Ranges Advisory 308.1).	C	\$131.00
Arts and Culture	Cliffondale Arts Center	4654 Butner Rd SW Atlanta, GA 30349	Girls Accessible Restroom Adjacent to Activity Room No. 10	Paper towel dispenser is mounted beyond required reach allowed for approach provided and is mounted at 52.75" (1340 mm) above the finished floor to paper.	§308.2.1	Lower or install paper towel dispenser at 48" (1219 mm) max. above the finished floor to paper for forward approach to object (2010 ADA Fig. 308.3.1).	C	\$131.00
Arts and Culture	Cliffondale Arts Center	4654 Butner Rd SW Atlanta, GA 30349	Girls Accessible Restroom Adjacent to Activity Room No. 10	Toilet seat cover dispenser is mounted at a non-compliant height above the finished floor	§308.2.1	Relocate toilet seat cover dispenser and mount between 20" to 36" (510 mm - 915 mm) above the finished floor for unobstructed forward approach to object (2010 ADA Fig. 308.1 Children's Reach Ranges ages 3 and 4).	C	\$131.00
Arts and Culture	Cliffondale Arts Center	4654 Butner Rd SW Atlanta, GA 30349	Dance Studio Room No. 12	Light switch is mounted at 73" (1854 mm) above the finished floor to the highest operable part.	§308.2.1	Install light switch at 48" (1219 mm) max. above the finished floor to the highest operable part for a forward approach to object (2010 ADA Fig. 308.2.1).	C	\$378.00
Arts and Culture	Cliffondale Arts Center	4654 Butner Rd SW Atlanta, GA 30349	Visual Arts Room No. 9	Light switch is mounted at 74.5" (1892 mm) above the finished floor to the highest operable part.	§308.2.1	Install light switch at 48" (1219 mm) max. above the finished floor to the highest operable part for a forward approach to object (2010 ADA Fig. 308.2.1).	C	\$378.00
Arts and Culture	Cliffondale Arts Center	4654 Butner Rd SW Atlanta, GA 30349	Visual Arts Room No. 9	Fan speed control is mounted at 75" (1905 mm) above the finished floor to the highest operable part.	§308.2.1	Install fan speed control at 48" (1219 mm) max. above the finished floor to the highest operable part for a forward approach to object (2010 ADA Fig. 308.2.1).	C	\$378.00
Arts and Culture	Cliffondale Arts Center	4654 Butner Rd SW Atlanta, GA 30349	Visual Arts Room No. 9	Paper towel dispenser is mounted beyond required reach allowed for approach provided and is mounted at 58" (1473 mm) above the finished floor to the	§308.2.1	Lower or install paper towel dispenser at 48" (1219 mm) max. above the finished floor to the highest operable part (2010 ADA Fig. 308.3.1).	C	\$102.12
Arts and Culture	Cliffondale Arts Center	4654 Butner Rd SW Atlanta, GA 30349	Room No. 11	Light switch is mounted at 74" (1880 mm) above the finished floor to the highest operable part.	§308.2.1	Install light switch at 48" (1219 mm) max. above the finished floor to the highest operable part for a forward approach to object (2010 ADA Fig. 308.2.1).	C	\$378.00
Arts and Culture	Cliffondale Arts Center	4654 Butner Rd SW Atlanta, GA 30349	Room No. 11	Fan speed control is mounted beyond required reach allowed for approach provided and is mounted at 73.25" (1861 mm) above the finished floor to the centerline of the highest operable part.	§308.2.1	Lower or install fan speed control at 48" (1219 mm) max. above the finished floor to the centerline of the highest operable part (2010 ADA Fig. 308.2.1).	C	\$378.00

**Fulton County ADA Transition Plan
ARTS AND CULTURE
Appendix 7-10**

Department	Bldg Name	Address	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction	Priority	Cost
Arts and Culture	Cliffondale Arts Center	4654 Butner Rd SW Atlanta, GA 30349	Room No. 11	Paper towel dispenser is mounted beyond required reach allowed for approach provided and is mounted at 58" (1473 mm) above the finished floor to the highest operable part.	\$308.2.1	Lower or install paper towel dispenser at 48" (1219 mm) max. above the finished floor to the highest operable part (2010 ADA Fig. 308.3.1).	C	\$131.00
Arts and Culture	Cliffondale Arts Center	4654 Butner Rd SW Atlanta, GA 30349	Wheel Pottery Room No. 14	Light switch is mounted at 74" (1880 mm) above the finished floor to the highest operable part.	\$308.2.1	Install light switch at 48" (1219 mm) max. above the finished floor to the highest operable part for a forward approach to object (2010 ADA Fig. 308.2.1).	C	\$378.00
Arts and Culture	Cliffondale Arts Center	4654 Butner Rd SW Atlanta, GA 30349	Wheel Pottery Room No. 14	Fan speed control is mounted at 75" (1905 mm) above the finished floor to the highest operable part.	\$308.2.1	Install fan speed control at 48" (1219 mm) max. above the finished floor to the highest operable part for a forward approach to object (2010 ADA Fig. 308.2.1).	C	\$378.00
Arts and Culture	Cliffondale Arts Center	4654 Butner Rd SW Atlanta, GA 30349	Girls Accessible Restroom Adjacent to Activity Room No. 10	Coat hook is mounted beyond required reach allowed for approach provided and is mounted at 58.25" (1480 mm) above the finished floor.	\$308.3	Lower or install coat hook at 48" (1219 mm) max. above the finished floor for forward approach to object (2010 ADA Fig. 308.3.1).	C	\$55.00
Arts and Culture	Cliffondale Arts Center	4654 Butner Rd SW Atlanta, GA 30349	Girls Accessible Restroom Adjacent to Activity Room No. 10	Stall hardware requires pinching and tight grasping to operate.	\$309.4	Replace or retrofit with system operable with one hand, not requiring pinching, tight grasping or turning of the wrist to operate.	C	\$0.00
Arts and Culture	Cliffondale Arts Center	4654 Butner Rd SW Atlanta, GA 30349	Girls Accessible Restroom Adjacent to Activity Room No. 10	Stall doorway opening has a clear width of 28.5" (724 mm).	\$404.2.3	Rework stall doorway (partitions) to provide the required 32" (812 mm) min. clear door or entryway width (2010 ADA Fig. 404.2.3).	C	\$0.00
Arts and Culture	Cliffondale Arts Center	4654 Butner Rd SW Atlanta, GA 30349	Dance Studio Room No. 12	Shelf encroaches over maneuvering clearance on the pull side of the door reducing it to 9.25" (235 mm).	\$404.2.4	Relocate shelf to provide the required 18" (457 mm) min. maneuvering clearance on the pull side of the door (2010 ADA Fig. 404.2.4.1).	C	\$55.00
Arts and Culture	Cliffondale Arts Center	4654 Butner Rd SW Atlanta, GA 30349	Unisex Accessible Restroom on Left	Lavatory mirror is mounted at 40.75" (1035 mm) above the finished floor to bottom edge of its reflecting surface.	\$603.3	Lower lavatory mirror to 40" (1016 mm) max. above the finished floor to bottom edge of its reflecting surface.	C	\$131.00
Arts and Culture	Cliffondale Arts Center	4654 Butner Rd SW Atlanta, GA 30349	Boys Accessible Restroom Adjacent to Activity Room No. 10	Coat hook is mounted beyond required reach allowed for approach provided and is mounted at 53" (1346 mm) above the finished floor.	\$603.4	Lower or install coat hook at 48" (1219 mm) max. above the finished floor for forward approach to object.	C	\$55.00
Arts and Culture	Cliffondale Arts Center	4654 Butner Rd SW Atlanta, GA 30349	Girls Accessible Restroom Adjacent to Activity Room No. 10	Coat hook is mounted beyond required reach allowed for approach provided and is mounted at 52.75" (1340 mm) above the finished floor.	\$603.4	Lower or install coat hook at 48" (1219 mm) max. above the finished floor for forward approach to object (For toilet and bathing rooms only).	C	\$55.00
Arts and Culture	Cliffondale Arts Center	4654 Butner Rd SW Atlanta, GA 30349	Boys Accessible Restroom Adjacent to Activity Room No. 10	Water closet is centered at 16.5" (419 mm) from side wall.	\$604.2	Retrofit water closet seat and center between 12" and 15" (305 mm - 380 mm) above the finished floor to top of seat. (Per 2010 ADA §604.9.6 Advisory Specifications for Water Closets Serving Ages 3 Through 12)	C	\$1,029.83
Arts and Culture	Cliffondale Arts Center	4654 Butner Rd SW Atlanta, GA 30349	Girls Accessible Restroom Adjacent to Activity Room No. 10	Water closet is centered at 19.25" (489 mm) from side wall.	\$604.2	Relocate water closet and center between 16" and 18" (406 mm - 457 mm) from side wall (2010 ADA Fig. 604.2).	C	\$1,029.83
Arts and Culture	Cliffondale Arts Center	4654 Butner Rd SW Atlanta, GA 30349	Girls Accessible Restroom Adjacent to Activity Room No. 10	Water closet is centered at 17" (432 mm) from side wall.	\$604.2 \$604.9.6	We recommend relocating water closet and centering between 12" and 15" (305 mm - 380 mm) from side wall (2010 ADA Fig. 604.2). (Per 2010 ADA §604.9.6 Advisory Specifications for Water Closets Serving Ages 3 Through 12).	C	\$1,029.83
Arts and Culture	Cliffondale Arts Center	4654 Butner Rd SW Atlanta, GA 30349	Unisex Accessible Restroom on Right	Lavatory in stall is mounted at 45.5" (1156 mm) from water closet side wall to the outer leading edge and encroaches over water closet clear floor space.	\$604.3.1	Reconfigure restroom's fixtures and/or offset partitions to provide the required 60" by 56" (1524 mm by 1422 mm) min. clearance at the water closet (2010 ADA Fig. 604.3.1). Per 36.304(d)(2)(i) Safe harbor. Elements that comply with the corresponding technical requirements and scoping requirements for those elements in the 1991 Standards do not need to be modified in order to comply with the requirements set forth in the 2010 Standards.	C	\$0.00
Arts and Culture	Cliffondale Arts Center	4654 Butner Rd SW Atlanta, GA 30349	Unisex Accessible Restroom on Right	Water closet side wall grab bar is mounted at 46" (1168 mm) perpendicular from rear wall to centerline of its outer flange.	\$604.5.1	Install a 42" (1066 mm) min. long side wall grab bar at 54" (1371 mm) min. perpendicular from rear wall to centerline of outer flange and at 12" (305 mm) max. perpendicular from rear wall to centerline of inner flange. Mount at 33"- 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig. 604.5.1).	C	\$0.00
Arts and Culture	Cliffondale Arts Center	4654 Butner Rd SW Atlanta, GA 30349	Unisex Accessible Restroom on Right	Water closet side wall grab bar is mounted at 36.75" (933 mm) above the finished floor to the top of the gripping surface.	\$604.5.1	Install a 42" (1066 mm) min. long side wall grab bar at 54" (1371 mm) min. from rear wall to centerline of outer flange and mount at 33"- 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig. 604.5.1).	C	\$150.00
Arts and Culture	Cliffondale Arts Center	4654 Butner Rd SW Atlanta, GA 30349	Unisex Accessible Restroom on Left	Water closet side wall grab bar is mounted at 46" (1168 mm) perpendicular from rear wall to centerline of its outer flange.	\$604.5.1	Install a 42" (1066 mm) min. long side wall grab bar at 54" (1371 mm) min. perpendicular from rear wall to centerline of outer flange and at 12" (305 mm) max. perpendicular from rear wall to centerline of inner flange. Mount at 33"- 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig. 604.5.1).	C	\$0.00
Arts and Culture	Cliffondale Arts Center	4654 Butner Rd SW Atlanta, GA 30349	Unisex Accessible Restroom on Left	Water closet side wall grab bar is mounted at 37" (940 mm) above the finished floor to the top of the gripping surface.	\$604.5.1	Install a 42" (1066 mm) min. long side wall grab bar at 54" (1371 mm) min. perpendicular from rear wall to centerline of outer flange and at 12" (305 mm) max. perpendicular from rear wall to centerline of inner flange. Mount at 33"- 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig. 604.5.1).	C	\$150.00
Arts and Culture	Cliffondale Arts Center	4654 Butner Rd SW Atlanta, GA 30349	Boys Accessible Restroom Adjacent to Activity Room No. 10	Water closet side wall grab bar is mounted at 45" (1143 mm) perpendicular from rear wall to centerline of its outer flange.	\$604.5.1	Install a 42" (1066 mm) min. long side wall grab bar at 54" (1371 mm) min. perpendicular from rear wall to centerline of outer flange and at 12" (305 mm) max. perpendicular from rear wall to centerline of inner flange. Mount at 33"- 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig. 604.5.1).	C	\$150.00
Arts and Culture	Cliffondale Arts Center	4654 Butner Rd SW Atlanta, GA 30349	Unisex Accessible Restroom on Right	Water closet rear wall grab bar is mounted at 37" (940 mm) above the finished floor to the top of the gripping surface.	\$604.5.2	Relocate rear wall grab bar and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface.	C	\$150.00
Arts and Culture	Cliffondale Arts Center	4654 Butner Rd SW Atlanta, GA 30349	Unisex Accessible Restroom on Left	Water closet rear wall grab bar is mounted at 36.75" (933 mm) above the finished floor to the top of the gripping surface.	\$604.5.2	Relocate rear wall grab bar and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface.	C	\$150.00
Arts and Culture	Cliffondale Arts Center	4654 Butner Rd SW Atlanta, GA 30349	Unisex Accessible Restroom on Left	Water closet flush control is toward the wall side.	\$604.6	Rotate water closet flush control toward the open side or install an electronically controlled mechanism.	C	\$350.00
Arts and Culture	Cliffondale Arts Center	4654 Butner Rd SW Atlanta, GA 30349	Girls Accessible Restroom Adjacent to Activity Room No. 10	Accessible toilet compartment (stall) is 57.25" (1454 mm) by 72" (1829 mm) wide.	\$604.8.1.1	Rework partitions and/or fixtures to provide a 60" (1524 mm) by 59" (1498 mm) min. accessible toilet compartment for a floor mounted water closet (2010 ADA Fig. 604.8.1.1).	C	\$2,119.74
Arts and Culture	Cliffondale Arts Center	4654 Butner Rd SW Atlanta, GA 30349	Boys Accessible Restroom Adjacent to Activity Room No. 10	Children's use ambulatory accessible compartment (Stall) is 34" (864 mm) wide.	\$604.8.2.1	Reconfigure ambulatory accessible compartment (stall) to provide a 60" (1524 mm) min. depth and a minimum width of 35" and 37" (890 mm - 940 mm) max. (2010 ADA Fig. 604.8.2).	C	\$2,119.74
Arts and Culture	Cliffondale Arts Center	4654 Butner Rd SW Atlanta, GA 30349	Girls Accessible Restroom Adjacent to Activity Room No. 10	Ambulatory accessible compartment (Stall) is 34" (864 mm) by 56.75" wide and does not have a door.	\$604.8.2.1	Reconfigure ambulatory accessible compartment (stall) to provide a 60" (1524 mm) min. depth and a minimum width of 35" and 37" (890 mm - 940 mm) max. (2010 ADA Fig. 604.8.2).	C	\$2,119.74
Arts and Culture	Cliffondale Arts Center	4654 Butner Rd SW Atlanta, GA 30349	Girls Accessible Restroom Adjacent to Activity Room No. 10	Children's use ambulatory accessible compartment stall does not have side wall grab bars.	\$604.8.2.3	Install a 42" (1066 mm) min. long side wall grab bar at 52" (1320 mm) min. from rear wall to centerline of outer flange and mount at 18" and 27" (455 mm - 685 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig. 604.5.1, 604.8.2) (Per 2010 ADA §604.9.6 Advisory Specifications for Water Closets Serving Ages 3 Through 12)	C	\$760.40
Arts and Culture	Cliffondale Arts Center	4654 Butner Rd SW Atlanta, GA 30349	Boys Accessible Restroom Adjacent to Activity Room No. 10	Water closet seat is mounted at 13" (330 mm) above the finished floor to top.	\$604.9	Retrofit water closet seat and mount between 11" and 15" (280 mm - 380 mm) above the finished floor to top of seat. (Per 2010 ADA §604.9.6 Advisory Specifications for Water Closets Serving Ages 3 Through 12) this dimension is acceptable, no remedial work is necessary.	C	\$0.00
Arts and Culture	Cliffondale Arts Center	4654 Butner Rd SW Atlanta, GA 30349	Boys Accessible Restroom Adjacent to Activity Room No. 10	Toilet tissue dispenser is mounted at a non-compliant height above the finished floor.	\$604.9.6	Relocate toilet tissue dispenser to water closet side wall at 7"-9" (177 mm to 228 mm) in front of the water closet to the centerline of the dispenser and 14"-19" (381 mm to 1219 mm) above the finished floor to the dispenser outlet (Per 2010 ADA §604.9.6 Advisory Specifications for Water Closets Serving Ages 3 Through 12)	C	\$131.00

**Fulton County ADA Transition Plan
ARTS AND CULTURE
Appendix 7-10**

Department	Bldg Name	Address	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction	Priority	Cost
Arts and Culture	Cliffondale Arts Center	4654 Butner Rd SW Atlanta, GA 30349	Boys Accessible Restroom Adjacent to Activity Room No. 10	Children's lavatory knee clearance is 21.5" (546 mm) above the finished floor to bottom leading edge of fixture.	\$606.2	Rework sink to provide a 27" (685 mm) min. knee clearance above the finished floor to bottom leading edge of fixture at an 8" (203 mm) min. horizontal projection (2010 ADA Fig. 306.3) Per 2010 ADA Section 606.2 Exception 5 a parallel approach complying with 305 shall be permitted to lavatories and sinks used primarily by children 5 years and younger. No remedial work is necessary.	C	\$0.00
Arts and Culture	Cliffondale Arts Center	4654 Butner Rd SW Atlanta, GA 30349	Girls Accessible Restroom Adjacent to Activity Room No. 10	Children's lavatory knee clearance is 21.5" (546 mm) above the finished floor to bottom leading edge of fixture.	\$606.2	Rework sink to provide a 27" (685 mm) min. knee clearance above the finished floor to bottom leading edge of fixture at an 8" (203 mm) min. horizontal projection (2010 ADA Fig. 306.3) Per 2010 ADA Section 606.2 Exception 5 a parallel approach complying with 305 shall be permitted to lavatories and sinks used primarily by children 5 years and younger. No remedial work is necessary.	C	\$0.00
Arts and Culture	Cliffondale Arts Center	4654 Butner Rd SW Atlanta, GA 30349	Visual Arts Room No. 9	Children's use sink counter does not have the required knee clearance.	\$606.2	Rework sink to provide a 27" (685 mm) min. knee clearance above the finished floor to bottom leading edge of fixture at an 8" (203 mm) min. horizontal projection (2010 ADA Fig. 306.3) Per 2010 ADA Section 606.2 Exception 5 a parallel approach complying with 305 shall be permitted to lavatories and sinks used primarily by children 5 years and younger. No remedial work is necessary.	C	\$0.00
Arts and Culture	Cliffondale Arts Center	4654 Butner Rd SW Atlanta, GA 30349	Visual Arts Room No. 9	Children's use lavatory knee clearance is 23.25" (591 mm) above the finished floor to bottom leading edge of fixture.	\$606.2	Rework sink to provide a 27" (685 mm) min. knee clearance above the finished floor to bottom leading edge of fixture at an 8" (203 mm) min. horizontal projection (2010 ADA Fig. 306.3) Per 2010 ADA Section 606.2 Exception 5 a parallel approach complying with 305 shall be permitted to lavatories and sinks used primarily by children 5 years and younger. No remedial work is necessary.	C	\$0.00
Arts and Culture	Cliffondale Arts Center	4654 Butner Rd SW Atlanta, GA 30349	Boys Accessible Restroom Adjacent to Activity Room No. 10	Lavatory knee clearance is 26" (660 mm) above the finished floor to bottom leading edge of fixture.	\$606.2.2	Rework lavatory to provide the required 27" (685 mm) min. knee clearance above the finished floor to bottom leading edge of fixture at an 8" (203 mm) min. horizontal projection (2010 ADA Fig. 306.3).	C	\$500.00
Arts and Culture	Cliffondale Arts Center	4654 Butner Rd SW Atlanta, GA 30349	Girls Accessible Restroom Adjacent to Activity Room No. 10	Lavatory knee clearance is 26.5" (673 mm) above the finished floor to bottom leading edge of fixture.	\$606.2.2	Rework lavatory to provide the required 27" (685 mm) min. knee clearance above the finished floor to bottom leading edge of fixture at an 8" (203 mm) min. horizontal projection (2010 ADA Fig. 306.3).	C	\$500.00
Arts and Culture	Cliffondale Arts Center	4654 Butner Rd SW Atlanta, GA 30349	Unisex Accessible Restroom on Left	Lavatory is mounted at 34.25" (870 mm) above the finished floor to top of rim.	\$606.3	Relocate lavatory at 34" (863 mm) max. above the finished floor to front end of rim or counter. For a facility that pre-dates the enactment of the ADA this dimension should be considered acceptable per 1990 ADA section 3.2 Dimensional Tolerances and 2010 ADA section 104.1 Construction and Manufacturing Tolerance.	C	\$0.00
Arts and Culture	Cliffondale Arts Center	4654 Butner Rd SW Atlanta, GA 30349	Girls Accessible Restroom Adjacent to Activity Room No. 10	Children's lavatory faucets require pinching and tight grasping to operate.	\$606.4	Replace or retrofit lavatory controls with paddle-operated, push-type or electronically-controlled mechanism.	C	\$200.00
Arts and Culture	Cliffondale Arts Center	4654 Butner Rd SW Atlanta, GA 30349	Unisex Accessible Restroom on Left	Lavatory has partially unwrapped bottom sink pipes.	\$606.5	Cover (insulate) lavatory bottom supply and drain pipes or reconfigure to protect against contact.	C	\$120.12
Arts and Culture	Cliffondale Arts Center	4654 Butner Rd SW Atlanta, GA 30349	Boys Accessible Restroom Adjacent to Activity Room No. 10	Lavatory has unwrapped bottom sink pipes.	\$606.5	Cover (insulate) lavatory bottom supply and drain pipes or reconfigure to protect against contact.	C	\$120.12
Arts and Culture	Cliffondale Arts Center	4654 Butner Rd SW Atlanta, GA 30349	Boys Accessible Restroom Adjacent to Activity Room No. 10	Children's use lavatory has unwrapped bottom sink pipes.	\$606.5	Cover (insulate) lavatory bottom supply and drain pipes or reconfigure to protect against contact.	C	\$120.12
Arts and Culture	Cliffondale Arts Center	4654 Butner Rd SW Atlanta, GA 30349	Girls Accessible Restroom Adjacent to Activity Room No. 10	Lavatory has unwrapped bottom sink pipes.	\$606.5	Cover (insulate) lavatory bottom supply and drain pipes or reconfigure to protect against contact.	C	\$120.12
Arts and Culture	Cliffondale Arts Center	4654 Butner Rd SW Atlanta, GA 30349	Girls Accessible Restroom Adjacent to Activity Room No. 10	Children's lavatory has unwrapped bottom sink pipes.	\$606.5	Cover (insulate) lavatory bottom supply and drain pipes or reconfigure to protect against contact.	C	\$120.12
Arts and Culture	Cliffondale Arts Center	4654 Butner Rd SW Atlanta, GA 30349	Visual Arts Room No. 9	Children's use lavatory has unwrapped bottom sink pipes.	\$606.5	Cover (insulate) lavatory bottom supply and drain pipes or reconfigure to protect against contact.	C	\$120.12
Arts and Culture	Cliffondale Arts Center	4654 Butner Rd SW Atlanta, GA 30349	Boys Accessible Restroom Adjacent to Activity Room No. 10	Sink knob-type faucet requires pinching and tight grasping to operate.	\$804.4	Replace or retrofit sink controls with paddle-operated, push-type or electronically-controlled mechanism.	C	\$200.00
Arts and Culture	Cliffondale Arts Center	4654 Butner Rd SW Atlanta, GA 30349	Visual Arts Room No. 9	Sink has unwrapped bottom pipes.	\$804.4	Cover (insulate) sink bottom supply and drain pipes.	C	\$120.12
Arts and Culture	Cliffondale Arts Center	4654 Butner Rd SW Atlanta, GA 30349	Wheel Pottery Room No. 14	Sink is mounted at 35.5" (902 mm) above the finished floor to top of rim.	\$804.4	Relocate and/or mount sink at 34" (863 mm) max. above the finished floor to top of rim.	C	\$1,891.00
Arts and Culture	Cliffondale Arts Center	4654 Butner Rd SW Atlanta, GA 30349	Wheel Pottery Room No. 14	Sink has unwrapped bottom pipes.	\$804.4	Cover (insulate) sink bottom supply and drain pipes.	C	\$120.12
Arts and Culture	Cliffondale Arts Center	4654 Butner Rd SW Atlanta, GA 30349	Visual Arts Room No. 9	Desk has a non-compliant 26.25" (667 mm) knee clearance.	\$902.2	Provide desk with a corresponding 30" by 48" (762 mm by 1219 mm) clear floor space, 27" (685 mm) min. bottom knee clearance above the finished floor and a 17" (430 mm) horizontal projection.	C	\$372.14
Arts and Culture	Cliffondale Arts Center	4654 Butner Rd SW Atlanta, GA 30349	Wheel Pottery Room No. 14	Children's tables have a 13" (330 mm) knee clearance.	\$902.4.1	Provide seating with a corresponding 30" by 48" (762 mm by 1219 mm) clear floor space, 24" (609 mm) min. bottom knee clearance above the finished floor and a 17" (430 mm) horizontal projection. Per exception §902.4 Dining surfaces and work surfaces that are used primarily by children 5 years and younger shall not be required to comply with 902.4 where a clear floor or ground space complying with 305 positioned for a parallel approach is provided. No remedial work is necessary.	C	\$0.00
Arts and Culture	Cliffondale Arts Center	4654 Butner Rd SW Atlanta, GA 30349	Wheel Pottery Room No. 14	Children's tables and/or work surfaces are mounted at 16" (406 mm) above the finished floor to the top.	\$902.4.2	Provide seating with a corresponding 30" by 48" (762 mm by 1219 mm) clear floor space, 24" (609 mm) min. bottom knee clearance above the finished floor and a 17" (430 mm) horizontal projection. Per exception §902.4 Dining surfaces and work surfaces that are used primarily by children 5 years and younger shall not be required to comply with 902.4 where a clear floor or ground space complying with 305 positioned for a parallel approach is provided. No remedial work is necessary.	C	\$0.00
Arts and Culture	Cliffondale Arts Center	4654 Butner Rd SW Atlanta, GA 30349	Corridor by Visual Arts Room No. 9	Bench back support is mounted at 17" (432 mm) above the seat surface.	\$903.4	As best practice we recommend replacing/reworking bench to provide a bench fixed to a wall or with a back support that is 42" (1065 mm) min. long, that extends from a point 2" (51 mm) max. above the seat surface to a point 18" (455 mm) min. above the seat surface (2010 ADA Fig. 903.4)	C	\$452.12
Arts and Culture	Cliffondale Arts Center	4654 Butner Rd SW Atlanta, GA 30349	Wooden Benches in Front of Main Entrance	Bench does not have armrests or supportive backrest design.	\$903.4	Replace/rework to provide a bench fixed to a wall or with a back support that is 42" (1065 mm) min. long, that extends from a point 2" (51 mm) max. above the seat surface to a point 18" (455 mm) min. above the seat surface (2010 ADA Fig. 903.4)	C	\$452.12
Arts and Culture	Cliffondale Arts Center	4654 Butner Rd SW Atlanta, GA 30349	Wooden Benches in Front of Main Entrance	Bench back support is mounted at 15.75" (400 mm) above the seat surface	\$903.4	Replace/rework to provide a bench fixed to a wall or with a back support that is 42" (1065 mm) min. long, that extends from a point 2" (51 mm) max. above the seat surface to a point 18" (455 mm) min. above the seat surface (2010 ADA Fig. 903.4)	C	\$0.00
Arts and Culture	Cliffondale Arts Center	4654 Butner Rd SW Atlanta, GA 30349	Boys Accessible Restroom Adjacent to Activity Room No. 10	Toilet compartment (stall) door does not provide pull handles on both sides of the door near the latch.	\$604.8.1.2	Provided pull handles on both sides of the door near the latch and center door opening hardware between 34" and 48" (863 mm - 1219 mm) above the finished floor.	D	\$55.00
Arts and Culture	Cliffondale Arts Center	4654 Butner Rd SW Atlanta, GA 30349	Girls Accessible Restroom Adjacent to Activity Room No. 10	Toilet compartment (stall) door does not provide pull handles on both sides of the door near the latch.	\$604.8.1.2	Provided pull handles on both sides of the door near the latch and center door opening hardware between 34" and 48" (863 mm - 1219 mm) above the finished floor.	D	\$55.00
Arts and Culture	Cliffondale Arts Center	4654 Butner Rd SW Atlanta, GA 30349	Boys Accessible Restroom Adjacent to Activity Room No. 10	Accessible compartment (stall) door does not have a self closing mechanism.	\$604.8.2.2	Provide a self closing mechanism on door with an opening force not exceeding 5 lbf.	D	\$291.64
Arts and Culture	Cliffondale Arts Center	4654 Butner Rd SW Atlanta, GA 30349	Girls Accessible Restroom Adjacent to Activity Room No. 10	Accessible compartment (stall) door does not have a self closing mechanism.	\$604.8.2.2	Provide a self closing mechanism on door with an opening force not exceeding 5 lbf.	D	\$291.00
Arts and Culture	Cliffondale Arts Center	4654 Butner Rd SW Atlanta, GA 30349	Girls Accessible Restroom Adjacent to Activity Room No. 10	Ambulatory accessible compartment (stall) door does not provide pull handles on both sides of the door near the latch.	\$604.8.2.2	Provided pull handles on both sides of the door near the latch and center door opening hardware between 34" and 48" (863 mm - 1219 mm) above the finished floor.	D	\$55.00
Arts and Culture	Cliffondale Arts Center	4654 Butner Rd SW Atlanta, GA 30349	Girls Accessible Restroom Adjacent to Activity Room No. 10	Accessible compartment (stall) door does not have a self closing mechanism.	\$604.8.2.2	Provide a self closing mechanism on door with an opening force not exceeding 5 lbf.	D	\$291.64

**Fulton County ADA Transition Plan
ARTS AND CULTURE
Appendix 7-10**

Department	Bldg Name	Address	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction	Priority	Cost
Arts and Culture	Cliffondale Arts Center	4654 Butler Rd SW Atlanta, GA 30349	Boys Accessible Restroom Adjacent to Activity Room No. 10	Toilet tissue dispenser is mounted 7" (178 mm) over the side wall grab bar.	\$609.3	Relocate toilet tissue dispenser to provide a clear space between the side wall grab bar and projecting objects above of 12" (305 mm) min. (2010 ADA Fig. 609.3). Per 36.304(d)(2)(i) Safe harbor. Elements that comply with the corresponding technical requirements and scoping requirements for those elements in the 1991 Standards do not need to be modified in order to comply with the requirements set forth in the 2010 Standards.	D	\$131.00
Arts and Culture	Cliffondale Arts Center	4654 Butler Rd SW Atlanta, GA 30349	Girls Accessible Restroom Adjacent to Activity Room No. 10	Toilet tissue dispenser is mounted 4" (102 mm) over the side wall grab bar.	\$609.3	Relocate toilet tissue dispenser to water closet side wall at 7"-9" (177 mm to 228 mm) in front of the water closet to the centerline of the dispenser and 15'-48" (381 mm to 1219 mm) above the finished floor to the dispenser outlet (2010 ADA Fig. 604.7). If mounted below the side wall grab bar there shall be a clearance of 1.5" (38 mm) below the grab bar. If mounted above the side wall grab bar there shall be a clearance of 12" (305 mm) min. above the grab bar (2010 ADA Fig 609.3)	D	\$131.00
Arts and Culture	Cliffondale Arts Center	4654 Butler Rd SW Atlanta, GA 30349	Girls Accessible Restroom Adjacent to Activity Room No. 10	Toilet seat cover dispenser is mounted 6" (152 mm) over the side wall grab bar.	\$609.3	Relocate toilet seat cover dispenser and mount 15'-48" (381 mm to 1219 mm) above the finished floor to the dispenser outlet (2010 ADA Fig. 604.7). If mounted below the side wall grab bar there shall be a clearance of 1.5" (38 mm) below the grab bar. If mounted above the side wall grab bar there shall be a clearance of 12" (305 mm) min. above the grab bar (2010 ADA Fig 609.3)	D	\$131.00
Arts and Culture	Hammond House	503 Peoples St SW Atlanta, GA 30310	Path of Travel Leading to Second Floor	The only means of access to the second floor is by stairs.	\$206.2.3 \$405.7.3	Per 2010 ADA 206.2.3 exception 7, an accessible route is not required to stories located above or below the accessible story if it will alter historic value. Providing access to the floors above grade implies utilizing an ADA lift (verify if this is allowed by local building code and/or regulatory requirements). This implies installing a mechanical means of access, that would potentially threaten or destroy the historic significance of the historic building. As such alternative programmatic and/or policy and procedure methods can be utilized (i.e. video presentations with assistive listening devices as a means of the historical significance of the building).	B	\$8,500.00
Arts and Culture	Hammond House	503 Peoples St SW Atlanta, GA 30310	Secondary Bathroom	This restroom is not accessible and there is no sign indicating location of accessible restroom.	\$216.6	Post sign indicating location of accessible restroom on first floor.	B	\$149.95
Arts and Culture	Hammond House	503 Peoples St SW Atlanta, GA 30310	Accessible Entrance From Accessible Parking Space	No sign indicating accessible entrance has been provided.	\$216.6	Per 2010 ADA §216.6 post directional signage indicating the location of the accessible entrance. Directional signs that indicate the location of the nearest accessible entrance shall comply with 703.5.	B	\$149.95
Arts and Culture	Hammond House	503 Peoples St SW Atlanta, GA 30310	Path of Travel From Public Rights of Way to Main Entrance	No sign posted indicating accessible entrance nor accessible parking spaces.	\$216.6	Per 2010 ADA §216.6 post directional signage indicating the location of the accessible entrance and accessible parking space through the back of the building on Culberson St SW. Directional signs that indicate the location of the nearest accessible entrance shall comply with 703.5.	B	\$149.95
Arts and Culture	Hammond House	503 Peoples St SW Atlanta, GA 30310	Accessible Entrance (Rear Entrance)	No sign posted indicated accessible entrance.	\$216.6	Provide signage at accessible entrance displaying the International symbol of accessibility.	B	\$149.95
Arts and Culture	Hammond House	503 Peoples St SW Atlanta, GA 30310	Main Entrance	This entrance is inaccessible and does not have signage posted indicating the location of an accessible entrance.	\$216.6	Per 2010 ADA §216.6 post directional signage indicating the location of the accessible entrance and accessible parking space through the back of the building on Culberson St SW. Directional signs that indicate the location of the nearest accessible entrance shall comply with 703.5.	B	\$0.00
Arts and Culture	Hammond House	503 Peoples St SW Atlanta, GA 30310	Public Right of Way Leading to Accessible Entrance (Rear Entrance)	The surface of the accessible route (pavers) is broken, loose or unstable and has multiple vertical changes in level.	\$302.1	Rework or repave accessible route to provide a surface that is stable, firm and slip resistant, with a cross slope not exceeding 2% and running slopes not exceeding 5%. Fulton County is not responsible for items on Public Rights-of-Way.	B	\$0.00
Arts and Culture	Hammond House	503 Peoples St SW Atlanta, GA 30310	Main Entrance	The only means of access to the Main Entrance is by stairs.	\$403.3 \$216.6	The accessible entrance is located in the back of the facility.	B	\$149.95
Arts and Culture	Hammond House	503 Peoples St SW Atlanta, GA 30310	Exhibit Room	Doorway opening has a clear width of 30" (762 mm).	\$404.2.3	Remove door or rework doorway (partition) to provide the required 32" (812 mm) min. clear door or entryway width (2010 ADA Fig. 404.2.3). Alternative is to remove the door.	B	\$1,500.00
Arts and Culture	Hammond House	503 Peoples St SW Atlanta, GA 30310	Accessible Entrance (Rear Entrance)	Maneuvering clearance on the pull side of the door is 12.5" (318 mm).	\$404.2.4	Install an automatic door opener or rework door side partition to provide the required 18" (457 mm) min. maneuvering clearance on the pull side of the door beyond the latch side and 60" (1524 mm) min. deep clear floor leveled area with slopes not exceeding 1:48 (2010 ADA Fig. 404.2.4.1). An alternative is to install an automatic door opener.	B	\$1,600.00
Arts and Culture	Hammond House	503 Peoples St SW Atlanta, GA 30310	Unisex Accessible Restroom	Non-compliant knob-type door hardware, requiring grasping and turning of the wrist to operate.	\$404.2.7	Replace or retrofit with system operable with one hand, not requiring pinching, tight grasping or turning of the wrist to operate.	B	\$291.64
Arts and Culture	Hammond House	503 Peoples St SW Atlanta, GA 30310	Lift at Rear Entrance	Ramp leading to lift has a non-compliant surface slope of 10.4 %.	\$405.2	We recommend reworking ramp to provide a running slope not exceeding 8.33%. Per 2010 ADA Table 405.2 Maximum Slope and Rise for Existing Sites, Buildings and Facilities slopes between 10% (1:10) and 12.5% (1:8) are allowed on ramps with a maximum rise of 3" (75 mm).	B	\$0.00
Arts and Culture	Hammond House	503 Peoples St SW Atlanta, GA 30310	Accessible Parking Space	Accessible parking space is not clearly outlined or needs re-striping.	\$502.3.1	Restripe to provide an accessible parking space 96" (2438 mm) min. wide and a 60" (15258 mm) min. wide access aisle with a surface slope not exceeding 2% in all directions (2010 ADA Figs. 502.3).	B	\$0.00
Arts and Culture	Hammond House	503 Peoples St SW Atlanta, GA 30310	Accessible Parking Space	There is no access aisle.	\$502.3.1	Restripe area to provide an accessible parking space that has a 60" (1524 mm) min. wide access aisle with a surface slope not exceeding 2% in all directions (2010 ADA Fig. 502.3).	B	\$0.00
Arts and Culture	Hammond House	503 Peoples St SW Atlanta, GA 30310	Accessible Parking Space	There is no fine posted on signage	\$502.6	Install signage indicating accessible parking that displays the international symbol of accessibility and mount at 60"(1524 mm) min. above the finished floor and indicates fine.	B	\$228.00
Arts and Culture	Hammond House	503 Peoples St SW Atlanta, GA 30310	Accessible Parking Space	Accessible parking space has a 7.2 % non-compliant running slope.	\$504.2	Rework or repave to provide an accessible parking space with surface slope not exceeding 2% in all directions all the way up to the accessible entrance.	B	\$1,897.39
Arts and Culture	Hammond House	503 Peoples St SW Atlanta, GA 30310	Secondary Bathroom	Permanent room identifying signage does not have Braille or raised characters and is mounted on the door leaf.	\$703.4.1	Provide signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. from the baseline of the highest tactile character (2010 ADA Fig. 703.4.1).	B	\$0.00

**Fulton County ADA Transition Plan
ARTS AND CULTURE
Appendix 7-10**

Department	Bldg Name	Address	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction	Priority	Cost
Arts and Culture	Hammond House	503 Peoples St SW Atlanta, GA 30310	Unisex Accessible Restroom	Permanent room identifying signage is mounted on the door leaf.	§703.4.1	Provide signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. from the baseline of the highest tactile character (2010 ADA Fig. 703.4.1).	B	\$55.00
Arts and Culture	Hammond House	503 Peoples St SW Atlanta, GA 30310	Secondary Bathroom	Accessible route leading to bathroom has a 0.75" (19 mm) vertical change in level.	§303.2	Rework threshold to provide a 0.25" (6 mm) max. vertical change of level, with a slope no greater than 1:2 (2010 ADA Fig. 303.2).	C	\$137.43
Arts and Culture	Hammond House	503 Peoples St SW Atlanta, GA 30310	Unisex Accessible Restroom	Paper towel dispenser is mounted beyond required reach allowed for approach provided and is mounted at 56" (1422 mm) above the finished floor to paper.	§308.2.1	Lower or install paper towel dispenser at 48" (1219 mm) max. above the finished floor to paper for forward approach to object (2010 ADA Fig. 308.3.1).	C	\$131.00
Arts and Culture	Hammond House	503 Peoples St SW Atlanta, GA 30310	Resource Center	Cabinet encroaches over maneuvering clearance on the pull side of the door.	§404.2.4	Relocate encroaching item to provide the required 18" (457 mm) min. maneuvering clearance on the pull side of the door (2010 ADA Fig. 404.2.4.1).	C	\$131.00
Arts and Culture	Hammond House	503 Peoples St SW Atlanta, GA 30310	Resource Center	Non-compliant knob-type door hardware, requiring grasping and turning of the wrist to operate.	§404.2.7	Replace or retrofit with system operable with one hand, not requiring pinching, tight grasping or turning of the wrist to operate.	C	\$291.64
Arts and Culture	Hammond House	503 Peoples St SW Atlanta, GA 30310	Unisex Accessible Restroom	Water closet is centered at 18.5" (470 mm) from side wall.	§604.2	Relocate water closet and center between 16" and 18" (406 mm - 457 mm) from side wall (2010 ADA Fig. 604.2).	C	\$1,029.03
Arts and Culture	Hammond House	503 Peoples St SW Atlanta, GA 30310	Unisex Accessible Restroom	Water closet side wall grab bar is mounted at 48" (1219 mm) perpendicular from rear wall to centerline of its outer flange.	§604.5.1	Install a 42" (1066 mm) min. long side wall grab bar at 54" (1371 mm) min. perpendicular from rear wall to centerline of outer flange and mount at 33" - 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (ADAAG Fig. 604.5.1)	C	\$150.00
Arts and Culture	Hammond House	503 Peoples St SW Atlanta, GA 30310	Unisex Accessible Restroom	Lavatory knee clearance is 25.5" (648 mm) above the finished floor to bottom leading edge of fixture.	§606.2.2	Rework or replace lavatory to provide the required 27" (685 mm) min. knee clearance above the finished floor to bottom leading edge of fixture at an 8" (203 mm) min. horizontal projection (2010 ADA Fig. 306.3).	C	\$500.00
Arts and Culture	Hammond House	503 Peoples St SW Atlanta, GA 30310	Unisex Accessible Restroom	Lavatory knob-type faucet requires pinching and tight grasping to operate.	§606.4	Replace or retrofit lavatory controls with paddle-operated, push-type or electronically-controlled mechanism.	C	\$228.00
Arts and Culture	Hammond House	503 Peoples St SW Atlanta, GA 30310	Resource Center	Permanent room identifying signage does not have Braille or raised characters and is mounted on the door leaf.	§703.4.1	Provide signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. from the baseline of the highest tactile character (2010 ADA Fig. 703.4.1).	C	\$149.95
Arts and Culture	Hammond House	503 Peoples St SW Atlanta, GA 30310	Resource Center	Tables have a non-compliant 25.5" (648 mm) knee clearance.	§902.2	Provide seating with a corresponding 30" by 48" (762 mm by 1219 mm) clear floor space, 27" (685 mm) min. bottom knee clearance above the finished floor and a 17" (430 mm) horizontal projection.	C	\$372.14
Arts and Culture	Hammond House	503 Peoples St SW Atlanta, GA 30310	Reception Area	Reception counter is mounted at 37.75" (959 mm) above the finished floor.	§904.4.1	Provide an alternative counter or rework reception counter to provide a portion that is 36" (914 mm) min. long, mounted at 36" (914 mm) max. above the finished floor to the top (For a parallel approach to counter). An alternative writing surface (clipboard) has been provided.	C	\$0.00
Arts and Culture	Southwest Arts Center Instructional Bldg	915 New Hope Road Atlanta, GA 30331	Women's Accessible Restroom	Maneuvering clearance on the pull side of the door is 17.5" (444 mm).	§404.2.4	Install an automatic door opener or rework door side partition to provide the required 18" (457 mm) min. maneuvering clearance on the pull side of the door beyond the latch side and 60" (1524 mm) min. deep clear floor leveled area with slopes not exceeding 1:48 (2010 ADA Fig. 404.2.4.1).	B	\$1,500.00
Arts and Culture	Southwest Arts Center Instructional Bldg	915 New Hope Road Atlanta, GA 30331	Men's Accessible Restroom	Maneuvering clearance on the push side is 41.5" (1054 mm) wide for a parallel hinge approach to door due to a vending machine	§404.2.4	Relocate vending machine to provide the required 22" (560 mm) min. maneuvering clearance on the push side of the door, for a parallel hinge approach and 42" (1065 mm) min. deep clear floor area (2010 ADA Fig. 404.2.4.1)	B	\$0.00
Arts and Culture	Southwest Arts Center Instructional Bldg	915 New Hope Road Atlanta, GA 30331	Men's Accessible Restroom	Door has a non-compliant opening force of 8 lbf.	§404.2.9	Adjust or replace door closer, maintain door hinges to provide an opening force not to exceed 5 lbf.	B	\$131.00
Arts and Culture	Southwest Arts Center Instructional Bldg	915 New Hope Road Atlanta, GA 30331	Graphic Design Room No. 134	Door has a non-compliant opening force of 9 lbf.	§404.2.9	Adjust or replace door closer, maintain door hinges to provide an opening force not to exceed 5 lbf.	B	\$131.00
Arts and Culture	Southwest Arts Center Instructional Bldg	915 New Hope Road Atlanta, GA 30331	Accessible Ramp on SW Corner of Building	Ramp has a non-compliant surface slope of up to 10.8 %.	§405.2	Rework ramp to provide a running slope not exceeding 8.33%.	B	\$7,177.50
Arts and Culture	Southwest Arts Center Instructional Bldg	915 New Hope Road Atlanta, GA 30331	Four Accessible Parking Spaces on NE Corner of Building	Second accessible parking space (from left to right) has a 2.4 % non-compliant surface slope.	§502.4	Rework or repave to provide an accessible parking space with surface slope not exceeding 2% in all directions.	B	\$1,897.39
Arts and Culture	Southwest Arts Center Instructional Bldg	915 New Hope Road Atlanta, GA 30331	Four Accessible Parking Spaces on NE Corner of Building	First accessible parking space (from left to right) has a 3.2 % non-compliant surface slope.	§502.4	Rework or repave to provide an accessible parking space with surface slope not exceeding 2% in all directions.	B	\$1,897.39
Arts and Culture	Southwest Arts Center Instructional Bldg	915 New Hope Road Atlanta, GA 30331	Four Accessible Parking Spaces on NE Corner of Building	First access aisle (from left to right) has a 2.4 % non-compliant surface slope.	§502.4	Rework or repave to provide an access aisle with surface slope not exceeding 2% in all directions.	B	\$0.00
Arts and Culture	Southwest Arts Center Instructional Bldg	915 New Hope Road Atlanta, GA 30331	Four Accessible Parking Spaces on NE Corner of Building	Second access aisle (from left to right) has a 2.7 % non-compliant surface slope.	§502.4	Rework or repave to provide an access aisle with surface slope not exceeding 2% in all directions.	B	\$0.00
Arts and Culture	Southwest Arts Center Instructional Bldg	915 New Hope Road Atlanta, GA 30331	Four Accessible Parking Spaces on NE Corner of Building	Fourth accessible parking space (from left to right) has a 2.7 % non-compliant surface slope.	§502.4	Rework or repave to provide an accessible parking space with surface slope not exceeding 2% in all directions.	B	\$1,897.39
Arts and Culture	Southwest Arts Center Instructional Bldg	915 New Hope Road Atlanta, GA 30331	Graphic Design Room No. 134	Computers do not appear to have accessible software.	§508	Title II of the ADA requires that programs, services and activities offered by public agencies be accessible to persons with disabilities. Section 508 of the Rehabilitation Act of 1973 provides guidelines for developing, procuring, maintaining, or using electronic and information technology. Per Section 508 ensure computer provides accessible hardware/software	B	\$1,095.00
Arts and Culture	Southwest Arts Center Instructional Bldg	915 New Hope Road Atlanta, GA 30331	Drama Rehearsal Room No. 136A	Permanent room identifying signage is mounted at 61.25" (1556 mm) to the baseline of the highest tactile character. (sign is at 60.5" (1536 mm) to centerline)	§703.4.1	Provide signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. to the baseline of the highest tactile character (2010 ADA Fig. 703.4.1).	B	\$55.00
Arts and Culture	Southwest Arts Center Instructional Bldg	915 New Hope Road Atlanta, GA 30331	Women's Accessible Restroom	Permanent room identifying signage is mounted on the door leaf.	§703.4.1	Provide signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. from the baseline of the highest tactile character (2010 ADA Fig. 703.4.1).	B	\$55.00
Arts and Culture	Southwest Arts Center Instructional Bldg	915 New Hope Road Atlanta, GA 30331	Music Room No. 115A	Permanent room identifying signage is mounted at 61.5" (1562 mm) to the baseline of the highest tactile character. sign is at 60.5" (1536 mm) to centerline)	§703.4.1	Provide signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. to the baseline of the highest tactile character (2010 ADA Fig. 703.4.1).	B	\$55.00
Arts and Culture	Southwest Arts Center Instructional Bldg	915 New Hope Road Atlanta, GA 30331	Practice Room A No. 113	Permanent room identifying signage is mounted at 61" (1549 mm) to the baseline of the highest tactile character.	§703.4.1	Provide signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. to the baseline of the highest tactile character (2010 ADA Fig. 703.4.1). Per 36.304(d)(2)(i) Safe harbor. Elements that comply with the corresponding technical requirements and scoping requirements for those elements in the 1991 Standards do not need to be modified in order to comply with the requirements set forth in the 2010 Standards.	B	\$0.00

**Fulton County ADA Transition Plan
ARTS AND CULTURE
Appendix 7-10**

Department	Bldg Name	Address	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction	Priority	Cost
Arts and Culture	Southwest Arts Center Instructional Bldg	915 New Hope Road Atlanta, GA 30331	Practice Room B No. 112	Permanent room identifying signage is mounted at 61" (1549 mm) to the baseline of the highest tactile character.	\$703.4.1	Provide signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. to the baseline of the highest tactile character (2010 ADA Fig. 703.4.1). Per 36.304(d)(2)(j) Safe harbor. Elements that comply with the corresponding technical requirements and scoping requirements for those elements in the 1991 Standards do not need to be modified in order to comply with the requirements set forth in the 2010 Standards.	B	\$0.00
Arts and Culture	Southwest Arts Center Instructional Bldg	915 New Hope Road Atlanta, GA 30331	Practice Room C No. 116	Permanent room identifying signage is mounted at 61" (1549 mm) to the baseline of the highest tactile character.	\$703.4.1	Provide signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. to the baseline of the highest tactile character (2010 ADA Fig. 703.4.1). Per 36.304(d)(2)(j) Safe harbor. Elements that comply with the corresponding technical requirements and scoping requirements for those elements in the 1991 Standards do not need to be modified in order to comply with the requirements set forth in the 2010 Standards.	B	\$0.00
Arts and Culture	Southwest Arts Center Instructional Bldg	915 New Hope Road Atlanta, GA 30331	Practice Room D No. 117	Permanent room identifying signage is mounted at 61" (1549 mm) to the baseline of the highest tactile character.	\$703.4.1	Provide signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. to the baseline of the highest tactile character (2010 ADA Fig. 703.4.1). Per 36.304(d)(2)(j) Safe harbor. Elements that comply with the corresponding technical requirements and scoping requirements for those elements in the 1991 Standards do not need to be modified in order to comply with the requirements set forth in the 2010 Standards.	B	\$0.00
Arts and Culture	Southwest Arts Center Instructional Bldg	915 New Hope Road Atlanta, GA 30331	Practice Room E No. 118	Permanent room identifying signage is mounted at 61" (1549 mm) to the baseline of the highest tactile character.	\$703.4.1	Provide signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. to the baseline of the highest tactile character (2010 ADA Fig. 703.4.1). Per 36.304(d)(2)(j) Safe harbor. Elements that comply with the corresponding technical requirements and scoping requirements for those elements in the 1991 Standards do not need to be modified in order to comply with the requirements set forth in the 2010 Standards.	B	\$0.00
Arts and Culture	Southwest Arts Center Instructional Bldg	915 New Hope Road Atlanta, GA 30331	Graphic Design Room No. 134	Permanent room identifying signage is mounted at 61.25" (1556 mm) to the baseline of the highest tactile character.	\$703.4.1	Provide signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. to the baseline of the highest tactile character (2010 ADA Fig. 703.4.1). Per 36.304(d)(2)(j) Safe harbor. Elements that comply with the corresponding technical requirements and scoping requirements for those elements in the 1991 Standards do not need to be modified in order to comply with the requirements set forth in the 2010 Standards.	B	\$0.00
Arts and Culture	Southwest Arts Center Instructional Bldg	915 New Hope Road Atlanta, GA 30331	Visual Arts Classroom 1 No. 130A	Permanent room identifying signage is mounted at 61.25" (1556 mm) to the baseline of the highest tactile character. Sign is at 60.5" (1536 mm) to centerline	\$703.4.1	Provide signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. to the baseline of the highest tactile character (2010 ADA Fig. 703.4.1).	B	\$55.00
Arts and Culture	Southwest Arts Center Instructional Bldg	915 New Hope Road Atlanta, GA 30331	Visual Arts Classroom 2 No. 126A	Permanent room identifying signage is mounted at 61.25" (1556 mm) to the baseline of the highest tactile character. Sign is at 60.5" (1536 mm) to centerline	\$703.4.1	Provide signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. to the baseline of the highest tactile character (2010 ADA Fig. 703.4.1).	B	\$55.00
Arts and Culture	Southwest Arts Center Instructional Bldg	915 New Hope Road Atlanta, GA 30331	Dance Studio 1 No. 122A	Permanent room identifying signage is mounted at 61.25" (1556 mm) to the baseline of the highest tactile character. Sign is at 60.5" (1536 mm) to centerline	\$703.4.1	Provide signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. to the baseline of the highest tactile character (2010 ADA Fig. 703.4.1).	B	\$55.00
Arts and Culture	Southwest Arts Center Instructional Bldg	915 New Hope Road Atlanta, GA 30331	Women's Accessible Restroom	Paper towel dispenser protrudes into walkway, projecting 11" (279 mm) from back wall, and is mounted at 38.25" (972 mm) above the finished floor to its bottom leading edge.	\$307.2r	Relocate or recess paper towel dispenser so that it does not project more than 4" (101 mm) from back wall to outer leading edge (2010 ADA Fig. 307.2).	C	\$131.00
Arts and Culture	Southwest Arts Center Instructional Bldg	915 New Hope Road Atlanta, GA 30331	Men's Accessible Restroom	Paper towel dispenser protrudes into walkway, projecting 11" (279 mm) from back wall, and is mounted at 38.25" (972 mm) above the finished floor to its bottom leading edge.	\$307.2r	Relocate or recess paper towel dispenser so that it does not project more than 4" (101 mm) from back wall to outer leading edge (2010 ADA Fig. 307.2).	C	\$131.00
Arts and Culture	Southwest Arts Center Instructional Bldg	915 New Hope Road Atlanta, GA 30331	Drama Rehearsal Room No. 136A	Thermostat is mounted beyond required reach allowed for approach provided and is mounted at 59.5" (1511 mm) above the finished floor to the centerline of the highest operable part.	\$308.2.1	Lower or install thermostat at 48" (1219 mm) max. above the finished floor above the finished floor to the centerline of the highest operable part (2010 ADA Fig. 308.2.1).	C	\$378.00
Arts and Culture	Southwest Arts Center Instructional Bldg	915 New Hope Road Atlanta, GA 30331	Corridor Leading to Restrooms by Lobby	Brochure rack is mounted at 51" (1295 mm) above the finished floor to highest shelf.	\$308.2.1	Lower or install brochure rack at 48" (1219 mm) max. above the finished floor to highest shelf (2010 ADA Fig. 308.2.1). Per 36.304(d)(2)(j) Safe harbor. Elements that comply with the corresponding technical requirements and scoping requirements for those elements in the 1991 Standards do not need to be modified in order to comply with the requirements set forth in the 2010 Standards.	C	\$0.00
Arts and Culture	Southwest Arts Center Instructional Bldg	915 New Hope Road Atlanta, GA 30331	Corridor Leading to Restrooms by Lobby	Clothes rod is mounted beyond required reach allowed for approach provided and is mounted at 59" (1499 mm) above the finished floor.	\$308.2.1	Lower or install accessible clothes rod at 48" (1219 mm) max. above the finished floor for forward approach to object (2010 ADA Fig. 308.2.1).	C	\$0.00
Arts and Culture	Southwest Arts Center Instructional Bldg	915 New Hope Road Atlanta, GA 30331	Corridor Leading to Restrooms by Lobby	Shelf is mounted beyond required reach allowed for approach provided and is mounted at 61.25" (1556 mm) above the finished floor.	\$308.2.1	Lower or install shelf at 48" (1219 mm) max. above the finished floor for forward approach to object (2010 ADA Fig. 308.2.1).	C	\$372.14
Arts and Culture	Southwest Arts Center Instructional Bldg	915 New Hope Road Atlanta, GA 30331	Women's Accessible Restroom	Thermostat is mounted beyond required reach allowed for approach provided and is mounted at 58.5" (1486 mm) above the finished floor to the centerline of the highest operable part.	\$308.2.1	Lower or install thermostat at 48" (1219 mm) max. above the finished floor to the centerline of the highest operable part (2010 ADA Fig. 308.2.1).	C	\$378.00
Arts and Culture	Southwest Arts Center Instructional Bldg	915 New Hope Road Atlanta, GA 30331	Men's Accessible Restroom	Baby changing station pull handle is mounted at 34.5" (876 mm) above the finished floor.	\$308.2.1	Relocate the baby changing station to be on an accessible path and to have a pull down handle no higher than 48 inches and a surface height at or below 34 inches with at least 27 inches high knee clearance when open.	C	\$131.00
Arts and Culture	Southwest Arts Center Instructional Bldg	915 New Hope Road Atlanta, GA 30331	Music Room No. 115A	Light switch is mounted at 50" (1270 mm) above the finished floor to the highest operable part.	\$308.2.1	Install light switch at 48" (1219 mm) max. above the finished floor to the highest operable part for a forward approach to object (2010 ADA Fig. 308.2.1). Per 36.304(d)(2)(j) Safe harbor. Elements that comply with the corresponding technical requirements and scoping requirements for those elements in the 1991 Standards do not need to be modified in order to comply with the requirements set forth in the 2010 Standards.	C	\$0.00
Arts and Culture	Southwest Arts Center Instructional Bldg	915 New Hope Road Atlanta, GA 30331	Graphic Design Room No. 134	Thermostat is mounted beyond required reach allowed for approach provided and is mounted at 59.5" (1511 mm) above the finished floor to the centerline of the highest operable part.	\$308.2.1	Lower or install thermostat at 48" (1219 mm) max. above the finished floor to the centerline of the highest operable part (2010 ADA Fig. 308.2.1).	C	\$378.00
Arts and Culture	Southwest Arts Center Instructional Bldg	915 New Hope Road Atlanta, GA 30331	Visual Arts Classroom 1 No. 130A	Light switch is mounted at 49.5" (1257 mm) above the finished floor to the highest operable part.	\$308.2.1	Install light switch at 48" (1219 mm) max. above the finished floor to the highest operable part for a forward approach to object (2010 ADA Fig. 308.2.1). Per 36.304(d)(2)(j) Safe harbor. Elements that comply with the corresponding technical requirements and scoping requirements for those elements in the 1991 Standards do not need to be modified in order to comply with the requirements set forth in the 2010 Standards.	C	\$0.00
Arts and Culture	Southwest Arts Center Instructional Bldg	915 New Hope Road Atlanta, GA 30331	Visual Arts Classroom 1 No. 130A	Thermostat is mounted beyond required reach allowed for approach provided and is mounted at 60" (1524 mm) above the finished floor to the highest operable part.	\$308.2.1	Lower or install thermostat at 48" (1219 mm) max. above the finished floor to the highest operable part (2010 ADA Fig. 308.2.1).	C	\$378.00

**Fulton County ADA Transition Plan
ARTS AND CULTURE
Appendix 7-10**

Department	Bldg Name	Address	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction	Priority	Cost
Arts and Culture	Southwest Arts Center Instructional Bldg	915 New Hope Road Atlanta, GA 30331	Visual Arts Classroom 2 No. 126A	Light switch is mounted at 50.5" (1283 mm) above the finished floor to the highest operable part.	\$308.2.1	Install light switch at 48" (1219 mm) max. above the finished floor to the highest operable part for a forward approach to object (2010 ADA Fig. 308.2.1). <i>Per 36.304(d)(2)(i) Safe harbor. Elements that comply with the corresponding technical requirements and scoping requirements for those elements in the 1991</i>	C	\$0.00
Arts and Culture	Southwest Arts Center Instructional Bldg	915 New Hope Road Atlanta, GA 30331	Visual Arts Classroom 2 No. 126A	Paper towel dispenser is mounted beyond required reach allowed for approach provided and is mounted at 52.75" (1340 mm) above the finished floor to paper.	\$308.2.1	Lower or install paper towel dispenser at 48" (1219 mm) max. above the finished floor to paper for forward approach to object (2010 ADA Fig. 308.3.1).	C	\$131.00
Arts and Culture	Southwest Arts Center Instructional Bldg	915 New Hope Road Atlanta, GA 30331	Visual Arts Classroom 1 No. 130A	TV provided does not have the closed caption feature turned on.	\$36.303(e)	Implement a policy to have the closed caption feature on during business hours.	C	\$0.00
Arts and Culture	Southwest Arts Center Instructional Bldg	915 New Hope Road Atlanta, GA 30331	Corridor Leading to Restrooms by Lobby	Maneuvering clearance on the push side of the men's restroom is 41.5" (1054 mm) wide for a parallel hinge approach to door due to a vending machine	\$404.2.4	Relocate vending machine to provide the required 22" (560 mm) min. maneuvering clearance on the push side of the door, for a parallel hinge approach and 42" (1065 mm) min. deep clear floor area (2010 ADA Fig. 404.2.4.1)	C	\$250.00
Arts and Culture	Southwest Arts Center Instructional Bldg	915 New Hope Road Atlanta, GA 30331	Men's Accessible Restroom	Maneuvering clearance on the pull side of the door is 17" (432 mm).	\$404.2.4	Install an automatic door opener to comply with the required 18" (457 mm) min. maneuvering clearance on the pull side of the door beyond the latch side and 60" (1524 mm) min. deep clear floor leveled area with slopes not exceeding 1:48 (2010 ADA Fig. 404.2.4.1).	C	\$1,500.00
Arts and Culture	Southwest Arts Center Instructional Bldg	915 New Hope Road Atlanta, GA 30331	Visual Arts Classroom 2 No. 126A	Equipment encroaches over maneuvering clearance on the pull side of the door.	\$404.2.4	Relocate equipment to provide the required 18" (457 mm) min. maneuvering clearance on the pull side of the door beyond the latch side and 60" (1524 mm) min. deep clear floor leveled area (2010 ADA Fig. 404.2.4.1).	C	\$55.00
Arts and Culture	Southwest Arts Center Instructional Bldg	915 New Hope Road Atlanta, GA 30331	Corridor by Visual Arts Classroom	Wall/post mounted drinking fountain has a 26.25" (667 mm) knee clearance.	\$602.1	Relocate/rework fountain to provide a 27" (685 mm) min. knee clearance above the finished floor, 30" (762 mm) min. wide and 25" (635 mm) max. deep (2010 ADA Fig. 306.3).	C	\$697.18
Arts and Culture	Southwest Arts Center Instructional Bldg	915 New Hope Road Atlanta, GA 30331	Men's Accessible Restroom	Coat hook is mounted beyond required reach allowed for approach provided and is mounted at 54.25" (1378 mm) above the finished floor.	\$603.4	Lower or install coat hook at 48" (1219 mm) max. above the finished floor for forward approach to object.	C	\$55.00
Arts and Culture	Southwest Arts Center Instructional Bldg	915 New Hope Road Atlanta, GA 30331	Women's Accessible Restroom	Water closet is centered at 21.25" (540 mm) from side wall	\$604.2	Relocate water closet and center between 16" and 18" (406 mm - 457 mm) from side wall (2010 ADA Fig. 604.2).	C	\$1,029.03
Arts and Culture	Southwest Arts Center Instructional Bldg	915 New Hope Road Atlanta, GA 30331	Women's Accessible Restroom	Accessible toilet compartment (stall) door is not mounted in partition or side wall farthest from water closet.	\$604.8.1.2	Install stall door with the opening mounted at 4" max. from the side wall or partition farthest from the water closet.	C	\$898.00
Arts and Culture	Southwest Arts Center Instructional Bldg	915 New Hope Road Atlanta, GA 30331	Men's Accessible Restroom	Accessible toilet compartment (stall) door is located at 21" (533 mm) from the front partition.	\$604.8.2.1	Reconfigure accessible toilet compartment (stall) to provide a self closing door with opening mounted at 4" (101 mm) max. from the side wall or partition farthest from the water closet (For door located in front of partition) (2010 ADA Fig. 604.8.1.1)	C	\$898.00
Arts and Culture	Southwest Arts Center Instructional Bldg	915 New Hope Road Atlanta, GA 30331	Men's Accessible Restroom	Urinal is mounted at 17.5" (444 mm) above the finished floor to top of rim.	\$605.2	Lower urinal and mount at 17" (431 mm) max. above the finished floor to top of rim. (2010 ADA Fig. 605.2)	C	\$1,029.03
Arts and Culture	Southwest Arts Center Instructional Bldg	915 New Hope Road Atlanta, GA 30331	Women's Accessible Restroom	Sink is mounted at 34.25" (870 mm) above the finished floor to the top.	\$606.3.2	Relocate / rework sink and mount at 34" (863 mm) max. above the finished floor to top of counter. <i>For a facility that pre-dates the enactment of the ADA this dimension should be considered acceptable per 1990 ADA section 3.2 Dimensional Tolerances and 2010 ADA section 104.1 Construction and Manufacturing Tolerance.</i>	C	\$0.00
Arts and Culture	Southwest Arts Center Instructional Bldg	915 New Hope Road Atlanta, GA 30331	Women's Accessible Restroom	Toilet tissue dispenser is mounted 6.75" (171 mm) over the side wall grab bar.	\$609.3	Relocate toilet tissue dispenser to provide a clear space between the side wall grab bar and projecting objects above of 12" (305 mm) min. (2010 ADA Fig. 609.3). <i>Per 36.304(d)(2)(i) Safe harbor. Elements that comply with the corresponding technical requirements and scoping requirements for those elements in the 1991 Standards do not need to be modified in order to comply with the requirements set forth in the 2010 Standards.</i>	C	\$0.00
Arts and Culture	Southwest Arts Center Instructional Bldg	915 New Hope Road Atlanta, GA 30331	Men's Accessible Restroom	Toilet tissue dispenser is mounted 9" (229 mm) over the side wall grab bar.	\$609.3	Relocate toilet tissue dispenser to provide a clear space between the side wall grab bar and projecting objects above of 12" (305 mm) min. (2010 ADA Fig. 609.3). <i>Per 36.304(d)(2)(i) Safe harbor. Elements that comply with the corresponding technical requirements and scoping requirements for those elements in the 1991 Standards do not need to be modified in order to comply with the requirements set forth in the 2010 Standards.</i>	C	\$0.00
Arts and Culture	Southwest Arts Center Instructional Bldg	915 New Hope Road Atlanta, GA 30331	Visual Arts Classroom 1 No. 130A	Wall cabinets over the work surface are mounted at 53.5" (1359 mm) above the finished floor to the bottom shelf.	\$804.5	Relocate wall cabinets, above the work surface, and mount at 48" (1219 mm) max. above the finished floor to the bottom shelf. Handles shall be mounted as close to the bottom as possible.	C	\$1,891.00
Arts and Culture	Southwest Arts Center Instructional Bldg	915 New Hope Road Atlanta, GA 30331	Visual Arts Classroom 2 No. 126A	Wall cabinets over the work surface are mounted at 53.5" (1359 mm) above the finished floor to the bottom shelf.	\$804.5	Relocate wall cabinets, above the work surface, and mount at 48" (1219 mm) max. above the finished floor to the bottom shelf. Handles shall be mounted as close to the bottom as possible.	C	\$1,891.00
Arts and Culture	Southwest Arts Center Instructional Bldg	915 New Hope Road Atlanta, GA 30331	Drama Rehearsal Room No. 136A	Tables have a non-compliant 26.5" (673 mm) knee clearance.	\$902.2	Replace with a new table mounted between 28" (710 mm) min. and 34" (865 mm) max. above the finished floor or ground. The table must provide a knee clearance that is at least 27" (685 mm) high, 30" (762 mm) wide and with a horizontal projection that is 17" (432 mm) deep. With it's corresponding 30" by 48" (762 mm by 1219 mm) min. wheelchair clear floor space (2010 ADA Figs. 305.5 (a), 306.2 (a)(b) and 306.3 (a)(b))	C	\$452.12
Arts and Culture	Southwest Arts Center Instructional Bldg	915 New Hope Road Atlanta, GA 30331	Visual Arts Classroom 1 No. 130A	Tables have a non-compliant 26.5" (673 mm) knee clearance.	\$902.2	Replace with a new table mounted between 28" (710 mm) min. and 34" (865 mm) max. above the finished floor or ground. The table must provide a knee clearance that is at least 27" (685 mm) high, 30" (762 mm) wide and with a horizontal projection that is 17" (432 mm) deep. With it's corresponding 30" by 48" (762 mm by 1219 mm) min. wheelchair clear floor space (2010 ADA Figs. 305.5 (a), 306.2 (a)(b) and 306.3 (a)(b))	C	\$372.14
Arts and Culture	Southwest Arts Center Instructional Bldg	915 New Hope Road Atlanta, GA 30331	Visual Arts Classroom 2 No. 126A	Tables have a non-compliant 26.75" (679 mm) knee clearance.	\$902.2	Replace with a new table mounted between 28" (710 mm) min. and 34" (865 mm) max. above the finished floor or ground. The table must provide a knee clearance that is at least 27" (685 mm) high, 30" (762 mm) wide and with a horizontal projection that is 17" (432 mm) deep. With it's corresponding 30" by 48" (762 mm by 1219 mm) min. wheelchair clear floor space (2010 ADA Figs. 305.5 (a), 306.2 (a)(b) and 306.3 (a)(b))	C	\$372.14
Arts and Culture	Southwest Arts Center Instructional Bldg	915 New Hope Road Atlanta, GA 30331	Women's Accessible Restroom	Toilet compartment (stall) door does not provide pull handles on both sides of the door near the latch.	\$604.8.1.2	Provided pull handles on both sides of the door near the latch and center door opening hardware between 34" and 48" (863 mm - 1219 mm) above the finished floor.	D	\$55.00
Arts and Culture	Southwest Arts Center Instructional Bldg	915 New Hope Road Atlanta, GA 30331	Men's Accessible Restroom	Toilet compartment (stall) door does not provide pull handles on both sides of the door near the latch.	\$604.8.1.2	Provided pull handles on both sides of the door near the latch and center door opening hardware between 34" and 48" (863 mm - 1219 mm) above the finished floor.	D	\$55.00
Arts and Culture	Southwest Arts Center Instructional Bldg	915 New Hope Road Atlanta, GA 30331	Women's Accessible Restroom	Accessible compartment (stall) door does not have a self closing mechanism.	\$604.8.2.2	Provide a self closing mechanism on door with an opening force not exceeding 5 lbf.	D	\$291.64
Arts and Culture	Southwest Arts Center Instructional Bldg	915 New Hope Road Atlanta, GA 30331	Men's Accessible Restroom	Accessible compartment (stall) door does not have a self closing mechanism.	\$604.8.2.2	Provide a self closing mechanism on door with an opening force not exceeding 5 lbf.	D	\$291.64

**Fulton County ADA Transition Plan
ARTS AND CULTURE
Appendix 7-10**

Department	Bldg Name	Address	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction	Priority	Cost
Arts and Culture	Southwest Arts Center Theater	915 New Hope Rd Atlanta, GA 30331	Wheelchair Spaces on Left Side of Theater	There is a total of 3 wheelchair spaces provided in theater.	\$221.2.1.1	Seating capacity in theater is 377. reconfigure theater seating area to provide at least (6) wheelchair spaces and companion seats dispersed horizontally and vertically throughout the amphitheater, that provide spectators with choice of seating locations and viewing angles that are substantially equivalent to or better than, the choices of seating locations and viewing angles available to all other spectators that comply with \$221.1.(See 2010 ADA Table 221.2.1.1.Number of Wheelchair Spaces in Assembly Areas)	B	\$1,921.32
Arts and Culture	Southwest Arts Center Theater	915 New Hope Rd Atlanta, GA 30331	Main Entrance	Trash bin encroaches over power door push button clear floor space.	\$305.3	Relocate trash bin to provide a 30" by 48" (762 mm by 1219 mm) min. wheelchair clear floor space at power door push button (2010 ADA Figs. 305.3-305.5).	B	\$291.64
Arts and Culture	Southwest Arts Center Theater	915 New Hope Rd Atlanta, GA 30331	Accessible Route on Left Leading to Stage Area	Accessible route has a non-compliant running slope of 8.4 %.	\$403.3	Rework or repave accessible route to provide a running slope not exceeding 5%.	B	\$0.00
Arts and Culture	Southwest Arts Center Theater	915 New Hope Rd Atlanta, GA 30331	Accessible Route on Left Leading to Stage Area	Accessible route has a non-compliant running slope of 8.5 %.	\$403.3	Rework or repave accessible route to provide a running slope not exceeding 5%.	B	\$0.00
Arts and Culture	Southwest Arts Center Theater	915 New Hope Rd Atlanta, GA 30331	Accessible Route on Left Leading to Stage Area	Accessible route has a non-compliant running slope of 8.4 %.	\$403.3	Rework or repave accessible route to provide a running slope not exceeding 5%.	B	\$0.00
Arts and Culture	Southwest Arts Center Theater	915 New Hope Rd Atlanta, GA 30331	Accessible Route on Left Leading to Stage Area	Accessible route has a non-compliant running slope of 10.7 %.	\$403.3	Rework or repave accessible route to provide a running slope not exceeding 5%.	B	\$0.00
Arts and Culture	Southwest Arts Center Theater	915 New Hope Rd Atlanta, GA 30331	Accessible Route on Left Leading to Stage Area	Accessible route has a non-compliant running slope of 8.7 %.	\$403.3	Rework or repave accessible route to provide a running slope not exceeding 5%.	B	\$0.00
Arts and Culture	Southwest Arts Center Theater	915 New Hope Rd Atlanta, GA 30331	Accessible Route on Left Leading to Stage Area	Accessible route has a non-compliant running slope of 8.6 %.	\$403.3	Rework or repave accessible route to provide a running slope not exceeding 5%.	B	\$0.00
Arts and Culture	Southwest Arts Center Theater	915 New Hope Rd Atlanta, GA 30331	Accessible Route on Left Leading to Stage Area	Accessible route has a non-compliant running slope of 8.6 %.	\$403.3	Rework or repave accessible route to provide a running slope not exceeding 5%.	B	\$0.00
Arts and Culture	Southwest Arts Center Theater	915 New Hope Rd Atlanta, GA 30331	Accessible Route on Left Leading to Stage Area	Accessible route has a non-compliant running slope of 8.9 %.	\$403.3	Rework or repave accessible route to provide a running slope not exceeding 5%.	B	\$0.00
Arts and Culture	Southwest Arts Center Theater	915 New Hope Rd Atlanta, GA 30331	Accessible Route on Right Leading to Stage Area	Accessible route has a non-compliant running slope of 7.9 %.	\$403.3	Rework or repave accessible route to provide a running slope not exceeding 5%.	B	\$0.00
Arts and Culture	Southwest Arts Center Theater	915 New Hope Rd Atlanta, GA 30331	Accessible Route on Right Leading to Stage Area	Accessible route has a non-compliant running slope of 8.8 %.	\$403.3	Rework or repave accessible route to provide a running slope not exceeding 5%.	B	\$0.00
Arts and Culture	Southwest Arts Center Theater	915 New Hope Rd Atlanta, GA 30331	Accessible Route on Right Leading to Stage Area	Accessible route has a non-compliant running slope of 7.0 %.	\$403.3	Rework or repave accessible route to provide a running slope not exceeding 5%.	B	\$0.00
Arts and Culture	Southwest Arts Center Theater	915 New Hope Rd Atlanta, GA 30331	Accessible Route on Right Leading to Stage Area	Accessible route has a non-compliant running slope of 8.6 %.	\$403.3	Rework or repave accessible route to provide a running slope not exceeding 5%.	B	\$0.00
Arts and Culture	Southwest Arts Center Theater	915 New Hope Rd Atlanta, GA 30331	Accessible Route on Right Leading to Stage Area	Accessible route has a non-compliant running slope of 9.0 %.	\$403.3	Rework or repave accessible route to provide a running slope not exceeding 5%.	B	\$0.00
Arts and Culture	Southwest Arts Center Theater	915 New Hope Rd Atlanta, GA 30331	Accessible Route on Right Leading to Stage Area	Accessible route has a non-compliant running slope of 9.9 %.	\$403.3	Rework or repave accessible route to provide a running slope not exceeding 5%.	B	\$0.00
Arts and Culture	Southwest Arts Center Theater	915 New Hope Rd Atlanta, GA 30331	Accessible Route on Right Leading to Stage Area	Accessible route has a non-compliant running slope of 8.8 %.	\$403.3	Rework or repave accessible route to provide a running slope not exceeding 5%.	B	\$0.00
Arts and Culture	Southwest Arts Center Theater	915 New Hope Rd Atlanta, GA 30331	Accessible Route in Front to the Six Accessible Parking Spaces by Main Entrance	Accessible route has a non-compliant cross slope of 2.3 %.	\$403.3	Rework or repave accessible route to provide a cross slope not exceeding 2%.	B	\$450.00
Arts and Culture	Southwest Arts Center Theater	915 New Hope Rd Atlanta, GA 30331	Accessible Route in Front to the Six Accessible Parking Spaces by Main Entrance	Accessible route has a non-compliant cross slope of 3.0 %.	\$403.3	Rework or repave accessible route to provide a cross slope not exceeding 2%.	B	\$450.00
Arts and Culture	Southwest Arts Center Theater	915 New Hope Rd Atlanta, GA 30331	Accessible Route in Front to the Six Accessible Parking Spaces by Main Entrance	Accessible route has a non-compliant cross slope of 2.9 %.	\$403.3	Rework or repave accessible route to provide a cross slope not exceeding 2%.	B	\$450.00
Arts and Culture	Southwest Arts Center Theater	915 New Hope Rd Atlanta, GA 30331	Accessible Route in Front to the Six Accessible Parking Spaces by Main Entrance	Accessible route has a non-compliant cross slope of 2.9 %.	\$403.3	Rework or repave accessible route to provide a cross slope not exceeding 2%.	B	\$450.00
Arts and Culture	Southwest Arts Center Theater	915 New Hope Rd Atlanta, GA 30331	Accessible Route in Front to the Six Accessible Parking Spaces by Main Entrance	Accessible route has a non-compliant cross slope of 2.8 %.	\$403.3	Rework or repave accessible route to provide a cross slope not exceeding 2%.	B	\$450.00
Arts and Culture	Southwest Arts Center Theater	915 New Hope Rd Atlanta, GA 30331	Accessible Route in Front to the Six Accessible Parking Spaces by Main Entrance	Accessible route has a non-compliant cross slope of 3.5 %.	\$403.3	Rework or repave accessible route to provide a cross slope not exceeding 2%.	B	\$450.00
Arts and Culture	Southwest Arts Center Theater	915 New Hope Rd Atlanta, GA 30331	Accessible Route in Front to the Six Accessible Parking Spaces by Main Entrance	Accessible route has a non-compliant cross slope of 2.5 %.	\$403.3	Rework or repave accessible route to provide a cross slope not exceeding 2%.	B	\$450.00
Arts and Culture	Southwest Arts Center Theater	915 New Hope Rd Atlanta, GA 30331	Accessible Route on North Side of Building From Performing Arts Center Leading to Theater	Accessible route has a non-compliant cross slope of 5.0 % that extends 10 ft (3.04 mt).	\$403.3	Rework or repave accessible route to provide a cross slope not exceeding 2%.	B	\$900.00
Arts and Culture	Southwest Arts Center Theater	915 New Hope Rd Atlanta, GA 30331	Accessible Route on North Side of Building From Performing Arts Center Leading to Theater	Accessible route has a non-compliant cross slope of 5 % that extends 10 ft (3.04 mt).	\$403.3	Rework or repave accessible route to provide a cross slope not exceeding 2%.	B	\$900.00
Arts and Culture	Southwest Arts Center Theater	915 New Hope Rd Atlanta, GA 30331	Accessible Route on North Side of Building From Performing Arts Center Leading to Theater	Accessible route has a non-compliant cross slope of 4.2 % that extends 10 ft (3.04 mt).	\$403.3	Rework or repave accessible route to provide a cross slope not exceeding 2%.	B	\$900.00
Arts and Culture	Southwest Arts Center Theater	915 New Hope Rd Atlanta, GA 30331	Men's Dressing Room No. 132	Maneuvering clearance on the pull side of the door is 16" (406 mm).	\$404.2.4	Install an automatic door opener or area to provide the required 18" (457 mm) min. maneuvering clearance on the pull side of the door beyond the latch side and 60" (1524 mm) min. deep clear floor leveled area (2010 ADA Fig. 404.2.4.1).	B	\$1,500.00
Arts and Culture	Southwest Arts Center Theater	915 New Hope Rd Atlanta, GA 30331	Toilet Room No. 137	Furniture encroaches over maneuvering clearance on the pull side of the door.	\$404.2.4	Relocate furniture to provide the required 18" (457 mm) min. maneuvering clearance on the pull side of the door (2010 ADA Fig. 404.2.4.1).	B	\$55.00
Arts and Culture	Southwest Arts Center Theater	915 New Hope Rd Atlanta, GA 30331	Entrance on North Side of Theater	Maneuvering clearance on the pull side of the door has a 5.0% surface slope.	\$404.2.4	Rework door side partition to provide the required 18" (457 mm) min. maneuvering clearance on the pull side of the door beyond the latch side and 60" (1524 mm) min. deep clear floor leveled area with slopes not exceeding 1:48 (2010 ADA Fig. 404.2.4.1).	B	\$900.00
Arts and Culture	Southwest Arts Center Theater	915 New Hope Rd Atlanta, GA 30331	Men's Lounge	Door has a non-compliant opening force of 7 lbf.	\$404.2.9	Adjust or replace door closer, maintain door hinges to provide an opening force not to exceed 5 lbf.	B	\$131.00
Arts and Culture	Southwest Arts Center Theater	915 New Hope Rd Atlanta, GA 30331	Men's Dressing Room No. 132	Door has a non-compliant opening force of 8 lbf.	\$404.2.9	Adjust or replace door closer, maintain door hinges to provide an opening force not to exceed 5 lbf.	B	\$131.00
Arts and Culture	Southwest Arts Center Theater	915 New Hope Rd Atlanta, GA 30331	Toilet Room No. 137	Door has a non-compliant opening force of 8 lbf.	\$404.2.9	Adjust or replace door closer, maintain door hinges to provide an opening force not to exceed 5 lbf.	B	\$131.00

**Fulton County ADA Transition Plan
ARTS AND CULTURE
Appendix 7-10**

Department	Bldg Name	Address	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction	Priority	Cost
Arts and Culture	Southwest Arts Center Theater	915 New Hope Rd Atlanta, GA 30331	Accessible Route on Left Leading to Stage Area	The first segment of ramp leading to stage does not have the required handrails.	\$405.8	Install a hand rail on the wall side of ramp and mount between 34" and 38" (863 mm - 965 mm) above the ramp surface to top of gripping surfaces, extending 12" (304 mm) min. beyond the top and bottom of the ramp segment (2010 ADA Fig. 505.10.1). Per 2010 ADA exception 505.2 in Assembly Areas: Handrails shall not be required on both sides of aisle ramps where a handrails is provided at either side or within the access aisle	B	\$0.00
Arts and Culture	Southwest Arts Center Theater	915 New Hope Rd Atlanta, GA 30331	Accessible Route on Right Leading to Stage Area	The first segment of ramp leading to stage does not have the required handrails.	\$405.8	Install a hand rail on the wall side of ramp and mount between 34" and 38" (863 mm - 965 mm) above the ramp surface to top of gripping surfaces, extending 12" (304 mm) min. beyond the top and bottom of the ramp segment (2010 ADA Fig. 505.10.1). Per 2010 ADA exception 505.2 in Assembly Areas: Handrails shall not be required on both sides of aisle ramps where a handrails is provided at either side or within the access aisle	B	\$0.00
Arts and Culture	Southwest Arts Center Theater	915 New Hope Rd Atlanta, GA 30331	Six Accessible Parking Spaces by Main Entrance	Accessible parking space is not clearly outlined or needs re-striping.	\$502.3.1	Restripe to provide an accessible parking space 96" (2438 mm) min. wide and a 60" (15258 mm) min. wide access aisle with a surface slope not exceeding 2% in all directions (2010 ADA Figs. 502.3).	B	\$0.00
Arts and Culture	Southwest Arts Center Theater	915 New Hope Rd Atlanta, GA 30331	Six Accessible Parking Spaces by Main Entrance	There was a vehicle parked on the second access aisle (from right to left) therefore no measurements were taken.	\$502.4	Rework or repave to provide an access aisle with running slope not exceeding 2% in all directions.	B	\$0.00
Arts and Culture	Southwest Arts Center Theater	915 New Hope Rd Atlanta, GA 30331	Six Accessible Parking Spaces by Main Entrance	First accessible parking space (from right to left) has a non-compliant surface slope of up to 3.8%	\$502.4	Rework or repave to provide an accessible parking space with surface slope not exceeding 2% in all directions.	B	\$1,897.39
Arts and Culture	Southwest Arts Center Theater	915 New Hope Rd Atlanta, GA 30331	Six Accessible Parking Spaces by Main Entrance	First access aisle (from right to left) has a non-compliant surface slope of up to 5.4%	\$502.4	Rework or repave to provide an access aisle with running slope not exceeding 2% in all directions.	B	\$0.00
Arts and Culture	Southwest Arts Center Theater	915 New Hope Rd Atlanta, GA 30331	Six Accessible Parking Spaces by Main Entrance	Third access aisle (from right to left) has a non-compliant surface slope of up to 6.8%	\$502.4	Rework or repave to provide an access aisle with running slope not exceeding 2% in all directions.	B	\$0.00
Arts and Culture	Southwest Arts Center Theater	915 New Hope Rd Atlanta, GA 30331	Six Accessible Parking Spaces by Main Entrance	First accessible parking space (from right to left) does not have signage indicating accessible parking.	\$502.6	Install signage indicating accessible parking that displays the international symbol of accessibility and mount at 60" (1524 mm) min. above the finished floor.	B	\$0.00
Arts and Culture	Southwest Arts Center Theater	915 New Hope Rd Atlanta, GA 30331	Passenger Loading Zone	Passenger loading zone does not have signage displaying the international symbol of accessibility.	\$503	Provide signage displaying the International symbol of accessibility at passenger loading zone.	B	\$228.00
Arts and Culture	Southwest Arts Center Theater	915 New Hope Rd Atlanta, GA 30331	Passenger Loading Zone	Passenger loading zone does not have a clearly defined access aisle.	\$503.3.1	Provide a 60" (1524 mm) min. wide access aisle serving a 20 ft. (6096 mm) min. long vehicle pull up space with a surface slope not exceeding 2% in all directions (2010 ADA Fig. 503.3).	B	\$299.81
Arts and Culture	Southwest Arts Center Theater	915 New Hope Rd Atlanta, GA 30331	Passenger Loading Zone	Passenger loading zone has a 3.5 % non-compliant surface slope.	\$503.4	Restripe to provide a 60" (1524 mm) min. wide access aisle serving a 20 ft. (6096 mm) min. long vehicle pull up space with a surface slope not exceeding 2% in all directions (2010 ADA Fig. 503.3).	B	\$2,846.06
Arts and Culture	Southwest Arts Center Theater	915 New Hope Rd Atlanta, GA 30331	Six Accessible Parking Spaces by Main Entrance	Second accessible parking space (from right to left) has a non-compliant surface slope of up to 4.5%	\$504.2	Rework or repave to provide an accessible parking space with surface slope not exceeding 2% in all directions.	B	\$1,897.39
Arts and Culture	Southwest Arts Center Theater	915 New Hope Rd Atlanta, GA 30331	Six Accessible Parking Spaces by Main Entrance	Third accessible parking space (from right to left) has a non-compliant surface slope of up to 5.3%	\$504.2	Rework or repave to provide an accessible parking space with surface slope not exceeding 2% in all directions.	B	\$1,897.39
Arts and Culture	Southwest Arts Center Theater	915 New Hope Rd Atlanta, GA 30331	Six Accessible Parking Spaces by Main Entrance	Fourth accessible parking space (from right to left) has a non-compliant surface slope of up to 6.2%	\$504.2	Rework or repave to provide an accessible parking space with surface slope not exceeding 2% in all directions.	B	\$1,897.39
Arts and Culture	Southwest Arts Center Theater	915 New Hope Rd Atlanta, GA 30331	Six Accessible Parking Spaces by Main Entrance	Fifth accessible parking space (from right to left) has a non-compliant surface slope of up to 6.1%	\$504.2	Rework or repave to provide an accessible parking space with surface slope not exceeding 2% in all directions.	B	\$1,897.39
Arts and Culture	Southwest Arts Center Theater	915 New Hope Rd Atlanta, GA 30331	Six Accessible Parking Spaces by Main Entrance	Sixth accessible parking space (from right to left) has a non-compliant surface slope of up to 6.8%	\$504.2	Rework or repave to provide an accessible parking space with surface slope not exceeding 2% in all directions.	B	\$1,897.39
Arts and Culture	Southwest Arts Center Theater	915 New Hope Rd Atlanta, GA 30331	Star Dressing Room No. 130	Permanent room identifying signage is mounted on the hinge side of the door.	\$703.4.1	Provide signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. from the baseline of the highest tactile character (2010 ADA Fig. 703.4.1). There is no space on the latch side of door, no remedial work is necessary	B	\$0.00
Arts and Culture	Southwest Arts Center Theater	915 New Hope Rd Atlanta, GA 30331	Women's Toilet Room No. 131	Permanent room identifying signage is mounted at 61.5" (1562 mm) to the baseline of the highest tactile character.	\$703.4.1	Provide signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. to the baseline of the highest tactile character (2010 ADA Fig. 703.4.1). Per 36.304(d)(2)(j) Safe harbor. Elements that comply with the corresponding technical requirements and scoping requirements for those elements in the 1991 Standards do not need to be modified in order to comply with the requirements set forth in the 2010 Standards.	B	\$0.00
Arts and Culture	Southwest Arts Center Theater	915 New Hope Rd Atlanta, GA 30331	Women's Dressing Room No. 132	Permanent room identifying signage is mounted at 61.25" (1556 mm) to the baseline of the highest tactile character.	\$703.4.1	Provide signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. to the baseline of the highest tactile character (2010 ADA Fig. 703.4.1). Per 36.304(d)(2)(j) Safe harbor. Elements that comply with the corresponding technical requirements and scoping requirements for those elements in the 1991 Standards do not need to be modified in order to comply with the requirements set forth in the 2010 Standards.	B	\$0.00
Arts and Culture	Southwest Arts Center Theater	915 New Hope Rd Atlanta, GA 30331	Men's Dressing Room No. 132	Permanent room identifying signage is mounted at 61.25" (1556 mm) to the baseline of the highest tactile character.	\$703.4.1	Provide signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. to the baseline of the highest tactile character (2010 ADA Fig. 703.4.1). Per 36.304(d)(2)(j) Safe harbor. Elements that comply with the corresponding technical requirements and scoping requirements for those elements in the 1991 Standards do not need to be modified in order to comply with the requirements set forth in the 2010 Standards.	B	\$0.00

**Fulton County ADA Transition Plan
ARTS AND CULTURE
Appendix 7-10**

Department	Bldg Name	Address	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction	Priority	Cost
Arts and Culture	Southwest Arts Center Theater	915 New Hope Rd Atlanta, GA 30331	Men's Toilet Room No. 134	Permanent room identifying signage is mounted at 61.25" (1556 mm) to the baseline of the highest tactile character.	§703.4.1	Provide signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. to the baseline of the highest tactile character (2010 ADA Fig. 703.4.1). Per 36.304(d)(2)(j) Safe harbor. Elements that comply with the corresponding technical requirements and scoping requirements for those elements in the 1991 Standards do not need to be modified in order to comply with the requirements set forth in the 2010 Standards.	B	\$0.00
Arts and Culture	Southwest Arts Center Theater	915 New Hope Rd Atlanta, GA 30331	Star Dressing Room No. 135	Permanent room identifying signage is mounted at 61" (1549 mm) to the baseline of the highest tactile character.	§703.4.1	Provide signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. to the baseline of the highest tactile character (2010 ADA Fig. 703.4.1). Per 36.304(d)(2)(j) Safe harbor. Elements that comply with the corresponding technical requirements and scoping requirements for those elements in the 1991 Standards do not need to be modified in order to comply with the requirements set forth in the 2010 Standards.	B	\$0.00
Arts and Culture	Southwest Arts Center Theater	915 New Hope Rd Atlanta, GA 30331	Green Room No. 139	Permanent room identifying signage is mounted at 61.25" (1556 mm) to the baseline of the highest tactile character.	§703.4.1	Provide signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. to the baseline of the highest tactile character (2010 ADA Fig. 703.4.1). Per 36.304(d)(2)(j) Safe harbor. Elements that comply with the corresponding technical requirements and scoping requirements for those elements in the 1991 Standards do not need to be modified in order to comply with the requirements set forth in the 2010 Standards.	B	\$0.00
Arts and Culture	Southwest Arts Center Theater	915 New Hope Rd Atlanta, GA 30331	Toilet Room No. 137	Permanent room identifying signage is mounted at 61.25" (1556 mm) to the baseline of the highest tactile character.	§703.4.1	Provide signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. to the baseline of the highest tactile character (2010 ADA Fig. 703.4.1). Per 36.304(d)(2)(j) Safe harbor. Elements that comply with the corresponding technical requirements and scoping requirements for those elements in the 1991 Standards do not need to be modified in order to comply with the requirements set forth in the 2010 Standards.	B	\$0.00
Arts and Culture	Southwest Arts Center Theater	915 New Hope Rd Atlanta, GA 30331	Assistive Listening Systems	Per site manager the theater has a total of 16 assistive listening devices, but there is no signage indicating that assistive listening systems are provided upon request.	§703.7.2.4	Provide signage in a conspicuous area indicating that assistive listening systems are provided upon request. The sign must be identified by the International Symbol of Access for Hearing Loss (2010 ADA Fig. 703.7.2.4).	B	\$149.95
Arts and Culture	Southwest Arts Center Theater	915 New Hope Rd Atlanta, GA 30331	Wheelchair Spaces at Mid Section Right Side	There is no companion seat provided next to the wheelchair area.	§802.3	Provide a movable companion seat that provides shoulder alignment with adjacent wheelchair spaces, that is the equivalent in size, quality, comfort and amenities to the immediate area (2010 ADA Figs. 802.2).	B	\$400.00
Arts and Culture	Southwest Arts Center Theater	915 New Hope Rd Atlanta, GA 30331	Wheelchair Spaces at Theater	Aisle side seat is not identified by a sign or marker.	§802.4.2	Provide signage identifying the designated access aisle seat.	B	\$149.95
Arts and Culture	Southwest Arts Center Theater	915 New Hope Rd Atlanta, GA 30331	Wheelchair Spaces on Right Side of Theater	Aisle side seat is not identified by a sign or marker.	§802.4.2	Provide signage identifying the designated access aisle seat.	B	\$149.95
Arts and Culture	Southwest Arts Center Theater	915 New Hope Rd Atlanta, GA 30331	Wheelchair Spaces at Mid Section Right Side	Aisle side seat is not identified by a sign or marker.	§802.4.2	Provide signage identifying the designated access aisle seat.	B	\$149.95
Arts and Culture	Southwest Arts Center Theater	915 New Hope Rd Atlanta, GA 30331	Toilet Room No. 137	Paper towel dispenser protrudes into walkway, projecting 11" (279 mm) from back wall, and is mounted at 43" (1092 mm) above the finished floor to its bottom leading edge.	§307.2r	Relocate or recess paper towel dispenser so that it does not project more than 4" (101 mm) from back wall to outer leading edge (2010 ADA Fig. 307.2).	C	\$131.00
Arts and Culture	Southwest Arts Center Theater	915 New Hope Rd Atlanta, GA 30331	Women's Lounge	Toilet seat cover dispenser is mounted beyond reach ranges at 49.5" (1257 mm) above the finished floor to the receptacle.	§308.2.1	Relocate toilet seat cover dispenser and mount between 15" to 48" (380 mm - 1219 mm) above the finished floor to the receptacle for unobstructed forward approach to object (2010 ADA Fig. 308.2.1). Per 36.304(d)(2)(j) Safe harbor. Elements that comply with the corresponding technical requirements and scoping requirements for those elements in the 1991 Standards do not need to be modified in order to comply with the requirements set forth in the 2010 Standards.	C	\$0.00
Arts and Culture	Southwest Arts Center Theater	915 New Hope Rd Atlanta, GA 30331	Men's Lounge	Toilet seat cover dispenser is mounted on top of the rear wall grab bar and behind the water closet.	§308.2.1	Relocate toilet seat cover dispenser and mount between 15" to 48" (380 mm - 1219 mm) above the finished floor for unobstructed forward approach to object (2010 ADA Fig. 308.2.1). If mounted below the side wall grab bar there shall be a clearance of 1.5" (38 mm) below the grab bar - If mounted above the side wall grab bar there shall be a clearance of 12" (305 mm) min. above the grab bar (2010 ADA Fig 609.3)	C	\$131.00
Arts and Culture	Southwest Arts Center Theater	915 New Hope Rd Atlanta, GA 30331	Men's Lounge	Toilet seat cover dispenser is mounted beyond reach ranges at 51" (1295 mm) above the finished floor and is mounted behind the water closet.	§308.2.1	Relocate toilet seat cover dispenser and mount between 15" to 48" (380 mm - 1219 mm) above the finished floor for unobstructed forward approach to object (2010 ADA Fig. 308.2.1).	C	\$131.00
Arts and Culture	Southwest Arts Center Theater	915 New Hope Rd Atlanta, GA 30331	Women's Dressing Room No. 132	Thermostat is mounted beyond required reach allowed for approach provided and is mounted at 61" (1549 mm) above the finished floor to the highest operable part.	§308.2.1	Lower or install thermostat at 48" (1219 mm) max. above the finished floor to the highest operable part (2010 ADA Fig. 308.2.1).	C	\$378.00
Arts and Culture	Southwest Arts Center Theater	915 New Hope Rd Atlanta, GA 30331	Women's Toilet Room No. 131	Toilet seat cover dispenser is on the floor.	§308.2.1	Relocate toilet seat cover dispenser and mount between 15" to 48" (380 mm - 1219 mm) above the finished floor for unobstructed forward approach to object (2010 ADA Fig. 308.2.1).	C	\$131.00
Arts and Culture	Southwest Arts Center Theater	915 New Hope Rd Atlanta, GA 30331	Star Dressing Room No. 135	Clothes rod is mounted beyond required reach allowed for approach provided and is mounted at 71.5" (1816 mm) above the finished floor.	§308.2.1	Lower or install accessible clothes rod at 48" (1219 mm) max. above the finished floor for forward approach to object (2010 ADA Fig. 308.2.1).	C	\$131.00
Arts and Culture	Southwest Arts Center Theater	915 New Hope Rd Atlanta, GA 30331	Green Room No. 139	Outlet is mounted beyond required reach allowed for approach provided at 55.75" (1416 mm) above the finished floor over an obstruction (sink counter).	§308.2.1	Lower or install outlet at 44" (1219 mm) max. above the finished floor, over a 20" - 25" (510 mm - 1120 mm) max. obstruction (2010 ADA Fig. 308.2.1).	C	\$500.00
Arts and Culture	Southwest Arts Center Theater	915 New Hope Rd Atlanta, GA 30331	Toilet Room No. 137	Paper towel dispenser is mounted beyond required reach allowed for approach provided and is mounted at 48.75" (1238 mm) above the finished floor to highest operable part.	§308.2.1	Lower or install paper towel dispenser at 48" (1219 mm) max. above the finished floor to highest operable part (2010 ADA Fig. 308.3.1). Per 36.304(d)(2)(j) Safe harbor. Elements that comply with the corresponding technical requirements and scoping requirements for those elements in the 1991 Standards do not need to be modified in order to comply with the requirements set forth in the 2010 Standards.	C	\$0.00
Arts and Culture	Southwest Arts Center Theater	915 New Hope Rd Atlanta, GA 30331	Men's Lounge	Standard stall doorway opening has a clear width of 23" (584 mm).	§404.2.3	Rework stall doorway (partitions) to provide the required 32" (813 mm) min. clear door or entryway width (2010 ADA Fig. 404.2.3).	C	\$0.00
Arts and Culture	Southwest Arts Center Theater	915 New Hope Rd Atlanta, GA 30331	Women's Lounge	Door has a non-compliant opening force of 8 lbf.	§404.2.9	Adjust or replace door closer, maintain door hinges to provide an opening force not to exceed 5 lbf.	C	\$131.00
Arts and Culture	Southwest Arts Center Theater	915 New Hope Rd Atlanta, GA 30331	Toilet Room No. 137	Lavatory mirror is mounted at 40.25" (1022 mm) above the finished floor to bottom edge of its reflecting surface.	§603.3	Lower lavatory mirror to 40" (1016 mm) max. above the finished floor to bottom edge of its reflecting surface.	C	\$131.00
Arts and Culture	Southwest Arts Center Theater	915 New Hope Rd Atlanta, GA 30331	Women's Lounge	Coat hook is mounted beyond required reach allowed for approach provided and is mounted at 48.5" (1232 mm) above the finished floor.	§603.4	Lower or install coat hook at 48" (1219 mm) max. above the finished floor for forward approach to object (For toilet and bathing rooms only).	C	\$55.00
Arts and Culture	Southwest Arts Center Theater	915 New Hope Rd Atlanta, GA 30331	Women's Lounge	Coat hook is mounted beyond required reach allowed for approach provided and is mounted at 48.75" (1238 mm) above the finished floor.	§603.4	Lower or install coat hook at 48" (1219 mm) max. above the finished floor for forward approach to object. Per 36.304(d)(2)(j) Safe harbor. Elements that comply with the corresponding technical requirements and scoping requirements for those elements in the 1991 Standards do not need to be modified in order to comply with the requirements set forth in the 2010 Standards.	C	\$0.00
Arts and Culture	Southwest Arts Center Theater	915 New Hope Rd Atlanta, GA 30331	Men's Lounge	Coat hook is mounted beyond required reach allowed for approach provided and is mounted at 62" (1651 mm) above the finished floor.	§603.4	Lower or install coat hook at 48" (1219 mm) max. above the finished floor for forward approach to object.	C	\$55.00
Arts and Culture	Southwest Arts Center Theater	915 New Hope Rd Atlanta, GA 30331	Women's Lounge	Water closet is centered at 20.5" (521 mm) from side wall.	§604.2	Relocate water closet and center between 16" and 18" (406 mm - 457 mm) from side wall (2010 ADA Fig. 604.2).	C	\$1,029.03

**Fulton County ADA Transition Plan
ARTS AND CULTURE
Appendix 7-10**

Department	Bldg Name	Address	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction	Priority	Cost
Arts and Culture	Southwest Arts Center Theater	915 New Hope Rd Atlanta, GA 30331	Women's Lounge	Water closet is centered at 18.25" (464 mm) from side wall.	§604.2	Relocate water closet and center between 16" and 18" (406 mm - 457 mm) from side wall (2010 ADA Fig. 604.2). This dimension should be considered acceptable per 1990 ADA section 3.2 Dimensional Tolerances and 2010 ADA section 104.1 Construction and Manufacturing Tolerance.	C	\$0.00
Arts and Culture	Southwest Arts Center Theater	915 New Hope Rd Atlanta, GA 30331	Men's Lounge	Water closet is centered at 21" (533 mm) from side wall.	§604.2	Relocate water closet and center between 16" and 18" (406 mm - 457 mm) from side wall (2010 ADA Fig. 604.2).	C	\$1,029.03
Arts and Culture	Southwest Arts Center Theater	915 New Hope Rd Atlanta, GA 30331	Toilet Room No. 137	Water closet is centered at 19" (483 mm) from side wall.	§604.2	Relocate water closet and center between 16" and 18" (406 mm - 457 mm) from side wall (2010 ADA Fig. 604.2).	C	\$1,029.03
Arts and Culture	Southwest Arts Center Theater	915 New Hope Rd Atlanta, GA 30331	Women's Lounge	Water closet side wall grab bar is mounted at 36.5" (927 mm) above the finished floor to the top of the gripping surface.	§604.5.1	Install a 42" (1066 mm) min. long side wall grab bar at 54" (1371 mm) min. from rear wall to centerline of outer flange and mount at 33" - 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig. 604.5.1).	C	\$150.00
Arts and Culture	Southwest Arts Center Theater	915 New Hope Rd Atlanta, GA 30331	Women's Lounge	Water closet side wall grab bar is mounted at 36.75" (933 mm) above the finished floor to the top of the gripping surface.	§604.5.1	Install a 42" (1066 mm) min. long side wall grab bar at 54" (1371 mm) min. from rear wall to centerline of outer flange and mount at 33" - 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig. 604.5.1).	C	\$150.00
Arts and Culture	Southwest Arts Center Theater	915 New Hope Rd Atlanta, GA 30331	Men's Lounge	Water closet does not have a side wall grab bar.	§604.5.1	Install a 42" (1066 mm) min. long side wall grab bar at 54" (1371 mm) min. from rear wall to centerline of outer flange and mount at 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (ADAAG Fig. 604.5.1).	C	\$380.20
Arts and Culture	Southwest Arts Center Theater	915 New Hope Rd Atlanta, GA 30331	Women's Toilet Room No. 131	Water closet side wall grab bar is mounted at 36.5" (927 mm) above the finished floor to the top of the gripping surface.	§604.5.1	Install a 42" (1066 mm) min. long side wall grab bar at 54" (1371 mm) min. from rear wall to centerline of outer flange and mount at 33" - 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig. 604.5.1).	C	\$150.00
Arts and Culture	Southwest Arts Center Theater	915 New Hope Rd Atlanta, GA 30331	Women's Toilet Room No. 131	Water closet side wall grab bar is mounted at 36.5" (927 mm) above the finished floor to the top of the gripping surface.	§604.5.1	Install a 42" (1066 mm) min. long side wall grab bar at 54" (1371 mm) min. from rear wall to centerline of outer flange and mount at 33" - 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig. 604.5.1).	C	\$150.00
Arts and Culture	Southwest Arts Center Theater	915 New Hope Rd Atlanta, GA 30331	Toilet Room No. 137	Water closet side wall grab bar is mounted at 37" (940 mm) above the finished floor to the top of the gripping surface.	§604.5.1	Install a 42" (1066 mm) min. long side wall grab bar at 54" (1371 mm) min. from rear wall to centerline of outer flange and mount at 33" - 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig. 604.5.1).	C	\$150.00
Arts and Culture	Southwest Arts Center Theater	915 New Hope Rd Atlanta, GA 30331	Women's Lounge	Water closet rear wall grab bar is mounted at 36.5" (927 mm) above the finished floor to the top of the gripping surface.	§604.5.2	Relocate rear wall grab bar and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface.	C	\$150.00
Arts and Culture	Southwest Arts Center Theater	915 New Hope Rd Atlanta, GA 30331	Men's Lounge	Water closet does not have a rear wall grab bar.	§604.5.2	Install a 36" (914 mm) min. long rear wall grab bar and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig. 604.5.2).	C	\$380.20
Arts and Culture	Southwest Arts Center Theater	915 New Hope Rd Atlanta, GA 30331	Women's Toilet Room No. 131	Water closet rear wall grab bar is mounted at 36.5" (927 mm) above the finished floor to the top of the gripping surface.	§604.5.2	Relocate rear wall grab bar and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface.	C	\$150.00
Arts and Culture	Southwest Arts Center Theater	915 New Hope Rd Atlanta, GA 30331	Women's Toilet Room No. 131	Water closet rear wall grab bar is mounted at 36.5" (927 mm) above the finished floor to the top of the gripping surface.	§604.5.2	Relocate rear wall grab bar and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface.	C	\$150.00
Arts and Culture	Southwest Arts Center Theater	915 New Hope Rd Atlanta, GA 30331	Toilet Room No. 137	Water closet rear wall grab bar is mounted at 37" (940 mm) above the finished floor to the top of the gripping surface.	§604.5.2	Relocate rear wall grab bar and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface.	C	\$150.00
Arts and Culture	Southwest Arts Center Theater	915 New Hope Rd Atlanta, GA 30331	Women's Lounge	Toilet tissue dispenser is mounted at 6.5" (165 mm) in front of the water closet to the centerline of the dispenser.	§604.7	Relocate toilet tissue dispenser to water closet side wall at 7"-9" (177 mm to 228 mm) in front of the water closet to the centerline of the dispenser and 15"-48" (381 mm to 1219 mm) above the finished floor to the dispenser outlet (2010 ADA Fig. 604.7). If mounted below the side wall grab bar there shall be a clearance of 1.5" (38 mm) below the grab bar. If mounted above the side wall grab bar there shall be a clearance of 12" (305 mm) min. above the grab bar (2010 ADA Fig 609.3)	C	\$131.00
Arts and Culture	Southwest Arts Center Theater	915 New Hope Rd Atlanta, GA 30331	Men's Lounge	The door swings into accessible toilet compartment (stall) clear floor space.	§604.8.1.1	Reverse door swing and reconfigure stall partitions to provide a 60" by 56" (1524 mm by 1422 mm) min. accessible toilet compartment for a wall mounted water closet (2010 ADA Fig. 604.8.1.1).	C	\$0.00
Arts and Culture	Southwest Arts Center Theater	915 New Hope Rd Atlanta, GA 30331	Men's Lounge	Accessible toilet compartment (stall) is 60" (1524 mm) deep by 47.25" (1206 mm) wide.	§604.8.1.1	Rework partitions and/or fixtures to provide a 60" (1524 mm) min. wide by 56" (1422 mm) min. deep accessible toilet compartment for a wall mounted water closet (2010 ADA Fig. 604.8.1.1).	C	\$2,119.74
Arts and Culture	Southwest Arts Center Theater	915 New Hope Rd Atlanta, GA 30331	Women's Toilet Room No. 131	Accessible toilet compartment (stall) is 55.5" (1410 mm) deep.	§604.8.1.1	Rework partitions and/or fixtures to provide a 60" (1524 mm) min. wide by 56" (1422 mm) min. deep accessible toilet compartment for a wall mounted water closet (2010 ADA Fig. 604.8.1.1). This dimension should be considered acceptable per 1990 ADA section 3.2 Dimensional Tolerances and 2010 ADA section 104.1 Construction and Manufacturing Tolerance.	C	\$0.00
Arts and Culture	Southwest Arts Center Theater	915 New Hope Rd Atlanta, GA 30331	Women's Lounge	Secondary toilet compartment (stall) on right does not provide pull handles on both sides of the door near the latch.	§604.8.1.2	Provided pull handles on both sides of the door near the latch and center door opening hardware between 34" and 48" (863 mm - 1219 mm) above the finished floor.	C	\$55.00
Arts and Culture	Southwest Arts Center Theater	915 New Hope Rd Atlanta, GA 30331	Men's Lounge	Toilet compartment (stall) door does not provide pull handles on both sides of the door near the latch.	§604.8.1.2	Provided pull handles on both sides of the door near the latch and center door opening hardware between 34" and 48" (863 mm - 1219 mm) above the finished floor.	C	\$55.00
Arts and Culture	Southwest Arts Center Theater	915 New Hope Rd Atlanta, GA 30331	Women's Toilet Room No. 131	Toilet compartment (stall) door does not provide pull handles on both sides of the door near the latch.	§604.8.1.2	Provided pull handles on both sides of the door near the latch and center door opening hardware between 34" and 48" (863 mm - 1219 mm) above the finished floor.	C	\$55.00
Arts and Culture	Southwest Arts Center Theater	915 New Hope Rd Atlanta, GA 30331	Women's Lounge	Accessible toilet compartment (stall) door is not located on the side wall or partition farthest from the water closet (door is located in front of water closet).	§604.8.2.2	Reconfigure accessible toilet compartment (stall) to provide a self closing door with opening mounted at 4" (101 mm) max. from the side wall or partition farthest from the water closet (For door located in front of partition) (2010 ADA Fig. 604.8.1.1).	C	\$898.00
Arts and Culture	Southwest Arts Center Theater	915 New Hope Rd Atlanta, GA 30331	Men's Lounge	Accessible toilet compartment (stall) door is not located on the side wall or partition farthest from the water closet (door is located in front of water closet).	§604.8.2.2	Reconfigure accessible toilet compartment (stall) to provide a self closing door with opening mounted at 4" (101 mm) max. from the side wall or partition farthest from the water closet (For door located in front of partition) (2010 ADA Fig. 604.8.1.1).	C	\$898.00
Arts and Culture	Southwest Arts Center Theater	915 New Hope Rd Atlanta, GA 30331	Men's Lounge	Accessible toilet compartment (stall) door is located at 20.5" (521 mm) from the side wall or partition farthest from the water closet	§604.8.2.2	Reconfigure accessible toilet compartment (stall) to provide a self closing door with opening mounted at 4" (101 mm) max. from the side wall or partition farthest from the water closet (For door located in front of partition) (2010 ADA Fig. 604.8.1.1).	C	\$0.00
Arts and Culture	Southwest Arts Center Theater	915 New Hope Rd Atlanta, GA 30331	Women's Toilet Room No. 131	Accessible toilet compartment (stall) door is not located on the side wall or partition farthest from the water closet (stall door is in front of water closet)	§604.8.2.2	Reconfigure accessible toilet compartment (stall) to provide a self closing door with opening mounted at 4" (101 mm) max. from the side wall or partition farthest from the water closet (For door located in front of partition) (2010 ADA Fig. 604.8.1.1).	C	\$898.00
Arts and Culture	Southwest Arts Center Theater	915 New Hope Rd Atlanta, GA 30331	Men's Lounge	Lowest urinal is mounted at 17.25" (438 mm) above the finished floor to top of rim.	§605.2	Lower urinal and mount at 17" (431 mm) max. above the finished floor to top of rim. (2010 ADA Fig. 605.2). This dimension should be considered acceptable per 1990 ADA section 3.2 Dimensional Tolerances and 2010 ADA section 104.1 Construction and Manufacturing Tolerance.	C	\$0.00
Arts and Culture	Southwest Arts Center Theater	915 New Hope Rd Atlanta, GA 30331	Women's Toilet Room No. 131	Transfer shower stall is 41.25" by 46" (1048 by 1168 mm) deep.	§608.2.1	Reconfigure room's fixtures and/or offset partitions to provide a 36" by 36" (914 mm by 914 mm) shower stall with the required 36" by 48" (914 mm by 1219 mm) min. clear floor space (2010 ADA Fig. 608.2.1).	C	\$2,502.43
Arts and Culture	Southwest Arts Center Theater	915 New Hope Rd Atlanta, GA 30331	Women's Toilet Room No. 131	Transfer shower stall is 41.5" by 47.5" (1054 by 1206 mm) deep.	§608.2.1	Reconfigure room's fixtures and/or offset partitions to provide a 36" by 36" (914 mm by 914 mm) shower stall with the required 36" by 48" (914 mm by 1219 mm) min. clear floor space (2010 ADA Fig. 608.2.1).	C	\$2,502.43
Arts and Culture	Southwest Arts Center Theater	915 New Hope Rd Atlanta, GA 30331	Women's Toilet Room No. 131	Transfer shower grab bar is mounted at a point of 26" (660 mm) from the control wall	§608.3.1	Install grab bars across the control wall and back wall to a point 18" (457 mm) from the control wall, and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig. 608.3.1).	C	\$380.20
Arts and Culture	Southwest Arts Center Theater	915 New Hope Rd Atlanta, GA 30331	Women's Toilet Room No. 131	Transfer shower grab bar is mounted at a point of 26.25" (667 mm) from the control wall	§608.3.1	Install grab bars across the control wall and back wall to a point 18" (457 mm) from the control wall, and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig. 608.3.1).	C	\$380.20
Arts and Culture	Southwest Arts Center Theater	915 New Hope Rd Atlanta, GA 30331	Women's Toilet Room No. 131	Transfer shower seat is mounted at 19.5" (495 mm) above the finished floor to top of seat.	§608.4	Install a transfer shower seat and mount between 17"- 19" max. (431 mm - 482 mm) above the finished floor to top of seat. The seat shall extend from the back wall to a point within 3" (75 mm) of the compartment entry (2010 ADA Fig. 610.3).	C	\$225.00

**Fulton County ADA Transition Plan
ARTS AND CULTURE
Appendix 7-10**

Department	Bldg Name	Address	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction	Priority	Cost
Arts and Culture	Southwest Arts Center Theater	915 New Hope Rd Atlanta, GA 30331	Women's Toilet Room No. 131	Transfer shower controls are mounted 50.5" (1283 mm) above the finished floor to the centerline	§608.5.1	Mount shower controls on the side wall opposite to the seat, between 38" (965 mm) min. - 48" (1220 mm) max. above the finished floor to the highest operable part and at 15" (380 mm) from centerline to the edge of shower.	C	\$898.00
Arts and Culture	Southwest Arts Center Theater	915 New Hope Rd Atlanta, GA 30331	Women's Toilet Room No. 131	Transfer shower controls are mounted 50.75" (1289 mm) above the finished floor to the centerline	§608.5.1	Mount shower controls on the side wall opposite to the seat, between 38" (965 mm) min. - 48" (1220 mm) max. above the finished floor to the highest operable part and at 15" (380 mm) from centerline to the edge of shower.	C	\$898.00
Arts and Culture	Southwest Arts Center Theater	915 New Hope Rd Atlanta, GA 30331	Women's Toilet Room No. 131	Transfer shower stall has a 0.75" (19 mm) high curb.	§608.7	Rework transfer shower to provide a beveled curb that does not exceed 0.5" (12 mm) in height.	C	\$390.54
Arts and Culture	Southwest Arts Center Theater	915 New Hope Rd Atlanta, GA 30331	Women's Lounge	Toilet tissue dispenser is mounted 4" (102 mm) over the side wall grab bar.	§609.3	Relocate toilet seat cover dispenser to provide a clear space between the side wall grab bar and projecting objects above of 12" (305 mm) min. (2010 ADA Fig. 609.3). <i>Per 36.304(d)(2)(i) Safe harbor. Elements that comply with the corresponding technical requirements and scoping requirements for those elements in the 1991 Standards do not need to be modified in order to comply with the requirements set forth in the 2010 Standards.</i>	C	\$0.00
Arts and Culture	Southwest Arts Center Theater	915 New Hope Rd Atlanta, GA 30331	Women's Lounge	Toilet seat cover dispenser is mounted 6" (152 mm) over the side wall grab bar.	§609.3	Relocate toilet seat cover dispenser to provide a clear space between the side wall grab bar and projecting objects above of 12" (305 mm) min. (2010 ADA Fig. 609.3). <i>Per 36.304(d)(2)(i) Safe harbor. Elements that comply with the corresponding technical requirements and scoping requirements for those elements in the 1991 Standards do not need to be modified in order to comply with the requirements set forth in the 2010 Standards.</i>	C	\$0.00
Arts and Culture	Southwest Arts Center Theater	915 New Hope Rd Atlanta, GA 30331	Men's Lounge	Toilet tissue dispenser is mounted 4.75" (121 mm) over the side wall grab bar.	§609.3	Relocate toilet tissue dispenser to provide a clear space between the side wall grab bar and projecting objects above of 12" (305 mm) min. (2010 ADA Fig. 609.3). <i>Per 36.304(d)(2)(i) Safe harbor. Elements that comply with the corresponding technical requirements and scoping requirements for those elements in the 1991 Standards do not need to be modified in order to comply with the requirements set forth in the 2010 Standards.</i>	C	\$0.00
Arts and Culture	Southwest Arts Center Theater	915 New Hope Rd Atlanta, GA 30331	Women's Toilet Room No. 131	Toilet tissue dispenser is mounted 3.5" (89 mm) over the side wall grab bar.	§609.3	Relocate toilet seat cover dispenser to provide a clear space between the side wall grab bar and projecting objects above of 12" (305 mm) min. (2010 ADA Fig. 609.3). <i>Per 36.304(d)(2)(i) Safe harbor. Elements that comply with the corresponding technical requirements and scoping requirements for those elements in the 1991 Standards do not need to be modified in order to comply with the requirements set forth in the 2010 Standards.</i>	C	\$0.00
Arts and Culture	Southwest Arts Center Theater	915 New Hope Rd Atlanta, GA 30331	Women's Toilet Room No. 131	Toilet tissue dispenser is mounted 4.25" (108 mm) over the side wall grab bar.	§609.3	Relocate toilet tissue dispenser to provide a clear space between the side wall grab bar and projecting objects above of 12" (305 mm) min. (2010 ADA Fig. 609.3). <i>Per 36.304(d)(2)(i) Safe harbor. Elements that comply with the corresponding technical requirements and scoping requirements for those elements in the 1991 Standards do not need to be modified in order to comply with the requirements set forth in the 2010 Standards.</i>	C	\$0.00
Arts and Culture	Southwest Arts Center Theater	915 New Hope Rd Atlanta, GA 30331	Toilet Room No. 137	Toilet tissue dispenser is mounted 3.5" (89 mm) over the side wall grab bar.	§609.3	Relocate toilet tissue dispenser to provide a clear space between the side wall grab bar and projecting objects above of 12" (305 mm) min. (2010 ADA Fig. 609.3). <i>Per 36.304(d)(2)(i) Safe harbor. Elements that comply with the corresponding technical requirements and scoping requirements for those elements in the 1991 Standards do not need to be modified in order to comply with the requirements set forth in the 2010 Standards.</i>	C	\$0.00
Arts and Culture	Southwest Arts Center Theater	915 New Hope Rd Atlanta, GA 30331	Green Room No. 139	Sink is mounted at 34.75" (883 mm) above the finished floor to top of rim.	§804.4	Relocate and/or mount sink at 34" (863 mm) max. above the finished floor to top of rim.	C	\$500.00
Arts and Culture	Southwest Arts Center Theater	915 New Hope Rd Atlanta, GA 30331	Green Room No. 139	Sink has partially unwrapped bottom pipes.	§804.4	Cover (insulate) sink bottom supply and drain pipes.	C	\$120.12
Arts and Culture	Southwest Arts Center Theater	915 New Hope Rd Atlanta, GA 30331	Star Dressing Room No. 130	Clothes rod is mounted beyond required reach range for approach provided and is mounted at 71.5" (1816 mm) above the finished floor.	§811.3	Lower or install accessible clothes rod at 48" (1219 mm) max. above the finished floor for forward or side approach to object 10" (254 mm) max. deep (ADAAG Fig. 308.3.1).	C	\$131.00
Arts and Culture	Southwest Arts Center Theater	915 New Hope Rd Atlanta, GA 30331	Star Dressing Room No. 130	Closet Shelf is mounted beyond required reach range for approach provided and is mounted at 75" (1905 mm) above the finished floor.	§811.3	Lower or install accessible shelf at 48" (1219 mm) max. above the finished floor for forward or side approach to object 10" (254 mm) max. deep (ADAAG Fig. 308.3.1).	C	\$131.00
Arts and Culture	Southwest Arts Center Theater	915 New Hope Rd Atlanta, GA 30331	Women's Dressing Room No. 132	Clothes rod is mounted beyond required reach range for approach provided and is mounted at 71.75" (1822 mm) above the finished floor.	§811.3	Lower or install accessible clothes rod at 48" (1219 mm) max. above the finished floor for forward or side approach to object 10" (254 mm) max. deep (ADAAG Fig. 308.3.1).	C	\$131.00
Arts and Culture	Southwest Arts Center Theater	915 New Hope Rd Atlanta, GA 30331	Women's Dressing Room No. 132	Closet Shelf is mounted beyond required reach range for approach provided and is mounted at 75.5" (1918 mm) above the finished floor.	§811.3	Lower or install accessible shelf at 48" (1219 mm) max. above the finished floor for forward or side approach to object 10" (254 mm) max. deep (ADAAG Fig. 308.3.1).	C	\$131.00
Arts and Culture	Southwest Arts Center Theater	915 New Hope Rd Atlanta, GA 30331	Men's Dressing Room No. 132	Clothes rod is mounted beyond required reach range for approach provided and is mounted at 71" (1803 mm) above the finished floor.	§811.3	Lower or install accessible clothes rod at 48" (1219 mm) max. above the finished floor (2010 ADA Fig. 308.3.1).	C	\$131.00
Arts and Culture	Southwest Arts Center Theater	915 New Hope Rd Atlanta, GA 30331	Men's Dressing Room No. 132	Closet Shelf is mounted beyond required reach range for approach provided and is mounted at 74.75" (1899 mm) above the finished floor.	§811.3	Lower or install accessible shelf at 48" (1219 mm) max. above the finished floor (2010 ADA Fig. 308.3.1).	C	\$131.00
Arts and Culture	Southwest Arts Center Theater	915 New Hope Rd Atlanta, GA 30331	Star Dressing Room No. 135	Closet Shelf is mounted beyond required reach range for approach provided and is mounted at 75" (1905 mm) above the finished floor.	§811.3	Lower or install accessible shelf at 48" (1219 mm) max. above the finished floor (2010 ADA Fig. 308.3.1).	C	\$131.00
Arts and Culture	Southwest Arts Center Theater	915 New Hope Rd Atlanta, GA 30331	Women's Lounge	Toilet compartment (stall) door does not provide pull handles on both sides of the door near the latch.	§604.8.1.2	Provided pull handles on both sides of the door near the latch and center door opening hardware between 34" and 48" (863 mm - 1219 mm) above the finished floor.	D	\$55.00
Arts and Culture	Southwest Arts Center Theater	915 New Hope Rd Atlanta, GA 30331	Men's Lounge	Toilet compartment (stall) door does not provide pull handles on both sides of the door near the latch.	§604.8.1.2	Provided pull handles on both sides of the door near the latch and center door opening hardware between 34" and 48" (863 mm - 1219 mm) above the finished floor.	D	\$55.00
Arts and Culture	Southwest Arts Center Theater	915 New Hope Rd Atlanta, GA 30331	Women's Toilet Room No. 131	Toilet compartment (stall) door does not provide pull handles on both sides of the door near the latch.	§604.8.1.2	Provided pull handles on both sides of the door near the latch and center door opening hardware between 34" and 48" (863 mm - 1219 mm) above the finished floor.	D	\$55.00
Arts and Culture	West End Performing Arts	955 Ralph David Abernathy Blvd Atlanta, GA 30310	Emergency Exit in Work Area	Emergency exit sign does not have Braille or raised characters and is mounted over the door header	§703.4.1	Provide additional signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. from the baseline of the highest tactile character (2010 ADA Fig. 703.4.1).	A	\$149.95
Arts and Culture	West End Performing Arts	970 Ralph David Abernathy Blvd Atlanta, GA 30310	Performance Area	Emergency exit sign does not have Braille or raised characters.	§703.4.1	Provide additional signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. from the baseline of the highest tactile character (2010 ADA Fig. 703.4.1).	A	\$149.95
Arts and Culture	West End Performing Arts	976 Ralph David Abernathy Blvd Atlanta, GA 30310	Fire Exit in Green Room	Emergency exit sign does not have Braille or raised characters and is mounted over the door header	§703.4.1	Provide additional signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. from the baseline of the highest tactile character (2010 ADA Fig. 703.4.1).	A	\$149.95

**Fulton County ADA Transition Plan
ARTS AND CULTURE
Appendix 7-10**

Department	Bldg Name	Address	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction	Priority	Cost
Arts and Culture	West End Performing Arts	945 Ralph David Abernathy Blvd Atlanta, GA 30310	Accessible Route From Public Rights-of-Way Leading to Main Entrance	Route from public right of way has a 0.5" (13 mm) vertical change in level.	\$303.2	Rework area and provide a 0.25" (6 mm) max. vertical change of level, with a slope no greater than 1:2 or mitigate condition by means of a curb ramp, ramp or platform lift (2010 ADA Fig. 303.2).	B	\$450.00
Arts and Culture	West End Performing Arts	972 Ralph David Abernathy Blvd Atlanta, GA 30310	Green Room	Furniture encroaches over maneuvering clearance on the pull side of the door.	\$404.2.4	Relocate furniture to provide the required 18" (457 mm) min. maneuvering clearance on the pull side of the door beyond the latch side and 60" (1524 mm) min. deep clear floor leveled area with slopes not exceeding 1:48 (2010 ADA Fig. 404.2.4.1).	B	\$291.64
Arts and Culture	West End Performing Arts	954 Ralph David Abernathy Blvd Atlanta, GA 30310	Emergency Exit in Work Area	Non-compliant knob-type door hardware, requiring grasping and turning of the wrist to operate.	\$404.2.7	Replace or retrofit with system operable with one hand, not requiring pinching, tight grasping or turning of the wrist to operate.	B	\$291.64
Arts and Culture	West End Performing Arts	971 Ralph David Abernathy Blvd Atlanta, GA 30310	Green Room	Non-compliant knob-type door hardware, requiring grasping and turning of the wrist to operate.	\$404.2.7	Replace or retrofit with system operable with one hand, not requiring pinching, tight grasping or turning of the wrist to operate.	B	\$291.64
Arts and Culture	West End Performing Arts	964 Ralph David Abernathy Blvd Atlanta, GA 30310	Men's Restroom Side by Side	Door has a non-compliant opening force of 11 lbf.	\$404.2.9	Adjust or replace door closer, maintain door hinges to provide an opening force not to exceed 5 lbf.	B	\$131.00
Arts and Culture	West End Performing Arts	946 Ralph David Abernathy Blvd Atlanta, GA 30310	Accessible Route From Public Rights-of-Way Leading to Main Entrance	Second segment of ramp has a non-compliant running slope of up to 9.5 %.	\$405.2	Rework ramp to provide a running slope not exceeding 8.33%.	B	\$2,154.30
Arts and Culture	West End Performing Arts	948 Ralph David Abernathy Blvd Atlanta, GA 30310	Accessible Route From Public Rights-of-Way Leading to Main Entrance	Third segment of the ramp has a non-compliant running slope of 8.9 %.	\$405.2	Rework ramp to provide a running slope not exceeding 8.33%.	B	\$2,154.30
Arts and Culture	West End Performing Arts	952 Ralph David Abernathy Blvd Atlanta, GA 30310	Accessible Route from The Accessible Parking Spaces Leading to Accessible Entrance on North Side	Second segment of ramp has a non-compliant running slope of up to 9.4 %.	\$405.2	Rework ramp to provide a running slope not exceeding 8.33%.	B	\$4,308.60
Arts and Culture	West End Performing Arts	947 Ralph David Abernathy Blvd Atlanta, GA 30310	Accessible Route From Public Rights-of-Way Leading to Main Entrance	Ramp with a change in direction has a 51" (1295 by 1295 mm) wide landing.	\$405.7.4	Rework ramp to provide 60" by 60" (1524 mm by 1524 mm) min. long landing, for ramps with a change of direction and runs rising over 30" (762 mm) (2010 ADA Fig. 405.7.4).	B	\$1,250.00
Arts and Culture	West End Performing Arts	949 Ralph David Abernathy Blvd Atlanta, GA 30310	Two Accessible Parking Spaces on North Side of Building	First accessible parking space has a 4.4 % non-compliant surface slope.	\$502.4	Rework or repave to provide an accessible parking space with surface slope not exceeding 2% in all directions.	B	\$1,897.39
Arts and Culture	West End Performing Arts	950 Ralph David Abernathy Blvd Atlanta, GA 30310	Two Accessible Parking Spaces on North Side of Building	Access aisle has a 5.7 % non-compliant surface slope.	\$502.4	Rework or repave to provide an access aisle with surface slope not exceeding 2% in all directions.	B	\$0.00
Arts and Culture	West End Performing Arts	951 Ralph David Abernathy Blvd Atlanta, GA 30310	Two Accessible Parking Spaces on North Side of Building	Second accessible parking space has a 6.4 % non-compliant surface slope.	\$502.4	Rework or repave to provide an accessible parking space with surface slope not exceeding 2% in all directions.	B	\$1,897.39
Arts and Culture	West End Performing Arts	977 Ralph David Abernathy Blvd Atlanta, GA 30310	Main entrance	Bench encroaches over maneuvering clearance on the pull side of the door.	\$404.2.4	Relocate bench to provide the required 18" (457 mm) min. maneuvering clearance on the pull side of the door (2010 ADA Fig. 404.2.4.1). Automatic door opener has been provided as an alternative.	B	\$55.00
Arts and Culture	West End Performing Arts	969 Ralph David Abernathy Blvd Atlanta, GA 30310	Performance Area	Performance mat has a 1" (25 mm) vertical change in level.	\$303.2	Rework area and provide a 0.25" (6 mm) max. vertical change of level, with a slope no greater than 1:2 (2010 ADA Fig. 303.2).	C	\$350.00
Arts and Culture	West End Performing Arts	963 Ralph David Abernathy Blvd Atlanta, GA 30310	Women's Restroom	Paper towel dispenser is mounted beyond required reach allowed for approach provided and is mounted at 62" (1575 mm) above the finished floor to highest operable part.	\$308.2.1	Lower or install paper towel dispenser at 48" (1219 mm) max. above the finished floor to highest operable part for forward approach to object (2010 ADA Fig. 308.3.1).	C	\$131.00
Arts and Culture	West End Performing Arts	968 Ralph David Abernathy Blvd Atlanta, GA 30310	Men's Restroom Side by Side	Paper towel dispenser is mounted beyond required reach allowed for approach provided and is mounted at 62" (1575 mm) above the finished floor to paper.	\$308.2.1	Lower or install paper towel dispenser at 48" (1219 mm) max. above the finished floor to paper for forward approach to object (2010 ADA Fig. 308.3.1).	C	\$131.00
Arts and Culture	West End Performing Arts	978 Ralph David Abernathy Blvd Atlanta, GA 30310	Rear Entrance	Intercom is mounted beyond required reach allowed for approach provided and is mounted at 52" (1321 mm) above the finished floor.	\$308.2.1	Lower or install at 48" (1219 mm) max. above the finished floor for forward approach to object (2010 ADA Fig. 308.2.1). For a facility that pre-dates the enactment of the ADA this dimension can be considered acceptable per 1990 ADA §3.2 Dimensional Tolerances & 2010 ADA §104.1 Construction and Manufacturing Tolerance.	C	\$378.00
Arts and Culture	West End Performing Arts	961 Ralph David Abernathy Blvd Atlanta, GA 30310	Women's Restroom	Coat hook is mounted beyond required reach allowed for approach provided and is mounted at 53" (1346 mm) above the finished floor.	\$603.4	Lower or install coat hook at 48" (1219 mm) max. above the finished floor for forward approach to object (For toilet and bathing rooms only).	C	\$55.00
Arts and Culture	West End Performing Arts	965 Ralph David Abernathy Blvd Atlanta, GA 30310	Men's Restroom Side by Side	Coat hook is mounted beyond required reach allowed for approach provided and is mounted at 52.5" (1334 mm) above the finished floor.	\$603.4	Lower or install coat hook at 48" (1219 mm) max. above the finished floor for forward approach to object (For toilet and bathing rooms only).	C	\$55.00
Arts and Culture	West End Performing Arts	958 Ralph David Abernathy Blvd Atlanta, GA 30310	Women's Restroom	Water closet is centered at 18.75" (476 mm) from side wall.	\$604.2	Relocate water closet and center between 16" and 18" (406 mm - 457 mm) from side wall (2010 ADA Fig. 604.2).	C	\$1,029.03
Arts and Culture	West End Performing Arts	960 Ralph David Abernathy Blvd Atlanta, GA 30310	Women's Restroom	Accessible toilet stall is 58.5" by 59.5" (1486 by 1511 mm) wide.	\$604.8.1.1	Rework partitions and/or fixtures to provide a 60" by 59" (1524 mm by 1498 mm) min. accessible toilet compartment for a floor mounted water closet (2010 ADA Fig. 604.8.1.1).	C	\$2,119.74
Arts and Culture	West End Performing Arts	959 Ralph David Abernathy Blvd Atlanta, GA 30310	Women's Restroom	Accessible stall door does not provide pull handles on both sides of the door near the latch.	\$604.8.2.2	Provided pull handles on both sides of the door near the latch and center door opening hardware between 34" and 48" (863 mm - 1219 mm) above the finished floor.	C	\$55.00
Arts and Culture	West End Performing Arts	966 Ralph David Abernathy Blvd Atlanta, GA 30310	Men's Restroom Side by Side	Accessible stall door does not provide pull handles on both sides of the door near the latch.	\$604.8.2.2	Provided pull handles on both sides of the door near the latch and center door opening hardware between 34" and 48" (863 mm - 1219 mm) above the finished floor.	C	\$55.00
Arts and Culture	West End Performing Arts	967 Ralph David Abernathy Blvd Atlanta, GA 30310	Men's Restroom Side by Side	Accessible stall door does not have a self closing mechanism.	\$604.8.2.2	Provide a self closing mechanism on door with an opening force not exceeding 5 lbf.	C	\$291.64
Arts and Culture	West End Performing Arts	962 Ralph David Abernathy Blvd Atlanta, GA 30310	Women's Restroom	Lavatory has unwrapped bottom sink pipes.	\$606.5	Cover (insulate) lavatory bottom supply and drain pipes or reconfigure to protect against contact.	C	\$120.12
Arts and Culture	West End Performing Arts	956 Ralph David Abernathy Blvd Atlanta, GA 30310	Work Area	Sink is mounted at 34.5" (876 mm) above the finished floor to top of rim.	\$804.4	Relocate and/or mount sink at 34" (863 mm) max. above the finished floor to top of rim.	C	\$500.00
Arts and Culture	West End Performing Arts	957 Ralph David Abernathy Blvd Atlanta, GA 30310	Work Area	Sink has unwrapped bottom pipes.	\$804.4	Cover (insulate) sink bottom supply and drain pipes.	C	\$120.12
Arts and Culture	West End Performing Arts	973 Ralph David Abernathy Blvd Atlanta, GA 30310	Green Room	Clothes rod is mounted beyond required reach range for approach provided and is mounted at 59" (1499 mm) above the finished floor.	\$811.3	Lower or install accessible clothes rod at 48" (1219 mm) max. above the finished floor for forward or side approach to object 10" (254 mm) max. deep (ADAAG Fig. 308.3.1).	C	\$55.00
Arts and Culture	West End Performing Arts	974 Ralph David Abernathy Blvd Atlanta, GA 30310	Green Room	Clothes rod is mounted beyond required reach range for approach provided and is mounted at 59" (1499 mm) above the finished floor.	\$811.3	Lower or install accessible clothes rod at 48" (1219 mm) max. above the finished floor for forward or side approach to object 10" (254 mm) max. deep (ADAAG Fig. 308.3.1).	C	\$55.00
Arts and Culture	West End Performing Arts	975 Ralph David Abernathy Blvd Atlanta, GA 30310	Green Room	Shelf is mounted beyond required reach range for approach provided and is mounted at 61" (1549 mm) above the finished floor.	\$811.3	Lower or install accessible shelf at 48" (1219 mm) max. above the finished floor for forward or side approach to object 10" (254 mm) max. deep (ADAAG Fig. 308.3.1).	C	\$55.00
Arts and Culture	West End Performing Arts	953 Ralph David Abernathy Blvd Atlanta, GA 30310	Main Reception	Counter is mounted at 36.75" (933 mm) above the finished floor.	\$904.4.1	Provide an alternative counter or rework main counter to provide a portion that is 36" (914 mm) min. long, mounted at 36" (914 mm) max. above the finished floor to the top (For a parallel approach to counter). Clipboard is provided as an alternative.	C	\$372.14
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Accessible Route From Accessible Parking Spaces Leading to Stage Area	There is no signage posted indicating the location of an accessible entrance.	\$216.6	Post signage indicating location of the accessible entrance serving the facility. If sign is to be placed overhead it shall have a minimum character height of 3" (76 mm).	B	\$149.95
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Main Entrance to Amphitheater	Accessible entrance does not have signage displaying the international symbol of accessibility.	\$216.6	Provide signage at accessible entrance displaying the International symbol of accessibility.	D	\$149.95
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Wheelchair Spaces at Pit Section of Amphitheater	There is no indication of the total number of assistive listening devices provided at wheelchair spaces at pit section area of amphitheater.	\$219.1	Provide hard-wired and/or wireless assistive listening systems as required by Table 219.3. Twenty five percent minimum of receivers shall be hearing aid compatible.	B	\$2,779.95
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Wheelchair Spaces at Mid Section of Amphitheater	There is no indication of the total number of assistive listening devices provided at wheelchair spaces at mid section area of amphitheater.	\$219.1	Provide hard-wired and/or wireless assistive listening systems as required by Table 219.3. Twenty five percent minimum of receivers shall be hearing aid compatible.	B	\$2,779.95
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Wheelchair Accessible Spaces at Mid Section 3 of Amphitheater (Left Side)	There is no indication that the wheelchair spaces at this area provide assistive listening devices.	\$219.1	Provide hard-wired and/or wireless assistive listening systems as required by Table 219.3. Twenty five percent minimum of receivers shall be hearing aid compatible.	B	\$0.00
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Wheelchair Accessible Spaces at Mid Section 3 of Amphitheater (Right Side)	There is no indication that the wheelchair spaces at this area provide assistive listening devices.	\$219.1	Provide hard-wired and/or wireless assistive listening systems as required by Table 219.3. Twenty five percent minimum of receivers shall be hearing aid compatible.	B	\$0.00

**Fulton County ADA Transition Plan
ARTS AND CULTURE
Appendix 7-10**

Department	Bldg Name	Address	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction	Priority	Cost
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Main Entrance to Amphitheater	Mat is not securely attached to the floor.	\$302.2	Provide a securely attached mat with a leveled loop or level cut pile, with texture height that is 0.5" (13 mm) max. and has a firm cushion pad or backing (2010 ADA Fig. 302.2).	A	\$55.00
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Sky Box No. 2 (Interior Area)	Mat is not securely attached to the floor.	\$302.2	Provide a securely attached mat with a leveled loop or level cut pile, with texture height that is 0.5" (13 mm) max. and has a firm cushion pad or backing (2010 ADA Fig. 302.2).	A	\$55.00
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Accessible Route From NE Accessible Parking Spaces Leading to Wheelchair Spaces at Pit Section of Amphitheater	Floor grate opening dimension is 1" (25 mm) in width.	\$302.3	Reinstall floor grate cover or rework floor grate to provide a 0.5" (12 mm) max. wide opening perpendicular to the dominant direction of travel (2010 ADA Fig.302.3).	B	\$250.00
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Accessible Route From NW Accessible Parking Spaces Leading to Wheelchair Spaces at Mid Section of Amphitheater	Floor grate opening dimension is 1" (25 mm) in width.	\$302.3	Install floor grate cover or rework floor grate to provide a 0.5" (12 mm) max. wide opening perpendicular to the dominant direction of travel (2010 ADA Fig.302.3).	B	\$250.00
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Manager's Office	Current layout of furniture encroaches over desk clear floor space.	\$305.3	Relocate furniture to provide a 30" by 48" (762 mm by 1219 mm) min. wheelchair clear floor space at desk (2010 ADA Figs. 305.3-305.5).	C	\$55.00
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Women's Accessible Restroom No. C101	Sanitary napkin dispenser protrudes into walkway, projecting more than 4" (102 mm) from back wall.	\$307.2r	Relocate or recess sanitary napkin dispenser so that it does not project more than 4" (101 mm) from back wall to outer leading edge (2010 ADA Fig. 307.2).	C	\$300.00
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	AED by Women's Accessible Restroom No. C101	AED protrudes into walkway, projecting 7" (178 mm) from back wall, and is mounted at 38" (965 mm) above the finished floor to its bottom leading edge.	\$307.2r	Relocate or recess AED so that it does not project more than 4" (101 mm) from back wall to outer leading edge (2010 ADA Fig. 307.2).	C	\$131.00
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Women's Accessible Restroom No. C101	Baby changing station pull handle is mounted at 49.25" (1251 mm) above the finished floor.	\$308.2.1	Relocate the baby changing station to be on an accessible path and to have a pull down handle no higher than 48 inches and a surface height at or below 34 inches with at least 27 inches high knee clearance when open.	C	\$0.00
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Men's Accessible Restroom No. C102	Baby changing station pull handle is mounted at 49.5" (1257 mm) above the finished floor.	\$308.2.1	Relocate the baby changing station to be on an accessible path and to have a pull down handle no higher than 48 inches and a surface height at or below 34 inches with at least 27 inches high knee clearance when open.	C	\$0.00
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Sky Box No. 1 (Interior Area)	Alarm keypad is mounted at 59.5" (1511 mm) above the finished floor to the highest operable part.	\$308.2.1	Lower or install alarm keypad at 48" (1219 mm) max. above the finished floor to the highest operable part (2010 ADA Fig. 308.2.1).	C	\$278.14
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Sky Box No. 1 (Interior Area)	Thermostat is mounted beyond required reach allowed for approach provided and is mounted at 57.5" (1460 mm) above the finished floor.	\$308.2.1	Lower or install thermostat at 48" (1219 mm) max. above the finished floor for forward approach to object (2010 ADA Fig. 308.2.1).	C	\$378.00
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Sky Box No. 2 (Interior Area)	Paper towel dispenser is mounted beyond required reach allowed for approach provided and is mounted at 51" (1295 mm) above the finished floor to the centerline of the highest operable part.	\$308.2.1	Lower or install paper towel dispenser at 48" (1219 mm) max. above the finished floor to the centerline of the highest operable part (2010 ADA Fig. 308.3.1). Per 36.304(d)(2)(i) Safe harbor. Elements that comply with the corresponding technical requirements and scoping requirements for those elements in the 1991 Standards do not need to be modified in order to comply with the requirements set forth in the 2010 Standards.	C	\$0.00
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Men's Accessible Restroom No. B102	Baby changing station pull handle is mounted at 49.25" (1251 mm) above the finished floor.	\$308.2.1	Relocate the baby changing station to be on an accessible path and to have a pull down handle no higher than 48 inches and a surface height at or below 34 inches with at least 27 inches high knee clearance when open.	C	\$0.00
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Women's Accessible Restroom No. B101	Paper towel dispenser is mounted beyond required reach allowed for approach provided and is mounted at 54.25" (1378 mm) above the finished floor to paper.	\$308.2.1	Lower or install paper towel dispenser at 48" (1219 mm) max. above the finished floor to paper for forward approach to object (2010 ADA Fig. 308.3.1).	C	\$131.00
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Women's Dressing Room No. 111	Coat hook is mounted beyond required reach allowed for approach provided and is mounted at 68.75" (1746 mm) above the finished floor.	\$308.3	Lower or install coat hook at 48" (1219 mm) max. above the finished floor for forward approach to object (2010 ADA Fig. 308.3.1).	C	\$55.00
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Sky Box No. 2 (Interior Area)	Paper towel dispenser control requires pinching and tight grasping to operate.	\$309.4	Replace or retrofit with system operable with one hand, not requiring pinching, tight grasping or turning of the wrist, to operate.	C	\$250.00
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Accessible Route in Front of Second Set of Accessible Parking Spaces on NE Corner	Accessible route has a non-compliant cross slope of 6.6 % that extends 10 ft (3.04 mt).	\$403.3	Rework or repave accessible route to provide a cross slope not exceeding 2%.	B	\$900.00
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Accessible Route in Front of Second Set of Accessible Parking Spaces on NE Corner	Accessible route has a non-compliant cross slope of 6.8 % that extends 10 ft (3.04 mt).	\$403.3	Rework or repave accessible route to provide a cross slope not exceeding 2%.	B	\$900.00
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Accessible Route in Front of Second Set of Accessible Parking Spaces on NE Corner	Accessible route has a non-compliant cross slope of 7.1 % that extends 10 ft (3.04 mt).	\$403.3	Rework or repave accessible route to provide a cross slope not exceeding 2%.	B	\$900.00
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Accessible Route in Front of Second Set of Accessible Parking Spaces on NE Corner	Accessible route has a non-compliant cross slope of 8.1 % that extends 10 ft (3.04 mt).	\$403.3	Rework or repave accessible route to provide a cross slope not exceeding 2%.	B	\$900.00
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Accessible Route in Front of Second Set of Accessible Parking Spaces on NE Corner	Accessible route has a non-compliant cross slope of 7.8 % that extends 10 ft (3.04 mt).	\$403.3	Rework or repave accessible route to provide a cross slope not exceeding 2%.	B	\$900.00
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Accessible Route in Front of Second Set of Accessible Parking Spaces on NE Corner	Accessible route has a non-compliant cross slope of 8.1 % that extends 10 ft (3.04 mt).	\$403.3	Rework or repave accessible route to provide a cross slope not exceeding 2%.	B	\$900.00
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Curb Ramp Leading to Fourth Set of Accessible Parking Spaces on NE Corner	Accessible route has a non-compliant cross slope of 2.9 % that extends 10 ft (3.04 mt).	\$403.3	Rework or repave accessible route to provide a cross slope not exceeding 2%.	B	\$900.00
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Curb Ramp Leading to Fourth Set of Accessible Parking Spaces on NE Corner	Accessible route has a non-compliant cross slope of 2.4 % that extends 5 ft (1.5 mt).	\$403.3	Rework or repave accessible route to provide a cross slope not exceeding 2%.	B	\$450.00
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Curb Ramp Leading to Fourth Set of Accessible Parking Spaces on NE Corner	Accessible route has a non-compliant cross slope of 2.5 % that extends 10 ft (3.04 mt).	\$403.3	Rework or repave accessible route to provide a cross slope not exceeding 2%.	B	\$900.00
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Curb Ramp Leading to Fourth Set of Accessible Parking Spaces on NE Corner	Accessible route has a non-compliant cross slope of 3.0 % that extends 10 ft (3.04 mt).	\$403.3	Rework or repave accessible route to provide a cross slope not exceeding 2%.	B	\$900.00
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Accessible Route From NW Accessible Parking Spaces Leading to Wheelchair Spaces at Mid Section of Amphitheater	Accessible route has a non-compliant cross slope of 4.1 % that extends 10 ft (3.04 mt).	\$403.3	Rework or repave accessible route to provide a cross slope not exceeding 2%.	B	\$950.00
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Accessible Route From NW Accessible Parking Spaces Leading to Wheelchair Spaces at Mid Section of Amphitheater	Accessible route has a non-compliant cross slope of 2.7 % that extends 10 ft (3.04 mt).	\$403.3	Rework or repave accessible route to provide a cross slope not exceeding 2%.	B	\$950.00
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Accessible Route From NW Accessible Parking Spaces Leading to Wheelchair Spaces at Mid Section of Amphitheater	Accessible route has a non-compliant cross slope of 3.2 % that extends 10 ft (3.04 mt).	\$403.3	Rework or repave accessible route to provide a cross slope not exceeding 2%.	B	\$950.00
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Accessible Route From NW Accessible Parking Spaces Leading to Wheelchair Spaces at Mid Section of Amphitheater	Accessible route has a non-compliant cross slope of 2.7 % that extends 10 ft (3.04 mt).	\$403.3	Rework or repave accessible route to provide a cross slope not exceeding 2%.	B	\$950.00

**Fulton County ADA Transition Plan
ARTS AND CULTURE
Appendix 7-10**

Department	Bldg Name	Address	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction	Priority	Cost
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Accessible Route From NW Accessible Parking Spaces Leading to Wheelchair Spaces at Mid Section of Amphitheater	Accessible route has a non-compliant cross slope of 3.2 % that extends 10 ft (3.04 mt).	\$403.3	Rework or repave accessible route to provide a cross slope not exceeding 2%.	B	\$950.00
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Accessible Route From NW Accessible Parking Spaces Leading to Wheelchair Spaces at Mid Section of Amphitheater	Accessible route has a non-compliant running slope of 5.4 %.	\$403.3	Rework or repave accessible route to provide a running slope not exceeding 5%.	B	\$950.00
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Accessible Route From NW Accessible Parking Spaces Leading to Wheelchair Spaces at Mid Section of Amphitheater	Accessible route has a non-compliant cross slope of 2.9 % that extends 10 ft (3.04 mt).	\$403.3	Rework or repave accessible route to provide a cross slope not exceeding 2%.	B	\$950.00
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Accessible Route From NW Accessible Parking Spaces Leading to Wheelchair Spaces at Mid Section of Amphitheater	Accessible route has a non-compliant cross slope of 3.1 % that extends 10 ft (3.04 mt).	\$403.3	Rework or repave accessible route to provide a cross slope not exceeding 2%.	B	\$950.00
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Accessible Route From NW Accessible Parking Spaces Leading to Wheelchair Spaces at Mid Section of Amphitheater	Accessible route has a non-compliant cross slope of 2.9 % that extends 10 ft (3.04 mt).	\$403.3	Rework or repave accessible route to provide a cross slope not exceeding 2%.	B	\$950.00
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Accessible Route From NW Accessible Parking Spaces Leading to Wheelchair Spaces at Mid Section of Amphitheater	Accessible route has a non-compliant cross slope of 2.9 % that extends 10 ft (3.04 mt).	\$403.3	Rework or repave accessible route to provide a cross slope not exceeding 2%.	B	\$950.00
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Accessible Route From Accessible Parking Spaces Leading to Stage Area	Accessible route has a non-compliant cross slope of 5.5 %.	\$403.3	Rework or repave accessible route to provide a cross slope not exceeding 2%.	B	\$450.00
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Accessible Route From Accessible Parking Spaces Leading to Stage Area	Accessible route has a non-compliant cross slope of 5.4 %.	\$403.3	Rework or repave accessible route to provide a cross slope not exceeding 2%.	B	\$450.00
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Accessible Route From Accessible Parking Spaces Leading to Stage Area	Accessible route has a non-compliant cross slope of 5.9 %.	\$403.3	Rework or repave accessible route to provide a cross slope not exceeding 2%.	B	\$450.00
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Accessible Route From Accessible Parking Spaces Leading to Stage Area	Accessible route has a non-compliant cross slope of 5.9 %.	\$403.3	Rework or repave accessible route to provide a cross slope not exceeding 2%.	B	\$450.00
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Accessible Route From Accessible Parking Spaces Leading to Stage Area	Accessible route has a non-compliant cross slope of 4.1 %.	\$403.3	Rework or repave accessible route to provide a cross slope not exceeding 2%.	B	\$450.00
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Men's Dressing Room No. A103	Accessible route has a non-compliant running slope of 7.8 % due to drain slope.	\$403.3	Rework drain slope area to provide a running slope not exceeding 5%.	C	\$450.00
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Accessible Route From NE Accessible Parking Spaces Leading to Wheelchair Spaces at Pit Section of Amphitheater	Accessible route has a 1" (25 mm) vertical change in level due to floor grate cover.	\$403.4	Reinstall floor grate cover to provide a 0.25"-0.5" (6 mm-12 mm) max. change of level, beveled with a slope no greater than 1:2 (2010 ADA Fig. 303.3).	B	\$0.00
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Ambulatory Stall in Men's Accessible Restroom No. B102	Stall doorway opening has a clear width of 23.5" (597 mm).	\$404.2.3	Rework stall doorway (partitions) to provide the required 32" (812 mm) min. clear door or entryway width (2010 ADA Fig. 404.2.3).	C	\$0.00
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Ambulatory Stall in Women's Accessible Restroom No. B101	Stall doorway opening has a clear width of 22.5" (572 mm).	\$404.2.3	Rework stall doorway (partitions) to provide the required 32" (812 mm) min. clear door or entryway width (2010 ADA Fig. 404.2.3).	C	\$898.00
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Sky Box No. 2 (Interior Area)	Maneuvering clearance on the pull side of the door has non-compliant slope of 2.4 %.	\$404.2.4	Rework area to provide the required 18" (457 mm) min. maneuvering clearance on the pull side of the door beyond the latch side and 60" (1524 mm) min. deep clear floor leveled area with slopes not exceeding 1:48 (2010 ADA Fig. 404.2.4.1).	B	\$450.00
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Women's Dressing Room No. 111	Maneuvering clearance on the pull side of the door is 15.75" (400 mm).	\$404.2.4	Rework door side partition to provide the required 18" (457 mm) min. maneuvering clearance on the pull side of the door beyond the latch side and 60" (1524 mm) min. deep clear floor leveled area with slopes not exceeding 1:48 (2010 ADA Fig. 404.2.4.1).	B	\$1,500.00
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Sky Box No. 1 (Interior Area)	Doorway has a 22.5 % at door threshold.	\$404.2.4.4	Rework door threshold to provide a 0.25" (6 mm) max. change of level, beveled with a slope no greater than 1:48 (2010 ADA Fig. 303.3).	B	\$450.00
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Entrance Leading to Stage Area	Door has a non-compliant opening force of 14 lbf.	\$404.2.9	Adjust or replace door closer, maintain door hinges to provide an opening force not to exceed 5 lbf.	B	\$131.00
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Women's Dressing Room No. 111	Door has a non-compliant opening force of 12 lbf.	\$404.2.9	Adjust or replace door closer, maintain door hinges to provide an opening force not to exceed 5 lbf.	B	\$131.00
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Men's Dressing Room No. A103	Door has a non-compliant opening force of 8 lbf.	\$404.2.9	Adjust or replace door closer, maintain door hinges to provide an opening force not to exceed 5 lbf.	B	\$131.00
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Accessible Route From Pit Area Leading to Public Restrooms on NW Side	Second leg of the ramp has a non-compliant surface slope of up to 9.4 %.	\$405.2	Rework ramp to provide a running slope not exceeding 8.33%.	C	\$9,500.00
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Accessible Ramp Leading to Amphitheater Entrance.	Ramp leading to main entrance extends approximately 100 ft (30.4 m) and has running slopes that are extremely steep.	\$405.8	Post sign indicating the location of the accessible entrance to the Amphitheater at the NW entrance of the Public Safety Building. Sign must display the International symbol of accessibility and direct wheelchair users to the elevator lobby on 1st floor (See survey note)	B	\$149.95
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Accessible Route From NE Accessible Parking Spaces Leading to Wheelchair Spaces at Pit Section of Amphitheater	Ramp with a slope of 6.6 % runs for 50ft (15.24 m) and does not have the required handrails.	\$405.8 \$505.4 \$505.5 \$505.6 \$505.10.1	Install handrails on both sides of ramp and mount between 34" and 38" (863 mm - 965 mm) above the ramp surface to top of gripping surfaces, extending 12" (304 mm) min. beyond the top and bottom of the ramp segment (2010 ADA Fig 505.4, 505.5, 505.6, 505.10.1).	B	\$8,360.00
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Accessible Route Leading to First Aid Station	Ramp with a slope of 7.3 % runs 15ft (4.57 m) and does not have the required handrails.	\$405.8 \$505.4 \$505.5 \$505.6 \$505.10.1	Install handrails on both sides of ramp and mount between 34" and 38" (863 mm - 965 mm) above the ramp surface to top of gripping surfaces, extending 12" (304 mm) min. beyond the top and bottom of the ramp segment (2010 ADA Fig 505.4, 505.5, 505.6, 505.10.1) Per site manager, first responders are responsible for taking people to first aid station during an emergency. If this is the case handrails would not be necessary.	C	\$2,760.00
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Curb Ramp Leading to Second Set of Accessible Parking Spaces	Curb ramp has a 9.2 % non-compliant running slope.	\$406	Rework curb ramp to provide a running slope not to exceed 8.33%	B	\$1,180.00
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Curb Ramp Leading to Second Set of Accessible Parking Spaces on NE Corner	Curb ramp (on right side) has a 9.4 % non-compliant running slope.	\$406	Rework curb ramp to provide a running slope not to exceed 8.33%	B	\$1,180.00
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Curb Ramp Leading to Second Set of Accessible Parking Spaces on NE Corner	Curb ramp (on left side) has a 9.0 % non-compliant running slope.	\$406	Rework curb ramp to provide a running slope not to exceed 8.33%	B	\$1,180.00
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Curb Ramp Leading to Fourth Set of Accessible Parking Spaces on NE Corner	Curb ramp on right side has a 9.8 % non-compliant running slope.	\$406	Rework curb ramp to provide a running slope not to exceed 8.33%	B	\$2,360.00
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Curb Ramp Leading to Fourth Set of Accessible Parking Spaces on NE Corner	Curb ramp on left side has a 9.1 % non-compliant running slope.	\$406	Rework curb ramp to provide a running slope not to exceed 8.33%	B	\$0.00

**Fulton County ADA Transition Plan
ARTS AND CULTURE
Appendix 7-10**

Department	Bldg Name	Address	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction	Priority	Cost
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Accessible Stall at Women's Dressing Room No. 111	Water closet is centered at 22" (559 mm) from side wall.	\$604.2	Relocate water closet and center between 16" and 18" (406 mm - 457 mm) from side wall (2010 ADA Fig. 604.2).	C	\$1,029.03
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Right Accessible Toilet Compartment in Women's Accessible Restroom No. B101	Water closet is centered at 18.25" (464 mm) from side wall.	\$604.2	Relocate water closet and center between 16" and 18" (406 mm - 457 mm) from side wall (2010 ADA Fig. 604.2). <i>For a facility that pre-dates the enactment of the ADA this dimension should be considered acceptable per 1990 ADA section 3.2 Dimensional Tolerances and 2010 ADA section 104.1 Construction and Manufacturing Tolerance.</i>	C	\$0.00
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Restroom at Stage Dressing Room No. A116	Lavatory counter encroaches over the water closet clearance reducing it to 29.5" (749 mm).	\$604.3.2	Reconfigure restroom fixtures and partitions to allow the required 60" by 56" (1524 mm by 1422 mm) min. clearance around the water closet (2010 ADA Fig. 604.3.1).	C	\$4,500.00
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Stall No. 1 in Women's Accessible Restroom No. C101	Water closet seat is mounted at 19.75" (502 mm) above the finished floor to top.	\$604.4	Retrofit water closet seat and mount between 17" and 19" (431 mm - 482 mm) above the finished floor to top of seat.	C	\$1,029.03
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Typical Ambulatory Stall in Women's Accessible Restroom No. C101	Water closet seat is mounted at 15.5" (394 mm) above the finished floor to top.	\$604.4	Retrofit water closet seat and mount between 17" and 19" (431 mm - 482 mm) above the finished floor to top of seat.	C	\$1,029.03
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Accessible Toilet Compartment in Men's Accessible Restroom No. B102	Water closet seat is mounted at 20" (508 mm) above the finished floor to top.	\$604.4	Retrofit water closet seat and mount between 17" and 19" (431 mm - 482 mm) above the finished floor to top of seat.	C	\$1,029.03
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Left Accessible Toilet Compartment in Women's Accessible Restroom No. B101	Water closet seat is mounted at 19.5" (495 mm) above the finished floor to top.	\$604.4	Retrofit water closet seat and mount between 17" and 19" (431 mm - 482 mm) above the finished floor to top of seat.	C	\$1,029.03
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Right Accessible Toilet Compartment in Women's Accessible Restroom No. B101	Water closet seat is mounted at 19.75" (502 mm) above the finished floor to top.	\$604.4	Retrofit water closet seat and mount between 17" and 19" (431 mm - 482 mm) above the finished floor to top of seat.	C	\$1,029.03
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Stall No. 1 in Women's Accessible Restroom No. C101	Water closet side wall grab bar is mounted at 53.5" (1359 mm) perpendicular from rear wall to centerline of its outer flange.	\$604.5.1	Install a 42" (1066 mm) min. long side wall grab bar at 54" (1371 mm) min. perpendicular from rear wall to centerline of outer flange and mount at 33" - 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig. 604.5.1)	C	\$150.00
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Stall No. 3 in Women's Accessible Restroom No. C101	Water closet side wall grab bar is mounted at 53.5" (1359 mm) perpendicular from rear wall to centerline of its outer flange.	\$604.5.1	Install a 42" (1066 mm) min. long side wall grab bar at 54" (1371 mm) min. perpendicular from rear wall to centerline of outer flange and mount at 33" - 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig. 604.5.1)	C	\$150.00
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Stall No. 4 in Women's Accessible Restroom No. C101	Water closet side wall grab bar is mounted at 53.5" (1359 mm) perpendicular from rear wall to centerline of its outer flange.	\$604.5.1	Install a 42" (1066 mm) min. long side wall grab bar at 54" (1371 mm) min. perpendicular from rear wall to centerline of outer flange and mount at 33" - 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig. 604.5.1)	C	\$150.00
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Stall No. 5 in Women's Accessible Restroom No. C101	Water closet side wall grab bar is mounted at 53.5" (1359 mm) perpendicular from rear wall to centerline of its outer flange.	\$604.5.1	Install a 42" (1066 mm) min. long side wall grab bar at 54" (1371 mm) min. perpendicular from rear wall to centerline of outer flange and mount at 33" - 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig. 604.5.1)	C	\$150.00
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Accessible Stall at Women's Dressing Room No. 111	Water closet side wall grab bar is mounted at 12.5" (318 mm) perpendicular from rear wall to centerline of its outer flange.	\$604.5.1	Install a 42" (1066 mm) min. long side wall grab bar at 54" (1371 mm) min. perpendicular from rear wall to centerline of outer flange and mount at 33" - 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig. 604.5.1)	C	\$150.00
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Men's Dressing Room No. A103	Water closet side wall grab bar is mounted at 50.5" (1283 mm) perpendicular from rear wall to centerline of its outer flange.	\$604.5.1	Install a 42" (1066 mm) min. long side wall grab bar at 54" (1371 mm) min. perpendicular from rear wall to centerline of outer flange and mount at 33" - 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig. 604.5.1)	C	\$150.00
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Restroom at Stage Dressing Room No. A116	Water closet does not have a side wall grab bar.	\$604.5.1	There is no space for a 42" (1066 mm) min. long side wall grab bar, reconfigure restroom fixture and/or partitions to allow a 42" (1066 mm) min. long side wall grab bar mounted, at 54" (1371 mm) min. from rear wall to centerline of outer flange and mount at 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig. 604.5.1).	C	\$0.00
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Left Accessible Toilet Compartment in Women's Accessible Restroom No. B101	Water closet side wall grab bar is mounted at 53.5" (1359 mm) perpendicular from rear wall to centerline of its outer flange.	\$604.5.1	Install a 42" (1066 mm) min. long side wall grab bar at 54" (1371 mm) min. perpendicular from rear wall to centerline of outer flange and mount at 33" - 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig. 604.5.1)	C	\$380.20
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Stall No. 2 in Women's Accessible Restroom No. C101	Water closet rear wall grab bar is mounted at 36.5" (927 mm) above the finished floor to the top of the gripping surface.	\$604.5.2	Relocate rear wall grab bar and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface.	C	\$150.00
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Restroom at Stage Dressing Room No. A116	Water closet does not have a rear wall grab bar.	\$604.5.2	There is no space for a 36" (914 mm) min. long side wall grab bar, reconfigure restroom fixture and/or partitions to allow a 36" (914 mm) min. long rear wall grab bar and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig. 604.5.2).	C	\$0.00
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Men's Dressing Room No. A103	Water closet flush control is toward the wall side.	\$604.6	Rotate water closet flush control toward the open side or install an electronically controlled mechanism.	C	\$350.00
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Restroom at Stage Dressing Room No. A116	Water closet flush control is toward the wall side.	\$604.6	Rotate water closet flush control toward the open side or install an electronically controlled mechanism.	C	\$0.00
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Stall No. 1 in Women's Accessible Restroom No. C101	Toilet tissue dispenser is mounted at 4.5" (114 mm) in front of the water closet to the centerline of the dispenser.	\$604.7	Relocate toilet tissue dispenser to water closet side wall at 7"-9" (177 mm to 228 mm) in front of the water closet to the centerline of the dispenser and 15"-48" (381 mm to 1219 mm) above the finished floor to the dispenser outlet.	C	\$131.00
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Stall No. 4 in Women's Accessible Restroom No. C101	Toilet tissue dispenser is mounted at 34.5" (876 mm) from rear wall to outer leading edge.	\$604.7	Relocate toilet tissue dispenser to water closet side wall at 7"-9" (177 mm to 228 mm) in front of the water closet to the centerline of the dispenser and 15"-48" (381 mm to 1219 mm) above the finished floor to the dispenser outlet.	C	\$131.00
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Typical Ambulatory Stall in Men's Accessible Restroom No. C102	Toilet tissue dispenser is mounted at 33" (838 mm) from rear wall to outer leading edge.	\$604.7	Relocate toilet tissue dispenser to water closet side wall at 7"-9" (177 mm to 228 mm) in front of the water closet to the centerline of the dispenser and 15"-48" (381 mm to 1219 mm) above the finished floor to the dispenser outlet. <i>Per 36.304(d)(2)(j) Safe harbor. Elements that comply with the corresponding technical requirements and scoping requirements for those elements in the 1991 Standards do not need to be modified in order to comply with the requirements set forth in the 2010 Standards.</i>	C	\$0.00
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Accessible Stall at Women's Dressing Room No. 111	Toilet tissue dispenser is mounted on the wrong wall.	\$604.7	Relocate toilet tissue dispenser to water closet side wall at 7"-9" (177 mm to 228 mm) in front of the water closet to the centerline of the dispenser and 15"-48" (381 mm to 1219 mm) above the finished floor to the dispenser outlet.	C	\$131.00
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Men's Dressing Room No. A103	Toilet tissue dispenser is mounted on the wrong wall.	\$604.7	Relocate toilet tissue dispenser to water closet side wall at 7"-9" (177 mm to 228 mm) in front of the water closet to the centerline of the dispenser and 15"-48" (381 mm to 1219 mm) above the finished floor to the dispenser outlet.	C	\$131.00
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Accessible Stall at Women's Dressing Room No. 111	Accessible toilet compartment (stall) is 59.25" (1505 mm) wide.	\$604.8.1.1	Relocate stall partitions to provide a 60" (1524 mm) min. wide by 59" (1498 mm) min. deep accessible toilet compartment for a floor mounted water closet (2010 ADA Fig. 604.8.1.1).	C	\$0.00
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Men's Dressing Room No. A103	Accessible toilet compartment (stall) is 53.5" (1359 mm) wide.	\$604.8.1.1	Rework partitions and/or fixtures to provide a 60" (1524 mm) min. wide by 59" (1498 mm) min. deep accessible toilet compartment for a floor mounted water closet (2010 ADA Fig. 604.8.1.1).	C	\$2,119.74
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Right Accessible Toilet Compartment in Women's Accessible Restroom No. B101	Accessible toilet compartment (stall) is 58.75" (1492 mm) deep.	\$604.8.1.1	Rework partitions and/or fixtures to provide a 60" by 59" (1524 mm by 1498 mm) min. accessible toilet compartment for a floor mounted water closet (2010 ADA Fig. 604.8.1.1). <i>For a facility that pre-dates the enactment of the ADA this dimension should be considered acceptable per 1990 ADA section 3.2 Dimensional Tolerances and 2010 ADA section 104.1 Construction and Manufacturing Tolerance.</i>	C	\$0.00

**Fulton County ADA Transition Plan
ARTS AND CULTURE
Appendix 7-10**

Department	Bldg Name	Address	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction	Priority	Cost
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Ambulatory Stall in Women's Accessible Restroom No. B101	Door is swing into ambulatory accessible compartment (stall) clear floor space.	\$604.8.2.2	Reverse door swing or reconfigure ambulatory accessible compartment (stall) to provide a 60" (1524 mm) min. depth and a minimum width of 35" and 37" (890 mm - 940 mm) max. (2010 ADA Fig. 604.8.2.)	C	\$0.00
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Ambulatory Stall in Women's Accessible Restroom No. B101	Accessible compartment (stall) door does not have a self closing mechanism.	\$604.8.2.2	Provide a self closing mechanism on door with an opening force not exceeding 5 lbf.	C	\$291.64
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Typical Ambulatory Stall in Women's Accessible Restroom No. C101	Ambulatory accessible compartment stall does not have side wall grab bars.	\$604.8.2.3	Install a 42" (1066 mm) min. long side wall grab bar at 52" (1320 mm) min. from rear wall to centerline of outer flange and mount at 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig. 604.5.1, 604.8.2.)	C	\$760.40
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Typical Ambulatory Stall in Men's Accessible Restroom No. C102	Ambulatory accessible compartment stall does not have side wall grab bars.	\$604.8.2.3	Install a 42" (1066 mm) min. long side wall grab bar at 52" (1320 mm) min. from rear wall to centerline of outer flange and mount at 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig. 604.5.1, 604.8.2.)	C	\$760.40
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Ambulatory Stall in Men's Accessible Restroom No. B102	Ambulatory accessible compartment stall does not have side wall grab bars.	\$604.8.2.3	Install a 42" (1066 mm) min. long side wall grab bar at 52" (1320 mm) min. from rear wall to centerline of outer flange and mount at 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig. 604.5.1, 604.8.2.)	C	\$760.40
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Ambulatory Stall in Women's Accessible Restroom No. B101	Ambulatory accessible compartment stall does not have side wall grab bars.	\$604.8.2.3	Install a 42" (1066 mm) min. long side wall grab bar at 52" (1320 mm) min. from rear wall to centerline of outer flange and mount at 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig. 604.5.1, 604.8.2.)	C	\$760.40
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Men's Accessible Restroom No. C102	Urinal is mounted at 17.25" (438 mm) above the finished floor to top of rim.	\$605.2	Lower urinal and mount at 17" (431 mm) max. above the finished floor to top of rim. (2010 ADA Fig. 605.2). <i>For a facility that pre-dates the enactment of the ADA this dimension should be considered acceptable per 1990 ADA section 3.2 Dimensional Tolerances and 2010 ADA section 104.1 Construction and Manufacturing Tolerance.</i>	C	\$0.00
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Women's Accessible Restroom No. C101	Lavatory is mounted at 34.75" (883 mm) above the finished floor to top of rim.	\$606.3	Relocate lavatory at 34" (863 mm) max. above the finished floor to front end of rim or counter.	C	\$750.00
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Men's Accessible Restroom No. B102	Lavatory is mounted at 34.75" (883 mm) above the finished floor to top of rim.	\$606.3	Relocate lavatory at 34" (863 mm) max. above the finished floor to front end of rim or counter.	C	\$750.00
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Women's Accessible Restroom No. B101	Lavatory is mounted at 35.25" (895 mm) above the finished floor to top of rim.	\$606.3	Relocate lavatory at 34" (863 mm) max. above the finished floor to front end of rim or counter.	C	\$750.00
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Men's Accessible Restroom No. C102	Sink is mounted at 35" (889 mm) above the finished floor to the top.	\$606.3.2	Relocate / rework sink and mount at 34" (863 mm) max. above the finished floor to top of counter.	C	\$500.00
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Sky Box No. 1 (Interior Area)	Sink is mounted at 35.75" (908 mm) above the finished floor to the top.	\$606.3.2	Relocate / rework sink and mount at 34" (863 mm) max. above the finished floor to top of counter.	C	\$1,891.00
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Sky Box No. 2 (Interior Area)	Sink is mounted at 36.5" (927 mm) above the finished floor to the top.	\$606.3.2	Relocate / rework sink and mount at 34" (863 mm) max. above the finished floor to top of counter.	C	\$1,891.00
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Women's Dressing Room No. 111	Sink is mounted at 34.25" (870 mm) above the finished floor to the top.	\$606.3.2	Relocate / rework sink and mount at 34" (863 mm) max. above the finished floor to top of counter.	C	\$500.00
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Men's Dressing Room No. A103	Sink is mounted at 34.25" (870 mm) above the finished floor to the top.	\$606.3.2	Relocate / rework sink and mount at 34" (863 mm) max. above the finished floor to top of counter.	C	\$500.00
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Women's Accessible Restroom No. C101	Lavatory has partially unwrapped bottom sink pipes.	\$606.5	Cover (insulate) lavatory bottom supply and drain pipes or reconfigure to protect against contact.	C	\$120.12
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Shower at Women's Dressing Room No. 111	Roll-in shower entryway is 29.25" (743 mm) wide.	\$608.2	Rework partitions to provide a 36" (915 mm) min. clear entryway width to the shower compartment (Fig. 608.2.3).	C	\$928.73
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Shower at Women's Dressing Room No. 111	Alternate shower stall is 35" (889 mm) deep by 56.5" (1435 mm) wide and does not have the required clear floor space.	\$608.2	Reconfigure room's fixtures and/or offset partitions to provide a 36" (915 mm) min. wide by 60" (1524 mm) min. deep shower stall with the required 30" by 60" (762 mm by 1525 mm) min. clear floor space (Fig. 608.2.3).	C	\$4,194.49
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Restroom at Stage Dressing Room No. A116	Transfer shower stall is 36" by 35.25" (914 by 895 mm) and does not have the required clear floor space.	\$608.2.1	Reconfigure room's fixtures and/or offset partitions to provide a 36" by 36" (914 mm by 914 mm) shower stall with the required 36" by 48" (914 mm by 1219 mm) min. clear floor space (2010 ADA Fig. 608.2.1).	C	\$2,502.43
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Shower at Women's Dressing Room No. 111	Alternate roll-in shower does not have grab bars.	\$608.2.3	Install grab bars on back and side walls at 6" (150 mm) max. from adjacent walls and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig. 608.2.3)	C	\$760.40
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Shower at Men's Dressing Room No. A103	Alternate shower stall is 35" by 56.5" (889 by 1435 mm) and does not have the required clear floor space.	\$608.2.3	Reconfigure room's fixtures and/or offset partitions to provide a 36" (915 mm) min. wide by 60" (1524 mm) min. deep shower stall with the required 30" by 60" (762 mm by 1525 mm) min. clear floor space (Fig. 608.2.3).	C	\$4,194.49
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Shower at Men's Dressing Room No. A103	Roll-in shower does not have grab bars.	\$608.3.1	Install grab bars on back and side walls at 6" (150 mm) max. from adjacent walls and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig. 608.3.1)	C	\$760.40
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Restroom at Stage Dressing Room No. A116	Transfer shower does not have grab bars.	\$608.3.1	Install grab bars across the control wall and back wall to a point 18" (457 mm) from the control wall, and mount between 33" and 36" (838 mm - 914 mm) above the finished floor to the top of the gripping surface (2010 ADA Fig. 608.3.1).	C	\$380.20
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Restroom at Stage Dressing Room No. A116	Transfer shower does not have a transfer seat.	\$608.4	Provide an L-shaped seat with the front edge mounted at 15"-16" (380 mm - 405 mm) max. from the wall, the end of the "L" shape shall be 22"-23" (560 mm - 585 mm) max. long and the front edge of the "L" portion 14"-15" (355 mm - 380 mm) max. from the wall.	C	\$476.71
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Shower at Men's Dressing Room No. A103	Alternate roll-in shower controls are mounted at 50" (1270 mm) above the finished floor to the highest operable part.	\$608.5.3	Relocate and mount shower controls above the grab bar at 48" (1220 mm) max. above the finished floor to the highest operable part, on the side wall farthest from the entry (For a alternate roll-in shower with out a seat only) (2010 ADA Fig. 608.5.3)	C	\$0.00
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Shower at Women's Dressing Room No. 111	Shower head is a fixed-type unit.	\$608.6	Replace or install additional shower spray unit with a hose that is 59" (1500 mm) min. in length and serves both as a fixed and hand-held unit.	C	\$295.57
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Shower at Men's Dressing Room No. A103	Shower head is a fixed-type unit.	\$608.6	Replace or install additional shower spray unit with a hose that is 59" (1500 mm) min. in length and serves both as a fixed and hand-held unit.	C	\$295.12
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Restroom at Stage Dressing Room No. A116	Shower head is a fixed-type unit.	\$608.6	Replace or install additional shower spray unit with a hose that is 59" (1500 mm) min. in length and serves both as a fixed and hand-held unit.	C	\$295.12
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Shower at Women's Dressing Room No. 111	Roll-in shower stall has a 5.25" (133 mm) high curb.	\$608.7	Rework roll-in shower curb so it does not exceed 0.5" (12 mm) in height.	C	\$0.00
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Shower at Men's Dressing Room No. A103	Roll-in shower stall has a 5" (127 mm) high curb.	\$608.7	Rework roll-in shower curb so it does not exceed 0.5" (12 mm) in height.	C	\$0.00
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Restroom at Stage Dressing Room No. A116	Transfer shower stall has a 5" (127 mm) high curb.	\$608.7	Rework transfer shower to provide a beveled curb that does not exceed 0.5" (12 mm) in height.	C	\$0.00
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Toilet No. 1 in Women's Accessible Restroom No. C101	Toilet tissue dispenser is mounted 3.25" (83 mm) over the side wall grab bar.	\$609.3	Relocate toilet tissue dispenser to provide a clear space between the side wall grab bar and projecting objects above of 12" (305 mm) min. (2010 ADA Fig. 609.3).	C	\$0.00
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Stall No. 2 in Women's Accessible Restroom No. C101	Toilet tissue dispenser is mounted 4.75" (121 mm) over the side wall grab bar.	\$609.3	Relocate toilet tissue dispenser to provide a clear space between the side wall grab bar and projecting objects above of 12" (305 mm) min. (2010 ADA Fig. 609.3).	C	\$131.00
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Stall No. 3 in Women's Accessible Restroom No. C101	Toilet tissue dispenser is mounted 6.25" (159 mm) over the side wall grab bar.	\$609.3	Relocate toilet tissue dispenser to provide a clear space between the side wall grab bar and projecting objects above of 12" (305 mm) min. (2010 ADA Fig. 609.3).	C	\$131.00
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Stall No. 5 in Women's Accessible Restroom No. C101	Toilet tissue dispenser is mounted 2.5" (64 mm) over the side wall grab bar.	\$609.3	Relocate toilet tissue dispenser to provide a clear space between the side wall grab bar and projecting objects above of 12" (305 mm) min. (2010 ADA Fig. 609.3).	C	\$131.00
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Accessible Stall in Men's Accessible Restroom No. C102	Toilet seat cover dispenser is mounted 4" (102 mm) over the side wall grab bar.	\$609.3	Relocate toilet seat cover dispenser to provide a clear space between the side wall grab bar and projecting objects above of 12" (305 mm) min. (2010 ADA Fig. 609.3).	C	\$131.00
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Accessible Stall at Women's Dressing Room No. 111	Grab bar is mounted at 1" (25 mm) above the toilet tank	\$609.3	Relocate/replace grab bar and mount at 1.5" (38 mm) min. above the toilet tank (2010 ADA Fig. 609.3).	C	\$150.00

Fulton County ADA Transition Plan
ARTS AND CULTURE
Appendix 7-10

Department	Bldg Name	Address	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction	Priority	Cost
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Accessible Toilet Compartment in Men's Accessible Restroom No. B102	Water closet rear wall grab bar is mounted at 1.25" (32 mm) above the water flush control pipes.	§609.3	Relocate/replace water closet rear wall grab bar and mount at 1.5" (38 mm) clear from the water closet pipes (2010 ADA Fig. 609.3).	C	\$150.00
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Accessible Toilet Compartment in Men's Accessible Restroom No. B102	Toilet tissue dispenser is mounted 7.5" (190 mm) over the side wall grab bar.	§609.3	Relocate toilet seat cover dispenser to provide a clear space between the side wall grab bar and projecting objects above of 12" (305 mm) min. (2010 ADA Fig. 609.3).	C	\$131.00
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Left Accessible Toilet Compartment in Women's Accessible Restroom No. B101	Toilet tissue dispenser is mounted 5" (127 mm) over the side wall grab bar.	§609.3	Relocate toilet seat cover dispenser to provide a clear space between the side wall grab bar and projecting objects above of 12" (305 mm) min. (2010 ADA Fig. 609.3).	C	\$131.00
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Right Accessible Toilet Compartment in Women's Accessible Restroom No. B101	Toilet tissue dispenser is mounted 6.75" (171 mm) over the side wall grab bar.	§609.3	Relocate toilet tissue dispenser to provide a clear space between the side wall grab bar and projecting objects above of 12" (305 mm) min. (2010 ADA Fig. 609.3).	C	\$131.00
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Sky Box No. 2 (Interior Area)	Permanent room identifying signage does not have Braille or raised characters and is mounted on the door leaf.	§703.4.1	Provide signage on latch side with raised characters and grade 2 Braille, mounted at 48" min. measured from the baseline of the lowest tactile character and 60" max. from the baseline of the highest tactile character (2010 ADA Fig. 703.4.1).	B	\$149.95
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Men's Accessible Restroom No. C102	Permanent room identifying signage is mounted at 63.25" (1607 mm) to the baseline of the highest tactile character.	§703.4.1	As best practice provide signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. to the baseline of the highest tactile character (2010 ADA Fig. 703.4.1). Per 36.304(d)(2)(i) Safe harbor. Elements that comply with the corresponding technical requirements and scoping requirements for those elements in the 1991 Standards do not need to be modified in order to comply with the requirements set forth in the 2010 Standards.	D	\$55.00
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Sky Box No. 1 (Interior Area)	Permanent room identifying signage is mounted on the door leaf.	§703.4.1	Provide signage on latch side with raised characters and grade 2 Braille, mounted at 48 inches min. measured from the baseline of the lowest tactile character and 60 inches max. from the baseline of the highest tactile character (2010 ADA Fig. 703.4.1).	D	\$55.00
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Wardrobe Room No. A106	Permanent room identifying signage is mounted at 61.75" (1568 mm) to the baseline of the highest tactile character.	§703.4.1	We recommend as best practice providing signage on latch side with raised characters and grade 2 Braille, mounted at 48" min. measured from the baseline of the lowest tactile character and 60" max. to the baseline of the highest tactile character (2010 ADA Fig. 703.4.1). Per 36.304(d)(2)(i) Safe harbor. Elements that comply with the corresponding technical requirements and scoping requirements for those elements in the 1991 Standards do not need to be modified in order to comply with the requirements set forth in the 2010 Standards.	D	\$55.00
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Stage Dressing Room No. A116	Permanent room identifying signage is mounted at 61.75" (1568 mm) to the baseline of the highest tactile character.	§703.4.1	As best practice providing signage on latch side with raised characters and grade 2 Braille, mounted at 48" min. measured from the baseline of the lowest tactile character and 60" max. to the baseline of the highest tactile character (2010 ADA Fig. 703.4.1). Per 36.304(d)(2)(i) Safe harbor. Elements that comply with the corresponding technical requirements and scoping requirements for those elements in the 1991 Standards do not need to be modified in order to comply with the requirements set forth in the 2010 Standards.	D	\$55.00
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Men's Accessible Restroom No. B102	Permanent room identifying signage is mounted at 63.25" (1607 mm) to the baseline of the highest tactile character.	§703.4.1	As best practice providing signage on latch side with raised characters and grade 2 Braille, mounted at 48" min. measured from the baseline of the lowest tactile character and 60" max. to the baseline of the highest tactile character (2010 ADA Fig. 703.4.1). Per 36.304(d)(2)(i) Safe harbor. Elements that comply with the corresponding technical requirements and scoping requirements for those elements in the 1991 Standards do not need to be modified in order to comply with the requirements set forth in the 2010 Standards.	D	\$55.00
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Women's Accessible Restroom No. B101	Permanent room identifying signage is mounted at 62.75" (1594 mm) to the baseline of the highest tactile character.	§703.4.1	As best practice providing signage on latch side with raised characters and grade 2 Braille, mounted at 48" min. measured from the baseline of the lowest tactile character and 60" max. to the baseline of the highest tactile character (2010 ADA Fig. 703.4.1). Per 36.304(d)(2)(i) Safe harbor. Elements that comply with the corresponding technical requirements and scoping requirements for those elements in the 1991 Standards do not need to be modified in order to comply with the requirements set forth in the 2010 Standards.	D	\$55.00
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Women's Accessible Restroom No. C101	Permanent room identifying signage is mounted at 63.25" (1607 mm) to the baseline of the highest tactile character.	§703.4.1	As best practice providing signage on latch side with raised characters and grade 2 Braille, mounted at 48" min. measured from the baseline of the lowest tactile character and 60" max. to the baseline of the highest tactile character (2010 ADA Fig. 703.4.1). Per 36.304(d)(2)(i) Safe harbor. Elements that comply with the corresponding technical requirements and scoping requirements for those elements in the 1991 Standards do not need to be modified in order to comply with the requirements set forth in the 2010 Standards.	D	\$55.00
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Wheelchair Spaces at Pit Section of Amphitheater	There is no signage indicating that assistive listening systems are provided in pit wheelchair sections of the amphitheater.	§703.7.2.4	Provide signage for assistive listening system identified by a symbol indicating International Symbol of Access for Hearing Loss (2010 ADA Fig. 703.7.2.4).	B	\$149.95
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Wheelchair Spaces at Mid Section of Amphitheater	There is no signage indicating that assistive listening systems are provided in mid wheelchair sections of the amphitheater.	§703.7.2.4	Provide signage for assistive listening system identified by a symbol indicating International Symbol of Access for Hearing Loss (2010 ADA Fig. 703.7.2.4).	B	\$149.95
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Wheelchair Spaces at Pit Section of Amphitheater	It is not clear if the current location of wheelchair spaces at the pit section allow lines of sight over the head of seated spectators in the first row in front of the wheelchair spaces.	§802.1.1	Ensure that spectators seated in wheelchair spaces are afforded lines of sight over the head of seated spectators in the first row in front of the wheelchair spaces.	B	\$0.00
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Wheelchair Spaces at Pit Section of Amphitheater	There is no indication that the companion seat provided next to each wheelchair space during events is equivalent in size, quality, comfort and amenities to the ones provided in the immediate area	§802.3	Provide a movable companion seat that provides shoulder alignment with adjacent wheelchair spaces, that is the equivalent in size, quality, comfort and amenities to the immediate area (2010 ADA Figs. 802.2).	B	\$0.00
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Wheelchair Spaces at Mid Section of Amphitheater	There is no indication that the companion seat provided next to each wheelchair space during events is equivalent in size, quality, comfort and amenities to the ones provided in the immediate area	§802.3	Provide a movable companion seat that provides shoulder alignment with adjacent wheelchair spaces, that is the equivalent in size, quality, comfort and amenities to the immediate area (2010 ADA Figs. 802.2).	B	\$0.00
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Wheelchair Spaces at Pit Section of Amphitheater	There is no indication that the aisle seat are identified by a sign or marker during events.	§802.4.2	Provide signage identifying the designated access aisle seat.	B	\$149.95
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Shower at Women's Dressing Room No. 111	Dressing room bench is 18.5" (470 mm) deep by 34" (864 mm) wide.	§803.4	Not enough space for a standard bench inside. Provide a bench adjacent to this area that is 20" to 24" (508 mm - 609 mm) max. deep, and 42" (1065 mm) min. long, fixed to a wall, and mounted 17" min. to 19" max. (431 mm-482 mm) above the finished floor to top of bench.	C	\$452.12
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Shower at Men's Dressing Room No. A103	Dressing room bench is 18.25" (464 mm) deep by 31.5" (800 mm) wide	§803.4	Not enough space for a standard bench inside. Provide a bench adjacent to this area that is 20" to 24" (508 mm - 609 mm) max. deep, and 42" (1065 mm) min. long, fixed to a wall, and mounted 17" min. to 19" max. (431 mm-482 mm) above the finished floor to top of bench.	C	\$452.12
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Sky Box No. 1 (Interior Area)	Sink has unwrapped bottom pipes.	§804.4	Cover (insulate) sink bottom supply and drain pipes.	C	\$120.12
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Sky Box No. 2 (Interior Area)	Sink has unwrapped bottom pipes.	§804.4	Cover (insulate) sink bottom supply and drain pipes.	C	\$120.12
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Sky Box No. 2 (Interior Area)	Second sink has unwrapped bottom pipes.	§804.4	Cover (insulate) sink bottom supply and drain pipes.	C	\$0.00
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Sky Box No. 2 (Interior Area)	Second sink is mounted at 36.25" (921 mm) above the finished floor to top of rim.	§804.4	Relocate and/or mount sink at 34" (863 mm) max. above the finished floor to top of rim.	C	\$0.00
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Sky Box No. 2 (Interior Area)	Third sink is mounted at 36.25" (921 mm) above the finished floor to top of rim.	§804.4	Relocate and/or mount sink at 34" (863 mm) max. above the finished floor to top of rim.	C	\$0.00

**Fulton County ADA Transition Plan
ARTS AND CULTURE
Appendix 7-10**

Department	Bldg Name	Address	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction	Priority	Cost
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Sky Box No. 2 (Interior Area)	Third sink has unwrapped bottom pipes.	\$804.4	Cover (insulate) sink bottom supply and drain pipes.	C	\$0.00
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Stage Dressing Room No. A116	Sink is mounted at 36" (914 mm) above the finished floor to top of rim.	\$804.4	Relocate and/or mount sink at 34" (863 mm) max. above the finished floor to top of rim.	C	\$500.00
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Sky Box No. 1 (Interior Area)	Wall cabinets over the work surface are mounted at 56" (1422 mm) above the finished floor to the bottom shelf.	\$804.5	Relocate wall cabinets, above the work surface, and mount at 48" (1219 mm) max. above the finished floor to the bottom shelf. Handles shall be mounted as close to the bottom as possible.	C	\$1,891.00
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Sky Box No. 2 (Interior Area)	Wall cabinets over the work surface are mounted at 56.75" (1441 mm) above the finished floor to the bottom shelf.	\$804.5	Relocate wall cabinets, above the work surface, and mount at 48" (1219 mm) max. above the finished floor to the bottom shelf. Handles shall be mounted as close to the bottom as possible.	C	\$0.00
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Sky Box No. 2 (Interior Area)	Wall cabinets over the work surface are mounted at 56.75" (1441 mm) above the finished floor to the bottom shelf.	\$804.5	Relocate wall cabinets, above the work surface, and mount at 48" (1219 mm) max. above the finished floor to the bottom shelf. Handles shall be mounted as close to the bottom as possible.	C	\$0.00
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Stage Dressing Room No. A116	Wall cabinets over the work surface are mounted at 54.75" (1391 mm) above the finished floor to the bottom shelf.	\$804.5	Relocate wall cabinets, above the work surface, and mount at 48" (1219 mm) max. above the finished floor to the bottom shelf. Handles shall be mounted as close to the bottom as possible.	C	\$1,891.00
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Stage Dressing Room No. A116	Make up counter has a non-compliant 25" (635 mm) knee clearance.	\$902.2	Provide make up counter with a corresponding 30" by 48" (762 mm by 1219 mm) clear floor space. 27" (685 mm) min. bottom knee clearance above the finished floor and a 17" (430 mm) horizontal projection.	C	\$372.14
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Sky Box No. 1 (Exterior Area)	There are 24 seating spaces at this area. There are no accessible seating spaces provided.	\$902.3	Replace tables to provide 5% accessible seating spaces with the table or counter mounted between 28" (710 mm) min. and 34" (865 mm) max. above the finished floor or ground. The table must provide a knee clearance that is at least 27" (685 mm) high, 30" (762 mm) wide and with a horizontal projection that is 17" (432 mm) deep. With it's corresponding 30" by 48" (762 mm by 1219 mm) min. wheelchair clear floor space (2010 ADA Figs. 305.5 (a), 306.2 (a)(b) and 306.3 (a)(b)). The accessible seating spaces must be dispersed throughout the different ambiances of the sky box (i.e. interior and exterior bar area, interior and interior dining area, lounge areas etc). We also recommend posting signage displaying the international symbol of accessibility indicating that assistance is available upon request	B	\$744.28
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Sky Box No. 2 (Interior Area)	There are no accessible tables provided.	\$902.3	Replace tables to provide 5% accessible seating spaces with the table or counter mounted between 28" (710 mm) min. and 34" (865 mm) max. above the finished floor or ground. The table must provide a knee clearance that is at least 27" (685 mm) high, 30" (762 mm) wide and with a horizontal projection that is 17" (432 mm) deep. With it's corresponding 30" by 48" (762 mm by 1219 mm) min. wheelchair clear floor space (2010 ADA Figs. 305.5 (a), 306.2 (a)(b) and 306.3 (a)(b)). The accessible seating spaces must be dispersed throughout the different ambiances of the sky box (i.e. interior and exterior bar area, interior and interior dining area, lounge areas etc). We also recommend posting signage displaying the international symbol of accessibility indicating that assistance is available upon request	B	\$372.14
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Sky Box No. 2 (Interior Area)	There is a total of 18 seating spaces. No accessible seating spaces have been provided.	\$902.3	Replace tables to provide 5% accessible seating spaces with the table or counter mounted between 28" (710 mm) min. and 34" (865 mm) max. above the finished floor or ground. The table must provide a knee clearance that is at least 27" (685 mm) high, 30" (762 mm) wide and with a horizontal projection that is 17" (432 mm) deep. With it's corresponding 30" by 48" (762 mm by 1219 mm) min. wheelchair clear floor space (2010 ADA Figs. 305.5 (a), 306.2 (a)(b) and 306.3 (a)(b)). The accessible seating spaces must be dispersed throughout the different ambiances of the sky box (i.e. interior and exterior bar area, interior and interior dining area, lounge areas etc). We also recommend posting signage displaying the international symbol of accessibility indicating that assistance is available upon request	B	\$372.14
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Sky Box No. 2 (Exterior Area)	There is a total of 18 seating spaces. No accessible seating spaces have been provided.	\$902.3	Replace tables to provide 5% accessible seating spaces with the table or counter mounted between 28" (710 mm) min. and 34" (865 mm) max. above the finished floor or ground. The table must provide a knee clearance that is at least 27" (685 mm) high, 30" (762 mm) wide and with a horizontal projection that is 17" (432 mm) deep. With it's corresponding 30" by 48" (762 mm by 1219 mm) min. wheelchair clear floor space (2010 ADA Figs. 305.5 (a), 306.2 (a)(b) and 306.3 (a)(b)). The accessible seating spaces must be dispersed throughout the different ambiances of the sky box (i.e. interior and exterior bar area, interior and interior dining area, lounge areas etc). We also recommend posting signage displaying the international symbol of accessibility indicating that assistance is available upon request	B	\$372.14
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Women's Accessible Restroom No. C101	Baby changing station is mounted at 34.5" (876 mm) above the finished floor to the top of the surface.	\$902.3	Relocate the baby changing station to be on an accessible path and to have a pull down handle no higher than 48 inches and a surface height at or below 34 inches with at least 27 inches high knee clearance when open.	C	\$131.00
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Men's Accessible Restroom No. C102	Baby changing station is mounted at 35" (889 mm) above the finished floor to the top of the surface.	\$902.3	Relocate the baby changing station to be on an accessible path and to have a pull down handle no higher than 48 inches and a surface height at or below 34 inches with at least 27 inches high knee clearance when open.	C	\$131.00
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Sky Box No. 1 (Interior Area)	There are no accessible tables provided.	\$902.3	Replace tables to provide 5% accessible seating spaces with the table or counter mounted between 28" (710 mm) min. and 34" (865 mm) max. above the finished floor or ground. The table must provide a knee clearance that is at least 27" (685 mm) high, 30" (762 mm) wide and with a horizontal projection that is 17" (432 mm) deep. With it's corresponding 30" by 48" (762 mm by 1219 mm) min. wheelchair clear floor space (2010 ADA Figs. 305.5 (a), 306.2 (a)(b) and 306.3 (a)(b)). The accessible seating spaces must be dispersed throughout the different ambiances of the sky box (i.e. interior & exterior bar area, interior & interior dining area, lounge areas etc). We also recommend posting signage displaying the international symbol of accessibility indicating that assistance is available upon request	C	\$750.00
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Sky Box No. 1 (Interior Area)	High chair counter surface is mounted at 43" (1092 mm) above the finished floor.	\$902.3	Rework to provide the top of the counter surface mounted between 28" (710 mm) min. and 34" (865 mm) max. above the finished floor or ground.	C	\$0.00
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Sky Box No. 2 (Interior Area)	Bar counter surface is mounted at 42" (1067 mm) above the finished floor.	\$902.3	Provide an accessible table adjacent to this area or rework to provide the a portion of the bar counter surface mounted between 28" (710 mm) min. and 34" (865 mm) max. above the finished floor or ground.	C	\$372.14
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Men's Accessible Restroom No. B102	Baby changing station is mounted at 34.5" (876 mm) above the finished floor to the top of the surface.	\$902.3	Relocate the baby changing station to be on an accessible path and to have a pull down handle no higher than 48 inches and a surface height at or below 34 inches with at least 27 inches high knee clearance when open.	C	\$131.00
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Women's Accessible Restroom No. B101	Baby changing station is mounted at 35.25" (895 mm) above the finished floor to the top of the surface.	\$902.3	Relocate the baby changing station to be on an accessible path and to have a pull down handle no higher than 48 inches and a surface height at or below 34 inches with at least 27 inches high knee clearance when open.	C	\$131.00

**Fulton County ADA Transition Plan
ARTS AND CULTURE
Appendix 7-10**

Department	Bldg Name	Address	Room No. Name	Physical Obstacle	ADA Code	Proposed Correction	Priority	Cost
Arts and Culture	Wolf Creek Amphitheater	3025 Merk Road Atlanta, GA 30349	Concession Stand No. 1 and No. 2	Counter is mounted at 36.25" (921 mm) above the finished floor.	§904.4.1	Provide an alternative counter or rework main counter to provide a portion that is 36" (914 mm) min. long, mounted at 36" (914 mm) max. above the finished floor to the top. <i>For a facility that pre- dates the enactment of the ADA this dimension should be considered acceptable per 1990 ADA section 3.2 Dimensional Tolerances and 2010 ADA section 104.1 Construction and Manufacturing Tolerance.</i>	C	\$0.00