



NOTES:

1. CASING TO BE STEEL PIPE (ROUND) WITH 45° BEVELED EDGES.
2. ALL CUTS TO BE SQUARED TO END.
3. JOIN ALL CASINGS WITH DOUBLE BEAD BUTT WELDS.
4. AUGER HEAD DIAMETER CANNOT EXCEED DIAMETER OF CASING BY MORE THAN 2".
5. BORING AND CASING SHALL BE INSTALLED SIMULTANEOUSLY.
6. CARRIER PIPES 6" OR LARGER REQUIRE BORE AND STEEL CASING.
7. CASING PIPE SHALL HAVE A PROTECTIVE COATING CONSISTING OF A COAL-TAR PRIMER COAT AND AN APPLICATION OF HOT COAL-TAR ENAMEL 3/32" (±1/32") THICK PLUS A BONDED 15 LB. ASBESTOS WRAP.
8. PIT TO BE NO CLOSER THAN 4' BEHIND CURB OR EDGE OF PAVEMENT.
9. TYPICAL PIT IS 32' LONG BY 10' WIDE.
10. CASING SHALL BE MANUFACTURED FROM STEEL CONFORMING TO ASTM:A 139, GRADE B.
11. THREE STAINLESS STEEL CASING SPACERS ARE REQUIRED PER JOINT.
12. CARRIER PIPE SHALL BE DUCTILE IRON.
13. FIELD LOCKING GASKETS REQUIRED INSIDE OF CASING.
14. ALL BORING MUST BE APPROVED AND A PERMIT OBTAINED FROM FULTON COUNTY PUBLIC WORKS (404) 612-7400 AND AUTHORITY HAVING JURISDICTION AS REQUIRED.
15. REFER TO DETAIL 107 FOR CASING SPECIFICATIONS.

FULTON COUNTY STANDARD DETAIL 129
CASING/PIPE SUPPORT INSTALLATION

DATE	REVISIONS	DATE	REVISIONS
M/Y	XXX	M/Y	XXX

DGS/DRN/CHKD: XXX
APPROVED: XXX
DATE: XX-X-XX



FULTON COUNTY PUBLIC WORKS
141 PRYOR ST. ATLANTA, GA. 30303
404-612-7400 FAX: 404-224-0498

DRAWING NO.
129